



Procurement Bid Office  
Customer Center 1<sup>st</sup> Floor, Room 002  
21 W. Church Street  
Jacksonville, Florida 32202

February 26, 2020

ADDENDUM NUMBER: **Four (4)**

---

TITLE: **STEEL TRANSMISSION POLES FOR THE CIRCUIT 838 STRUCTURES #5, 6, 7, 10 AND #11 REPLACEMENT**

---

JEA RFQ NUMBER: **98762**

---

BID DUE DATE: **February 28, 2020**

---

TIME OF RECEIPT: **12:00 PM**

---

TIME OF OPENING: **2:00 PM**

---

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS in Red below:**

1. **Question:** In the attached specifications please see page 6, 4.1.1 requesting 225 bail steps ( drawing 23 detail); and 98762 Appendix B , form suggests to include 225 step bolts. Are bail steps and bolts required or is the Appendix B wording to mean bail steps?
2. **Answer:** Refer to the Revised and Replaced – Appendix B – Form – Page 2 of 2, Bid Item 8 – wording changed from Step bolts to **Bail steps**. Only **Bail steps** are requested per the project specific tech specs and shown in the attachment details.

**\*\*Acknowledge receipt of this Addendum on the submitted Bid Form\*\***