



Building Community®

Procurement Bid Office
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

May 22, 2020

Addendum Number: Two (2)

Title: 99365 – Supply of two activated carbon injection systems and sorbent materials

JEA Solicitation Number: 99365

Response Due Date: June 10, 2020

Due Date Time: 12:00 PM

Submit by Email to: lovgrd@jea.com

This addendum is for the purpose of making the following additions, deletions and changes.

The Bid Due date has been changed to: June 10, 2020, 12:00 PM (Noon) by: lovgrd@jea.com.

Supplier Inquiry: United Conveyor Corp (UCC) has done many of this type systems. One concern we have with the bid requirements is the very low feed rate of 2 - 40 lb/hr. We have not seen feeds as low as 2. Would it be possible to offer a system with 4 - 40 lb/hr and not be disqualified?

JEA Response: JEA can handle 4-40 lb/ hour so it should be fine.

Acknowledge receipt of this addendum on the Response Form