



Building Community®

Procurement Bid Office
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

August 10, 2020~~August 7, 2020~~

ADDENDUM NUMBER: Three (3)

TITLE: Nassau Substation and Otis Road Substation Civil and Electrical 2020

JEA ITN NUMBER: 99702

RESPONSE DUE DATE: August 11, 2020

TIME OF RECEIPT: 10:00 AM

TIME OF OPENING: 10:00 AM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

Question:

1. Sheet E-4 Note 1 calls for intermediate post to be grounded every 40' but the fence is 100' per side. Do we stretch this out 50' and only do the center post or do we drop back and do every 30' do 2 on the intermediate post?

Answer:

1. Please provide grounding of the intermediate posts every 30', in lieu of every 40', as the existing Note 1 of Sheet E-4 requires.

Acknowledge receipt of this addendum on the Response Form