



Water, Wastewater & Reclaimed Water Design Guidelines

JEA Water, Wastewater, and Reclaimed Water Design Guidelines

Revised January 2025

Section 1.0 General Information	9
1.1 General	9
1.1.1 Definitions.....	10
1.2 Getting Started.....	11
1.2.1 Service Availability Request.....	11
1.2.1.1 Common Questions/Issues when submitting Availability Requests	11
1.2.2 Verification of JEA Points of Service.....	12
1.2.3 Update Existing Availability Letter Request	12
1.2.4 Project Phasing.....	12
1.2.5 Water, Wastewater and Reclaimed Water As-Built Drawing Request.....	13
1.2.6 Special Service Considerations.....	13
1.2.6.1 Alternative Connection Review Team (ACRT).....	13
1.2.6.2 Sewer Locate	14
1.2.6.3 Reclaimed Water Service Area.....	14
1.2.6.4 Septic Tank Phase Out Areas	14
1.2.6.5 Forms for Signature	15
1.3 Development Meeting.....	15
1.4 Modifications to Existing JEA Systems.....	16
1.5 Master Plan Requirements	16
1.6 Connection Pressure Letters.....	18
1.6.1 Force Main Connection Pressure Letter	18
1.6.2 Reuse Supply Pressure Letter	19
1.7 Project Acceptance Requirements.....	19
1.8 Submittal Expiration	19
Section 2.0 Infill Development	19
2.1 Availability Letter Request	19
2.1.1 Common Questions/Issues when submitting Availability Requests	20
2.1.2 Use of existing services	21

JEA Water, Wastewater, and Reclaimed Water Design Guidelines

2.1.3	Connections to 2-inch water main	21
2.1.4	Sewer POC on non-standard main sizes	21
2.2	Locates	22
2.2.1	Sewer Locates	22
2.2.2	Water Locates	22
2.3	Infill Layout.....	23
2.4	Special Estimate Determination	23
2.5	New Service Application	24
2.5.1	Existing Service to be used	24
2.5.2	JEA to Install New Service	25
2.6	Builder Installed Services.....	25
Section 3.0 Design Guidelines		27
3.0	General	27
3.1	Order of Precedence	28
3.2	JEA Plan Approval Effective Dates.....	28
3.3	JEA Review Time Frames.....	29
3.3.1	Preliminary Plan Submittal Review Time	29
3.3.2	Subsequent Plan Submittal Review Time.....	29
3.3.3	Revision Plan Submittal Review Time	29
3.3.4	Preliminary As-Built Plan Submittal Review Time.....	29
3.3.5	Subsequent As-Built Final Plan Submittal Review Time.....	29
3.4	Design Review	29
3.4.1	General Plan Submittal Requirements for New Development	29
3.4.2	Water Plan Submittal Requirements.....	31
3.4.3	Wastewater Plan Submittal Requirements.....	32
3.4.4	Reclaimed Water Plan Submittal Requirements.....	32
3.4.5	Horizontal Directional Drill/Jack & Bore Plan Submittal Requirements.....	33
3.4.6	Utility Construction Notes	33
3.5	Preliminary Plan Review Package	35

JEA Water, Wastewater, and Reclaimed Water Design Guidelines

3.6	Subsequent Plan Review	36
3.7	Approved Plan Revisions.....	37
3.7.1	Revision to Approved Plans.....	37
3.7.2	Revision to Approved Plans with Permit.....	37
3.8	Permits.....	38
3.8.1	Water & Wastewater Permit Submittal.....	38
3.8.2	JEA Permit Extension Request	39
3.8.3	JEA Permit Transfer Request.....	39
3.8.4	JEA Permit Modification Request	39
3.9	Shop Drawings	40
3.10	Real Estate.....	40
3.11	Pre-Construction Meeting	41
3.12	Construction and Inspection.....	42
3.13	As-Built Drawings.....	43
3.14	As-Built for Water COC Only	44
3.15	Permit COC	45
3.16	JEA Construction Substantial Completion Walk Through Field Meeting.....	45
3.17	JEA Final Inspection and Acceptance of the System.....	45
3.18	System Warranty	46
3.19	JEA Connection and Fees	46
3.20	Dedication of Existing Privately-Owned Systems.....	47
3.21	Public and Private Point of Service.....	47
3.22	Utility Easements	49
3.23	Revision to Dedicated Infrastructure.....	50
3.23.1	Water and Reclaimed Water Services.....	51
3.23.2	Fire Hydrants	51
3.23.3	Wastewater Services	52
3.23.4	Construction and Dedication of Redesigned Infrastructure.....	53
3.24	Revisions to Infrastructure Pre-Dedication.....	53

JEA Water, Wastewater, and Reclaimed Water Design Guidelines

3.25	Pre-Acceptance Letters	53
3.26	Pump Out Agreement.....	54
3.26.1	Pump Out Agreement Requirements	54
3.26.2	Applying for a Pump Out Agreement.....	54
Section 4.0 Potable Water and Reclaimed Water Design Guidelines		55
4.0	General	55
4.1	Design Flows.....	55
4.1.1	Average Daily Flow (ADF)	55
4.1.2	Single Family Residential	55
4.1.3	Multi-Family Residential	55
4.1.4	Commercial and Industrial.....	55
4.1.5	Flow Comparison Analysis.....	56
4.1.6	Reclaimed Water.....	56
4.2	Fire Flow	56
4.2.1	Single Family Residential	56
4.2.2	Multi-Family Residential	57
4.2.3	Manufactured Home Communities.....	57
4.2.4	Commercial.....	57
4.2.5	Institutional and Industrial	57
4.2.6	Fire Hydrant Test Data.....	57
4.3	Sizing Water and Reclaimed Water Mains	58
4.3.1	Major Transmission Mains	58
4.3.2	Distribution Mains	58
4.3.3	Velocities	59
4.3.4	“C” Factor	59
4.4	Water Main and Reclaimed Water Main Materials.....	59
4.5	Water Main and Reclaimed Water Main Bury Depths	60
4.6	Water Main and Reclaimed Water Main Locations.....	60
4.7	Water Main and Reclaimed Water Main Separation Requirements	61

JEA Water, Wastewater, and Reclaimed Water Design Guidelines

4.8	Swabbing Launching Stations.....	62
4.9	System Connections	62
4.10	Fire Hydrant Locations.....	63
4.10.1	General.....	63
4.10.2	Single-Family Residential.....	64
4.10.3	Multi-Family Residential, Commercial and Industrial	64
4.10.4	Open Rural Areas.....	65
4.11	Water and Reclaimed Water Valves	65
4.12	Flushing Hydrants and Sample Points on Water Mains.....	65
4.13	Flushing Hydrants on Reclaimed Mains	66
4.14	Air Relief Valves.....	66
4.15	Water and Reclaimed Water Services	66
4.16	Water Meters.....	67
4.16.1	General.....	67
4.16.2	Water Meter Sizing.....	68
4.16.3	Temporary Water Meters.....	69
4.16.4	Portable Fire Hydrant Meters for Construction Activities.....	69
4.16.5	Multi-Family, Commercial or Industrial Development Metering	70
4.17	Backflow Preventers	70
4.18	Water Treatment Plants.....	71
4.19	Stub-Outs and Terminal Point.....	71
Section 5.0 Wastewater Design Guidelines.....		72
5.0	General	72
5.1	Design Flows.....	72
5.1.1	Average Daily Flow (ADF)	72
5.1.2	Equivalent Dwelling Units.....	72
5.1.3	Peak Flow.....	72
5.2	Gravity Wastewater Mains.....	73
5.2.1	Sizing Gravity Wastewater Mains	73

JEA Water, Wastewater, and Reclaimed Water Design Guidelines

5.2.2	Gravity Wastewater Slope Requirements	74
5.2.3	Gravity Wastewater Main Materials	75
5.2.4	Gravity Wastewater Main Depth	75
5.2.5	Gravity Wastewater Main Location.....	75
5.3	Wastewater Main Separation Requirements	76
5.4	Gravity Services	777
5.4.1	Single Family Residential Services	788
5.4.2	Multi-Family Residential, Commercial and Industrial Services.....	788
5.4.3	Wastewater Service Locates	788
5.5	Wastewater Meters.....	79
5.6	Wastewater Manholes	79
5.6.1	Invert and Rim Elevations	800
5.6.2	Drop Connections	800
5.6.3	Lining.....	800
5.7	Force Mains.....	800
5.7.1	Pipe Diameter.....	800
5.7.2	Depth of Bury	811
5.7.3	Material and Fittings.....	811
5.7.4	Location	822
5.7.5	Swabbing Launching Stations.....	823
5.7.6	Force Main Separation Requirements.....	834
5.7.7	Valves	845
5.7.8	Force Main Connections to Existing Force Mains	856
5.7.8.1	Taps	856
5.7.8.2	To Existing Force Mains >12-inch diameter.....	856
5.8	Access Road	856
Section 6.0 Pump Station Design Guidelines.....		867
6.0	JEA Dedicated Pump Stations.....	867
6.0.1	General.....	867

JEA Water, Wastewater, and Reclaimed Water Design Guidelines

6.0.2	Site Plan	867
6.0.3	Junction Manhole.....	878
6.0.4	Class One and Class Two Lift Stations.....	878
6.0.5	Wet Well-Class Three Lift Station	8889
6.0.6	Pumps.....	901
6.0.7	Electrical Control Panel.....	912
6.0.8	Emergency Operations.....	922
6.0.8.1	Class One Pump Stations	922
6.0.8.2	Class Two, Three and Four Pump Stations.....	922
6.0.9	Water Service.....	933
6.1	Private Pump Stations	933
6.2	Low-Pressure Systems (LPS).....	944
6.2.1	Low Pressure Design Requirements	955

Section 1.0

General Information

1.1 General

The JEA Development Team consists of the JEA Director, Manager, Engineers, Technicians, and Coordination staff.

JEA team members are trained to assist in the project management, coordination with planning, system availability, hydraulic analysis, design review, construction inspection, as-built review, and acceptance processes of developer installed utility systems.

This section provides a summary of the processes included in the initial stages of project development and the JEA personnel involved in coordination of new developer installed utility system projects.

Typical development infrastructure investment centers around developers being solely responsible for the survey, engineering design, permitting, and construction for both on-site and off-site water/wastewater/reclaim utility infrastructure to meet the needs of their specific development.

All submittals will be made through our on-line portal: www.sagesgov.com

Training videos have been created to help you navigate through this program and are available at www.jea.com/sagesgov

Accessing [www.jea.com/water and wastewater development/](http://www.jea.com/water_and_wastewater_development/) will provide you links to the following:

- Frequently Asked Questions
- Forms and Procedures
- Reference Materials
- Stages of a Project

If you have any questions or need help with anything related to Water/Sewer/Reclaim Development please email jeadevelopment@jea.com.

1.1.1 Definitions

For the purposes of these Design Guidelines, the following definitions are provided to further clarify JEA's application of these guidelines.

1. Developer

Any person or entity who improves a parcel of land which may include the extension of the offsite utilities system from the existing point of connection to the proposed improvements for the purpose of providing service to said development.

2. Development

Any parcel of land upon which improvements are being made that require utility infrastructure to serve said improvements as defined by the City of Jacksonville, St Johns County, Nassau County or Clay County planning departments or any other appropriate local or federal entity having jurisdiction over said parcel of land.

3. Infill

A specific residential development category where immediately prior to development or redevelopment of land, property was vacant or, existing property divided to its prior platted development.

4. Lot of Record

A lot that is part of a subdivision recorded on or before September 21, 1990, in the Office of the Circuit Court of Duval County or a lot or parcel described by metes and bounds, which was lawfully created and the description for which was recorded on or before September 21, 1990. In the City Ordinance 656.704, the City of Jacksonville may not subject properties identified as "lot of record" to minimum lot size requirements.

5. New Development

Open land that is subdivided and platted into individual parcels upon which improvements are being made that requires utility infrastructure to serve said improvements.

6. Infill Development

Any property meeting the definition for infill that will involve demolition of an existing home and reconstruction of new home or new construction on a vacant lot where water, sewer, and reclaim infrastructure has been constructed for greater than 10 years.

7. Electronic Signatures

The requirement of electronic signatures is only applicable for the PE and the PS signature.

1.2 Getting Started

1.2.1 Service Availability Request

Prior to submitting for a building permit with local county agencies, a Service Availability Request shall be submitted to JEA. This request can be submitted to JEA at www.sagesgov.com within Step 1. Service availability requests are reviewed by JEA's Water and Wastewater System Planning Team to determine the nearest points of connection. Requests are normally completed within 10-business days. Responses from JEA are in the form of an availability letter. The availability letter will be emailed to the email address provided in the application. The availability has an expiration of two years from the date written and contains a tracking number known as the availability number. This number will be the reference number used throughout the project's lifecycle. If you need to submit any back-up documentation supporting your request (layouts, easement documents, etc.) please upload them during the Service Availability Request Application.

To submit an availability request:

- Log into www.sagesgov.com;
- Select Step 1;
- Select "Service Availability Request".

1.2.1.1 Common Questions/Issues when submitting Availability Requests

- Address doesn't appear in the database:
 - An address is not mandatory to request the letter, the RE# is. If your address is so new that it doesn't appear in the applicable County Property Appraiser's page, then skip it and proceed to the parcel number.
- Specified parcel number was not found in the applicable county GIS system:
 - Check the format of the parcel number you entered. There are example parcel numbers listed for each county at the top of the page to show you the format you must enter the parcel number in so that it registers on that applicable county page. If your format is not correct you will get this error.
 - The most common error is on Duval County and St. Johns County entries-make sure you put the space between the 6th and 7th digit in the RE#.
- Fill out the flow section of the application. Please see section 4.1 of this manual for additional information regarding design flows.

1.2.2 Verification of JEA Points of Service

In its evaluation of availability requests, JEA will rely upon JEA utility system records for the accuracy of existing JEA utilities. It shall be the sole and exclusive responsibility of the applicant and/or its affiliated parties to determine the suitability and accuracy of the record information and locate through field verification (including but not limited to sub-surface utility investigations, open excavation, etc.) during the design process. Should field verification of existing utilities not match the availability response, the applicant shall notify JEA immediately so a new point of connection can be identified.

1.2.3 Update Existing Availability Letter Request

To request an update to an existing, non-expired availability letter:

- Log into Sagesgov.com;
- Select Step 1;
- Select “Update Existing Availability Letter Request;
- Enter your Availability Number;
- Make the additions/changes and submit.

Updated Availability Letters can only be requested by the original requestor or the Engineer of Record, if they are listed as a collaborator on the project.

Expired letters will not be updated and you will need to request a new letter.

Exception: Project that already has plans submitted.

1.2.4 Project Phasing

For projects that will be constructed in more than one phase, JEA shall be provided with a phased master plan, which shall be submitted as its own separate availability request. JEA will require projects be broken into logical phases, each with their own availability number. Each phase will be a separate project and will require a separate plan review and permit. These separate projects will be linked within the Sages program.

If any of the following conditions apply, then the project will be required to be submitted in phases:

- a. If parcels are non-contiguous. Each non-contiguous parcel shall be a separate phase;
- b. If construction completion or JEA acceptance will occur at different times. Each parcel with schedules for construction completion and acceptance differing by more than 4-months will be separate phases;
- c. Construction will not be completed on the entire phase within 5-years from JEA plan approval. Parcels will be broken into smaller sizes so that construction can be completed within 5-years of plan approval;

1.2.5 Water, Wastewater and Reclaimed Water As-Built Drawing Request

For best available information on existing water, wastewater and reclaimed water mains or locations of water, wastewater, and reclaimed taps, an As-Built drawing request may be obtained from JEA's Record Department. Generally, requests for water, wastewater, and reclaimed water tap locations are completed within 2-business days and all other requests are completed within 5-business days. Results will be emailed to the customer provided email address.

To request an As-Built/GIS Map:

- Log into Sagesgov.com;
- Select Step 1;
- Select "As-Built/GIS Map Request";
- Enter your Availability Number, if you have it.

1.2.6 Special Service Considerations

1.2.6.1 Alternative Connection Review Team (ACRT)

For low pressure sewer designs for 2 or more properties, as well as any water or wastewater requests which are not in accordance with the JEA Water, Wastewater and Reclaimed Design Guidelines and/or Water and Wastewater Standards Manual and/or JEA Rules and Regulations for Water, Sewer and Reclaimed Water Services, the applicant may request a Development meeting with the JEA Development Team to discuss conceptual solutions which may be forwarded to a JEA review team for consideration.

The review team consists of representatives of design, operation, and maintenance. A representative from the JEA development team will present the request for consideration. The applicant may be asked to provide information and/or exhibits to support this presentation. The applicant does not meet with the review team.

The review team will meet monthly, as needed. After a decision has been made on any request, the applicant will be notified within 5-business days.

To submit a project to the ACT:

- Log into www.sagesgov.com;
- Select Step 2;
- Enter your availability number;
- Select "Alternative Connection Request".

You will be emailed the result of the request and any applicable next steps will be provided.

1.2.6.2 Sewer Locate

To determine the location of your sewer service, or to ascertain the condition and/or suitability of your sewer service you can request a sewer locate. When you apply and pay for this service, JEA forces will deploy a camera into the sewer main and will report back on the location and condition. They will also mark the locate of the service in the field on the pavement or curb. If the sewer lateral is located beneath a proposed driveway, a sewer locate is mandatory in order to determine if the sewer lateral may be utilized.

To request an As-Built/GIS Map:

- Log into www.sagesgov.com
- Select Step 1;
- Select “Sewer Locate Application”;
- Enter your Availability Number;
- Results will be emailed to you.

1.2.6.3 Reclaimed Water Service Area

Reuse Service Area is the geographic area within JEA’s Utility Service Area where the reclaimed water system exists or shall be expanded, to provide reclaimed water service. Where the distance from the reclaimed water distribution system and the property line is within the guidelines of the JEA Rules & Regulations for Water, Sewer and Reclaimed Water Services, Appendix A, Section A-3.02, Table 1, the owner shall connect or cause to be connected the new development to the reclaimed system. Where the distance from the reclaimed water distribution system and the property line is more than the distances in Table 1, the owner shall include reclaimed water distribution mains within their development for future connection to the system by JEA, and install a potable water jumper connection to the reclaimed water system until reclaimed water becomes available.

1.2.6.4 Septic Tank Phase Out Areas

For project locations, timelines and updates please see the following page:

https://www.jea.com/In_Our_Community/Construction_Projects/Septic_Tank_Phase_Out/

1.2.6.5 Forms for Signature

The following forms can be submitted to JEA via SagesGov for any required signatures:

- DACS (Department of Agriculture and Consumer Services)
- DBPR (Department of Business and Professional Regulation)
- FDOT (Florida Department of Transportation)
- FHFC (Florida Housing Finance Corporation)

To submit any of these forms:

- Log into www.sagesgov.com;
- Select Step 2;
- Enter your availability number;
- Select “Forms for Signature”;
- Fill out the application;
- Upload the forms in the document upload section of the application;
- Submit.

JEA will sign the document(s) you provide and you will receive an email when this task is complete.

1.3 Development Meeting

It is strongly recommended that the applicant schedule a development meeting with the JEA Development Team to discuss conceptual water and Wastewater requirements for any project other than simple tap projects.

Development Meetings will be required for the following projects/situations:

- Residential projects of 145 or more lots
- Phased projects
- HDD or Jack & Bore installations
- Including meters 3-inches or larger
- Project included in an existing Developer Agreement
- You will be requesting any of the following:
 - Cost Participation
 - Developer Agreement
 - Cost Recovery

To request a Development Meeting:

- Log in to your SagesGov account
- Select Step 2
- Enter your project Availability Number
- Select “Development Meeting Request”

- Fill out the application
- Attach your utility layout
- Submit Application

JEA will schedule the meeting and send you an invitation with meeting details.

1.4 Modifications to Existing JEA Systems

Unless approved by JEA's Development Manager, once a project has been accepted by JEA, no further revisions are allowed and the applicant must resubmit for a new availability number to make changes. [Revision to Dedicated Infrastructure.](#)

1.5 Master Plan Requirements

A Master Development Plan shall be required for all development projects being constructed in multiple phases, or for single phase residential projects with more than one pump station. The purpose of the Master Plan is to show how all phases of the development, outparcel tracts and any future development tracts will be served water, wastewater and reclaimed water and to provide sufficient data such that the proposed main sizing and pump stations will be adequate. In general, the Master Plan(s) shall conform to the following:

1. Submittal requirements: Original master plans and subsequent revisions shall be submitted under one availability number for the overall project. An availability request should be submitted for the overall project named as follows: Project Name – Master Plans (Example: Nocatee – Master Plan). Once the availability letter has been issued, the Master Plan should be submitted for review under "Master Plan Review" under Sages Step 2. Changes to the Master Plan will be handled as new Master Plan Review submittals under the same availability number.
2. The Master Plan must be approved prior to the approval of construction plans. For large subdivisions, the Master Plan may require approval before the POC, point of connection, can be issued during the processing of the project availability request.
3. The construction plans must be consistent with the approved Master Plan.
4. Each set of construction plans within the Master Plan MUST include the Master Plan within the submittal for review and clarity for the project.
5. For any changes to the development, the Developer must submit a revised and updated Master Plan. All revised Master Plans must be submitted with a letter specifying the proposed revisions to the Master Plan and must indicate on the Master Plan drawings the location of the revisions.
6. The requirement for submittal of a revised Master Plan may be waived by the JEA Development Team if they consider the changes to be minor or not significant.

7. Master Plan approval does not imply acceptance of easements, construction methods, or other items that may be in conflict with Design Guidelines.
8. The Master Plan will consist of a layout of the major water, wastewater, and/or reclaimed water lines. The layout plan sheet(s) shall be at a minimum scale of 1 inch = 200 feet and show existing and proposed improvements in sufficient detail to show intent of design. In the event that the number of plan sheets exceeds two (2) sheets at the 1 inch = 200 feet scale, the Master Plans shall be submitted at a scale of 1 inch = 500 feet. Attempts should be made to show the entire project on one plan sheet.
9. The Master Plan shall be signed and sealed by a Professional Engineer licensed in the State of Florida. Separate master plans to be provided per utility (water, wastewater, reclaimed). The requirements for each specific utility plan include:
10. General
 - a. Project boundary-shall match the project boundary approved by the local Planning and Zoning Department;
 - b. Developments immediately adjacent to the undeveloped tracts shall include a conceptual plan for extension of potable water, wastewater, and/or reclaimed water service to said tracts;
 - c. Vicinity map showing the location of the project and the scale used;
 - d. All plan elevations shall use the 1988 NAVD Vertical Datum;
 - e. Identification and scheduling of all phases.
11. Wastewater
 - a. Pipe diameters (both force mains and gravity lines);
 - b. Total wastewater flow (both average daily flow and peak) to each pump station. A summary of each unit, tract, or phase, including the contribution to each pump station stating: Type of use (single family residential, master-metered residential, commercial, etc.), and average daily flow (gpd)
 - c. If peak hour flow is greater than 300 GPM, gravity sizing calculations are required;
 - d. Pump Station locations;
 - e. Clear delineation of existing versus future units or tracts;
 - f. Wastewater model for networks with multiple pump stations;
 - g. Wastewater master plan should minimize the connections to existing JEA infrastructure by utilizing master pump stations and limiting manifolded systems.
12. Potable Water
 - a. Calculations for maximum potable water demand based on full or projected ultimate development or use gross acreage and land use. Required fire flows to be noted;

- b. Submit the Master Plan with a pipe network analysis for flow and pressure distribution for approval. The Master Plan shall include connection points and pipe sizes. All available information on hydrant locations and lot platting should be included;
- c. Total potable water flow for each unit, tract, or phase stating: Type of use (single family residential, master-metered residential, commercial, etc.), and average daily flow (gpd);
- d. Clear delineation of existing versus future units or tracts.

13. Reclaimed Water

- a. Calculations for reclaimed water demand;
- b. Request a system response curve representing JEA's reclaimed water distribution network hydraulic response to the requested water demand see [Connection Pressure Letters](#);
- c. Use the system response curve to design a reclaimed water distribution network. Then, submit the Master Plan with a pipe network analysis for flow and pressure distribution for approval. The Master Plan shall include connection points and pipe sizes. All available information lot platting should be included;
- d. Total reclaimed water flow for each unit, tract, or phase stating: Type of use (single family residential, master-metered residential, commercial, etc.), and average daily flow (gpd);
- e. Clear delineation of existing versus future units or tracts.

To submit a Master Plan:

- Submit during Availability Request;
- Submit during Availability Update Request.

1.6 Connection Pressure Letters

1.6.1 Force Main Connection Pressure Letter

To request a connection pressure letter for a JEA force main:

- Log into www.sagesgov.com;
 - Select Step 2;
 - Enter your availability number;
 - Select "Force Main Connection Pressure Letter Request";
 - Fill out application and submit.

Your letter will be emailed to you.

1.6.2 Reuse Supply Pressure Letter

To request a connection pressure letter for a JEA reclaimed water main:

- Log into www.sagesgov.com;
- Select Step 2;
- Enter your availability number;
- Select “Reuse Supply Pressure Letter Request”
- Fill out application and submit

Your letter will be emailed to you.

1.7 Project Acceptance Requirements

Once plans and permits (if applicable) are approved, a pre-construction meeting may be requested, during which an inspector will be assigned to your project. After completion of all acceptance requirements, including as-built drawings approval, permit COC and the project acceptance package has been received, JEA will set up a final walk-through. Once all punch-list items have been addressed, JEA will accept the project. In order to have meters set, a commercial/residential service application must be submitted in Sages Step 2 and once payment has been made the meter(s) will be scheduled for installation.

All utilities that will be constructed and dedicated to JEA, within the ROW and/or JEA easements, will be required to be completed by a Florida licensed underground contractor.

Project acceptance package documents can be found here: https://www.jea.com/engineering_and_construction/water_and_wastewater_development/forms_and_procedures/

1.8 Submittal Expiration

Disapproved submittals will be abandoned when they have been left inactive for 9 months. After we abandon your submittal you will need to begin the process again following the standards that are in place at the time of the new submittal.

Section 2.0

Infill Development

2.1 Availability Letter Request

To add a new water and/or sewer service to a lot a letter of availability first must be requested, see [Section 1.2.1 Service Availability Request](#). The availability letter will provide the nearest water and sewer point of connection. If the point of connection is not abutting the property in question, a line extension will be required. Line extension

projects are designed under and constructed under the direction of the customer and dedicated to JEA when construction is complete.

To submit an availability request:

- Log into www.sagesgov.com;
- Select Step 1;
- Select “Service Availability Request”.

2.1.1 Common Questions/Issues when submitting Availability Requests

- Address doesn’t appear in the database:
 - An address is not mandatory to request the letter, the RE# is. If your address is so new that it doesn’t appear in the applicable County Property Appraiser’s page, then skip it and proceed to the parcel number.
- Specified parcel number was not found in the applicable county GIS system:
 - Check the format of the parcel number you entered. There are example parcel numbers listed for each county at the top of the page to show you the format you must enter the parcel number in so that it registers on that applicable county page. If your format is not correct you will get this error.
 - The most common error is on Duval County and St. Johns County entries-make sure you put the space between the 6th and 7th digit in the RE#.
- Fill out the flow section of the application.

Use of existing services

- If there is a record of a service at your address and it has been active within the last 10 years we will provide that as your POC;
- If there is a record of a service at your address and it has not been active within the last 10 years we will provide the applicable main (water and/or sewer) as your POC;
 - If you plan to use an existing service that has been inactive for greater than 10 years, you MUST order the applicable locate to check the integrity of the existing service to see if it is usable;
- If there is no record of service at your address you will be provided the closest water main with sufficient capacity as your POC.
- Any existing sewer lateral MUST have a completed sewer locate if the lateral will be beneath a proposed driveway.

2.1.2 Connections to 2-inch water main

- We will check our billing records and as-built plans to see if there was ever water service at your address;
 - If there was water service you will be provided the water service (if service was active within last 10 years) or the water main as the POC as outlined above;
 - If there is no address provided on your availability (0 address lot) we can't check the billing records for that lot. If the lot had a previous address please provide that in the notes of your application;
 - If there is no record of water service at your address:
 - We will look at how many users are connected to the main:
 - If it is less than 5 existing customers on a dead-end main or less than 10 existing customers on a looped main we will provide the 2-inch main as the POC;
 - If it is more than 5 existing customers on a dead-end main or more than 10 existing customers on a looped main we will provide the nearest water main that can accommodate the additional flow you are requesting and your letter will reflect that a line extension will be needed.

2.1.3 Sewer POC on non-standard main sizes

- Existing 6-inch sewer mains will not be provided as the POC for individual sewer services;
- Existing 16-inch and larger sewer mains will not be provided as the POC for individual sewer services.

2.2 Locates

Prior to splitting lots, if applicable, please request water and/or sewer locates.

2.2.1 Sewer Locates

- Request through Sages, Step 1;
- Submit request for the original project address (prior to splitting);
- One address per application;
- Results will be marked on the pavement and noted in the process in Sages; Customer will also receive an email generated by Sages program when the results are ready;
- Customer shall have their surveyor depict the results on the survey so it is included on the infill layout for review.

To submit a sewer locate request:

- Log into www.sagesgov.com;
- Select Step 1;
- Select “Sewer Locate Application”.

2.2.2 Water Locates

- If there is record of a previous service for the parcel/address, we will approve this request and pass it on for payment;
 - If there is no record of prior service at this address we will disapprove the locate request;
- Submit request for the original project address (prior to splitting);
- One address per application;
- Results will be marked on the pavement and noted in the process in Sages; Customer will also receive an email generated by Sages program when the results are ready;
- Customer shall have their surveyor depict the results on the survey so it is included on the infill layout for review.

To submit a water locate request:

- Log into www.sagesgov.com;
- Select Step 2;
- Enter your availability number;
- Select “Water Service Locate and Flow Test”.

Water locates expire in 9 months after the locate is completed.

2.3 Infill Layout

Required for Sewer Services and all lot splits on new construction homes.

As applicable, infill layouts will need to include the following information:

- a. Street Name;
- b. Addresses of proposed and adjacent lots;
- c. Right-of-way lines;
- d. Existing Utilities (water, sewer, storm, etc.);
- e. Existing sewer and storm manholes with TMH and Invert elevations;
- f. Finished floor elevation (Based upon Vertical Datum NAVD 1988);
- g. Building footprints;
- h. Driveway locations;
- i. Existing water meters (if any).

To submit infill layouts:

- Log into www.sagesgov.com;
- Select Step 2;
- Enter your availability number;
- Select “Infill Layout Submission”.

2.4 Special Estimate Determination

All requests for JEA to install new service taps will need to be proceeded by a special estimate determination.

Special Estimate determinations are valid for 60 days. If application and payment is not made within 60 days of the determination issuance an update will be required.

If your project requires an infill layout to be submitted it will have to be approved prior to you submitting for a special estimate.

If you have a commercial project you will have to have approved plans prior to submitting for a special estimate.

In the event that a project requires a permit for the installation of the work you want JEA to perform, you will need to have approved plans and permits before JEA can provide the cost for the work. In addition, if the work will require an easement that will also have to be reviewed and recorded prior to the special estimate being issued.

JEA has the right to refuse to install complex services, in which case the construction of the connection will be accomplished by the developer and the project must complete the design review and dedication process.

For a cost to install new water, sewer and/or irrigation services please submit a Special Estimate Request by:

- Log into www.sagesgov.com;
- Select Step 2;
- Enter your availability number;
- Select “Special Estimate Determination”.

Not all Special Estimate requests will result in a special estimate for standard tap fees. Field factors that would designate the need for a special estimate are as follows:

- Main Depth 8+ feet deep
- Required work within FDOT, St. Johns County, Nassau County
- Pavement less than 5 years old
- Multiple services being installed
- Taps on water mains 20-inch and larger
- Water taps larger than 2-inches
- Sewer taps greater than 6-inches
- Low Pressure Sewer Service Connections
- Installation of Sewer Vac Pods
- Approved commercial development plans
- Force main taps-only if approved by O&M

2.5 New Service Application

2.5.1 Existing Service to be used

To apply for new service please submit an Application by:

- Log into www.sagesgov.com;
- Select Step 2;
- Enter your availability number;
- Select “Residential New Service Application”;
- Indicate that you are using existing services where applicable.

2.5.2 JEA to Install New Service

Before you submit this application be sure that you have been issued a Special Estimate Determination and it has not yet expired.

After payment has been made, most taps will be installed within 15 business days.

To apply for new service please submit an Application by:

- Log into www.sagesgov.com;
- Select Step 2;
- Enter your availability number;
- Select “Residential New Service Application”;
- Indicate that you are using existing services where applicable.

2.6 Builder Installed Services

For infill water and sewer taps only, a builder may install water and/or gravity sewer services on existing infrastructure without engineered plans under the following conditions:

1. Availability Letter from JEA identifies a point of connection that is abutting the property (no main line extension required);
2. Infill layout has been approved by JEA Development;
3. Put in a request in Sages for a Pre-Con Meeting (Sages Step 4)
 - a. Inspector will be assigned (inspector must be onsite for the tap and the running of the service line-if not the service will need to be uncovered from the tap to the termination point for their inspection.
 - b. Record Drawing and Acceptance Package will be reviewed.
4. Water and sewer services must be installed by a Florida licensed underground utility contractor;
5. Utility work must adhere to the latest JEA Design Guidelines and Water and Wastewater Standards;
6. A JEA inspector must be onsite, observe, and approve the installation of water and/or sewer services;
 - a. Builder submits Record drawings (use As-Built submittal option in Sages Step 4) to JEA within 5-Business days of work completion, including the location and depth of water and/or sewer service at tap and termination point;
7. Submit Project Acceptance package within 5-Business days of approval of Record drawings;

8. Submit Residential Service Application in Sages Step 2
9. Make Payment of all associated fees (meter set, capacity fees, growth fees).

Section 3.0

Design Guidelines

3.0 General

This section applies to all new residential, commercial, and industrial developments, as well as roadway construction requiring or requesting a new or modified water, reclaimed water, and/or sanitary wastewater service or main construction. For these new developments, a JEA Plan Review is required. To initiate a JEA Plan Review, the developer must first obtain a JEA Water and Wastewater Availability, which defines the JEA point of service. The availability number is utilized for tracking the project from start to finish. The applicant submits proposed construction plans, permits, and other applicable data to JEA's Plan Review Department for JEA water and wastewater utility review. The Plan Review process typically involves two submittals (a preliminary and final plan review) as described below.

JEA, in coordination with the Developer's Engineer, reserves the right to specify the point of service, the size of service, the type of service, and the general layout of the overall system within the guidelines established in this manual.

Water, reclaimed water, and wastewater distribution and collection systems shall be designed and constructed according to the most current editions of the following publications:

- JEA Water, Wastewater & Reclaimed Water Design Guidelines
- JEA Rules & Regulations for Water, Sewer and Reclaimed Water Services
- JEA Water and Wastewater Standards Manual
- The Recommended Standards for Sewage Works (Ten State Standards)
- FDEP and other applicable federal, state and local requirements
- JEA Self-Permitting

For utility work outside of Duval County, the location of water valves, meter boxes and the type and location of fire hydrants shall comply with the local (County) design and construction utility standards.

The engineer shall coordinate the location of water, reclaimed water and wastewater facilities with other utilities (electric, gas, telecommunication, drainage and cable) to minimize conflicts. Facilities shall be designed such that conflicts with driveways and sidewalks are minimized. In the event of conflict with a future driveway or sidewalk, the Developer and/or Builder shall be responsible to resolve the conflict at its expense.

For private water distribution systems involving two or more units that are connected to the JEA water distribution system (such as a master meter arrangement), the applicant, shall ensure that the above rules and standards are complied with during the design and construction phase of the project. Although a JEA Plan Review and/or a regulatory permit may not be required, it is the responsibility of the applicant to maintain the public drinking water standards by complying with the above applicable rules and standards including, but not limited to utility separation requirements, pressure and leakage testing and private bacteriological clearance testing. It should also be noted, in some cases, the private water distribution system might require a plumbing permit from the City or County having jurisdiction.

3.1 Order of Precedence

JEA will use the following order of precedence in resolving any conflict, error, or discrepancy for all installed systems:

1. Approved regulatory permits (JEA, FDEP)
2. Approved County/FDOT agency permit requirements
3. JEA Water and Wastewater Standards Manual
4. JEA Rules & Regulations for Water, Sewer and Reclaimed Water Services
5. JEA Water, Wastewater and Reclaimed Water Design Guidelines
6. Approved final design plans

3.2 JEA Plan Approval Effective Dates

JEA approved plans will be effective for 2-years from the date of JEA Plan Approval. For projects that include a JEA environmental construction permit, Plan Approval will be effective for the same dates as the permit. The date of JEA Plan Review Approval will be provided on the cover sheet of the approved construction plans. After the 2-year period has expired, JEA may grant up to one, 2-year time extension and subsequently, one, one-year time extension for a maximum of a 5-year construction time period. At each request for extension, a copy of the existing approved JEA plans, identifying any construction that has occurred, will be submitted for approval. Any construction not completed and accepted by JEA will adhere to the JEA standards in effect at the time the extension and plans are approved.

3.3 JEA Review Time Frames

Submittal intake process will be performed daily, with a response time of 1 business day. Intake cut-off time will be at 2 p.m. daily. Any submittals made after 2 p.m. will be considered as submitted the next business day.

3.3.1 Preliminary Plan Submittal Review Time

Preliminary plan reviews will typically be completed within 15-business days.

3.3.2 Subsequent Plan Submittal Review Time

Final plan reviews will typically be completed within 10-business days.

3.3.3 Revision Plan Submittal Review Time

Revision plan reviews will typically be completed within 5-business days.

3.3.4 Preliminary As-Built Plan Submittal Review Time

Preliminary As-Built plan review will typically be completed within 10-business days.

3.3.5 Subsequent As-Built Final Plan Submittal Review Time

Final As-Built plan review will typically be completed in 5-business days.

3.4 Design Review

3.4.1 General Plan Submittal Requirements for New Development

Dedicated water/sewer/reclaim plan sheets are required. Drainage infrastructure may be shown on these plan sheets, but it will need to be shaded back. As a minimum requirement, the following shall be included on the design drawings:

- a. Cover sheet with a vicinity map, JEA availability number, city development number (if applicable), and a note referring to the applicable Standards year for which the plans were designed. Example: Plans Designed under YYYY Standards;
- b. A north arrow with scale indicated;
- c. Lot numbers, street names and street address (if available - especially for in- fill areas) on all applicable sheets;
- d. A permanent benchmark or temporary benchmark (referenced to a permanent benchmark) referenced to State Plane Coordinates as well as topography depicted as 1-foot contours;
- e. The engineer's name, project name and all phases to be planned, designed, and constructed on all sheets;
- f. Developer's name and contact number;
- g. Plans must reflect the approved POC (point of connection) as specified in the Availability letter;

- h. All materials shown and clearly labeled (pipe, valves, fire hydrants, fire sprinkler lines, water meters, fittings-including all horizontal and vertical bends, manholes, services) with associated elevations, sizes, types, composition, slopes, and appurtenances;
- i. Location of existing utilities within the right-of-way including water mains, reclaimed water mains, force mains, gravity sewer mains, storm sewers, electric, gas, fiber optic, cable, and telephone. Label as existing and include the size and material;
- j. All construction plans require the EOR to have Level “A” SUE work (locate) performed for all points of connection. Level “A” SUE shall comply with the definition by [ASCE 38-02](#) and adopted by FDOT. Level “A” SUE report shall be included for all POC connections proposed in project, or included in the plans.
- k. Elevations (manhole tops and inverts) of all existing wastewater facilities within the right-of-way and easements;
- l. Pipe Crossing Information shall be provided in either a table or callouts per sheet. Include the FG elevation, bottom elevation of the top pipe and the top elevation of the bottom pipe at the crossing. If you find it necessary to deflect pipe to meet minimum clearances you must show and call out the required fittings;
- m. A site plan indicating any required grease, oil, sand, or lint separators and/or other required pretreatment systems such as dumpster pad run off;
- n. A master paving and drainage plan showing all storm water facilities, retention or detention ponds with elevations, the design high water and 100-year flood elevations and site contours shown at 2-foot maximum intervals;
- o. All drainage design plan sheets with profiles depicting proposed water, reclaimed water and wastewater systems;
- p. Utility Master Site Plan drawn with proposed phases clearly indicated. Updates provided as revisions are made;
- q. Match-lines, when applicable, shall be indicated on all plan sheets. Do not cut sheets through intersections. Label all match-lines with corresponding sheets and provide a 10-foot overlap;
- r. When available, preliminary plat shall be submitted on all platted projects in order for JEA to provide electric, water, or wastewater services to the development;
- s. Design plan shall include station numbers along proposed roadways for all projects;
- t. Offsite utilities shall include station numbers along the alignment of the pipe;

- u. Plan and Profile Sheet Scale: Please be sure that the scale is consistent from sheet to sheet and that the scale is such that the plans are legible. For commercial or residential subdivisions, plan only sheets drawn at a maximum horizontal scale of 1-inch = 40-feet. For commercial and residential subdivisions, plan and profile sheets drawn at a maximum horizontal scale of 1-inch = 40-feet and a maximum vertical scale of 1-inch = 5-feet;
- v. Roadway cross sections with all proposed and existing utilities depicted, road crossing details for open cuts, profiles for jack and bores and directional drills;
- w. Plan and profile sheets shall include all wastewater design information including pipe size, length, material, slope, manhole top and invert elevations, existing and proposed grades, the location of new gravity sewer mains and force mains, all crossings (storm water and water mains) and all additional pertinent information such as trench details, manhole details, joint details, and material specifications. Profiles are required for all force mains, and all other pressure pipe greater than 12-inch diameter;
- x. Landscaping plans with location of proposed utilities shown;
- y. All existing and proposed utility easements and rights-of way with dimensions, locations and grantee;
- z. All proposed or existing structures within the separation requirements laid out in [Separation Requirements](#);
- aa. All existing or proposed drainage easements with dimensions, locations and grantee;
- bb. When available, building footprints (for commercial projects), minimum finished floor elevations and number of floors, decorative brick walls and paving, entrance signs, fountains, fences, and landscape buffers shown;
- cc. Ownership of the proposed utility system shall be clearly designated as “JEA” or “Private”;
- dd. Stabilized access road shown in easements crossing wetlands or limited access areas which include manholes;
- ee. The limits of joint deflection for vertical and horizontal offsets must be reflected on the drawings. It could be “start vertical joint deflection” and “stop vertical joint deflection” or a dimensional line at each end labeled “limits of deflection.” Joint deflection must conform to JEA Standards.

3.4.2 Water Plan Submittal Requirements

In addition to the general plan submittal requirements discussed above. Water design plans shall include the following:

- a. Signed and sealed hydraulic Analysis supporting pipe and meter size selection and or fire flow including fire flow test results within one year of submittal date as applicable;
- b. Signed and sealed meter calculations for meters greater than 1-inch;
- c. All backflow prevention required in accordance with the JEA cross connection control program;

- d. Location of all points of connection to the existing water distribution system;
- e. Water service and meter locations for all applicable lots;
- f. Location of all sample points;
- g. Profiles for all waterlines greater than 12-inch diameter.
- h. Need to list when BFPs are required due to well water/pond water usage for irrigation. Including reclaim irrigation – by master reclaim meter, then private lines services each lot, NOT JUST THE GREEN SPACE

3.4.3 Wastewater Plan Submittal Requirements

In addition to the general plan submittal requirements discussed above, wastewater design plans shall include the following:

- a. Signed and Sealed Pump Station Analysis ([See Pump Station Design Guidelines](#));
- b. Sewer service locations for all applicable lots;
- c. Profiles for all gravity and force mains installed;
- d. Pump station drawings shall include: cross sectional view of pump station showing pump station piping and fittings and wet well elevations, pump information including model, impeller diameter, horsepower, motor speed, operating voltage, control panel, and operating point;
- e. For JEA pump station sites, a Standard Penetration soil boring shall be performed at each wet well location and submitted prior to final plan approval. The soil boring shall be a minimum of 15-feet deeper than the wet well bottom or extend until suitable soil is located up to a maximum of 25-feet below the wet well bottom;
- f. JEA pump station standard detail sheets where the pump station is to be dedicated to JEA. Where required, the standard site layout may be modified, as necessary, provided the minimum site dimensions are maintained and all standard general notes are included;
- g. If alteration to existing infrastructure is proposed that will result in temporary bypass pumping, then areas of service interruption as well as areas of needed TCE will be identified on the plans. If additional information is needed the plan reviewer will request those details. Our Planning team will review and provide the flow so that the contractor can determine pump capacity needs. Bypass pumping plan shall be submitted as a shop drawing and be approved prior to requesting a pre-construction meeting.

3.4.4 Reclaimed Water Plan Submittal Requirements

In addition to the general plan submittal requirements discussed above, reclaimed water design plans shall include the following:

- a. Signed and sealed hydraulic Analysis supporting pipe and meter size selection;
- b. Location of all potable water wells within 500-feet;
- c. Reclaimed water service and meter locations for all applicable lots;

- d. All existing and proposed reclaimed water storage ponds including any connection to the storm water management system and/or waters of the State;
- e. All backflow prevention required in accordance with the JEA cross connection control program;
- f. A plan sheet(s) showing a reclaimed water signage plan consistent with JEA Rules and Regulations for Water, Sewer and Reclaimed Water Services;
- g. Profile of all reclaimed water lines greater than 12-inch diameter.

3.4.5 Horizontal Directional Drill/Jack & Bore Plan Submittal Requirements

Installation of water and/or sewer mains by Horizontal Directional Drill will be approved on a case-by-case basis and you must get approval prior to plan submittal.

In addition to the general plan submittal requirements discussed above, horizontal directional drill design plans shall include the following:

- a. Profile of the entire length of the drill depicting the following:
 - i. Right-of-way limits;
 - ii. Property ownership information (if applicable);
 - iii. Any required easements, permanent or construction;
 - iv. Soil boring information
 - v. Existing underground utility information, both horizontal and vertical, verified by Level "A" SUE work and report (locate) and;
 - vi. Entry and exit locations, dimensioned;
 - vii. Entry and exit angles;
 - viii. Fittings and/or adaptors.
- b. Geotechnical Report to be provided, which:
 - i. Provides recommendations and analysis to confirm the suitability of the strata for the proposed drill path.

3.4.6 Utility Construction Notes

The following notes, at a minimum, shall be included on all plan submittals. Any deviation from the standards shall be requested by the Developer's Engineer and shall be approved, in writing, by JEA:

- 1. All water, reclaimed water, and sanitary wastewater work shall be constructed in accordance with the latest JEA Water and Wastewater Standards Manual, all applicable local and state regulatory rules & regulations and other applicable JEA rules.
- 2. All water, reclaimed water, and wastewater construction shall be provided by a contractor qualified, as required under the current Florida Statute, or by an underground utility contractor, licensed under the provisions of Chapter 489 FS.

3. The applicant shall be responsible for obtaining City or County Right-Of-Way permits for work in the City R/W, County R/W or a FDOT permit for work in the FDOT R/W.
4. The applicant shall contact the JEA, and schedule a Pre-Construction Meeting, to be held prior to initiating the JEA water and wastewater utility work, including all utility main taps by the contractor.
5. JEA water and wastewater tap fees, JEA water and sewer capacity fees, and JEA meter fees shall be paid prior to the water meter installation. Water meters will not be installed prior to the issuance of required acceptance (transfer of ownership) documents, which may include the issuance of a regulatory clearance letter (COC) for the water and wastewater improvements, completion, and approval of Final Inspection and approved As-Built drawings.
6. Final connection to the JEA system may be contingent upon the construction, dedication, and final acceptance (transfer of ownership/maintenance) of the JEA off-site utilities.
7. The minimum horizontal and vertical separation requirements for the water, reclaimed water, and wastewater improvements shall conform to the latest JEA and FDEP rules. The minimum horizontal separation requirements between the proposed water and wastewater utilities and ponds or structures shall conform to the latest JEA Water and Wastewater Standards Manual.
8. Water and wastewater pipes less than 24-inches in diameter shall be constructed with a minimum 30-inches cover in unpaved or sidewalk areas and a minimum of 36-inches cover in paved areas. The maximum cover for utilities, both open cut and utilizing Horizontal Directional Drill methods, shall comply with the latest JEA Water and Wastewater Standards Manual.
9. Water and wastewater pressure mains and services shall pass a JEA pressure and leakage test at 150-psi minimum, or two times operating pressure, whichever is greater, for 2-hours. In addition, water mains shall be disinfected and pass a bacteriological analysis. All tests shall conform to JEA and FDEP rules, regulations, and AWWA C-651. The JEA Inspector shall be notified 72-hours (min) prior to performing these tests. No final connection(s) to existing potable water mains shall be made until the new main is pressure tested, disinfected, and cleared for service.
10. In the areas where solvent contamination is found in the trench, work shall be stopped and the proper regulatory authorities notified. A revised construction plan shall be approved by JEA and FDEP that complies with all regulatory rules. The revised construction plan for the JEA water main system, including water service lines, may involve galvanized or ductile iron pipe with special solvent resistant (fluorocarbon type) gaskets that extend 100-feet beyond the contaminated areas.
11. The contractor shall minimize service interruptions to existing JEA water and wastewater customers. If JEA approves a service interruption, then

the contractor will be responsible for notifying the affected customers in accordance with the latest JEA rules.

12. Residential services using reclaimed water for irrigation must have a JEA approved backflow preventer installed on each potable water service prior to the installation of a JEA reclaimed water meter. The installation of a backflow preventer shall be in accordance with the JEA Rules and Regulations for Water, Sewer, and Reclaimed Water Services, Appendix B, Cross Connection Control Policy.
13. For developments utilizing reclaimed water, a JEA approved reclaimed water signage plan shall be implemented prior to the installation of the reclaimed water meters.
14. All backflow preventers shall be in accordance with JEA cross connection program. Backflow preventers must be tested after installation by a certified tester and annually thereafter.
JEA Contact: Permitting 904-665-7988.
15. Backflow preventers on fire lines or combination fire/potable mains shall have freeze protection.

3.5 Preliminary Plan Review Package

Required Documents to be submitted:

- a. One pdf set (not individual pdf pages) of clear and legible design plans that have been electronically signed and sealed for review only by a registered Professional Engineer licensed to practice in the state of Florida;
 - a. Pdf plan set should be flattened prior to submission.
 - b. Zip files will not be accepted.
 - c. Adobe packages will not be accepted.
- b. One pdf of each, as applicable, electronically signed and sealed for review only by a registered Professional Engineer licensed to practice in the state of Florida:
 - a. Hydraulic Analysis (electronically signed and sealed);
 - b. Calculations supporting meter size selection (electronically signed and sealed) > 1-inch;
 - c. Pump station calculations, electronically signed and sealed for review only by a registered Professional Engineer licensed to practice in the state of Florida;
- c. Phasing Plan (if applicable);
- d. Soil Boring Report for new Subdivision and/or JEA Pump Station with recommendation for intended use (electronically signed and sealed) (if applicable);
- e. Soil Boring Report for proposed HDD Installations (electronically signed and sealed) (if applicable);
- f. Level A SUE report for POCs (not required at initial plan submittal but required prior to approval);
- g. Level A SUE report for HDD crossings (if applicable - (not required at initial plan submittal but required prior to approval)
- h. Copy of existing JEA easements (if applicable);
- i. JEA Agent Authorization Form – signed and notarized by owner-pdf;

- j. Copy of Division of Corporation Report listing if property owner is a business, with authorized members names (Sunbiz)-pdf;
- k. Property Appraiser's map defining property and property owner-pdf.

Applicable [JEA forms](#) can be found at www.jea.com.

To submit Preliminary Plan Review Packages:

- Log into www.sagesgov.com
- Select Step 2
- Enter your availability number
- Select "Plan Submission"

Plan review submittals that are missing required information will be rejected for correction before they are routed to a plan reviewer.

3.6 Subsequent Plan Review

Required Documents to be submitted:

- a. One pdf of clear and legible design plans that have been electronically signed and sealed by a registered Professional Engineer licensed to practice in the state of Florida;
 - a. Pdf plan set should be flattened prior to submission.
 - b. Zip files will not be accepted.
 - c. Adobe packages will not be accepted.
- b. One pdf of each, as applicable, only if comments/changes requested:
 - a. Hydraulic Analysis;
 - b. Calculations supporting meter size selection;
 - c. Pump station calculations, electronically signed and sealed by a registered Professional Engineer licensed to practice in the state of Florida;

To submit Subsequent Plan Review Packages:

- Log into www.sagesgov.com
- Select "Worklist" menu
- Select your project/case (click on blue text)
- Select "Resubmit Project/Case"
- Toggle through application, making any changes that are needed
- To replace files (ex. new plan set addressing comments)
 - Upload Files page
 - Next to existing files you will have three options: keep, revise, delete
 - Select "Revise", a grey "choose file" and a blue "upload" button will appear
 - Select grey "choose file" button and select your new file (updated plans)
 - Select blue "upload" button

- Select blue “next” button
- Select blue “submit” button

Subsequent plan review package will be directly routed to project review coordinator.

3.7 Approved Plan Revisions

Any changes to the plan following final plan approval, prior to or during construction, will require a revision submittal and may require a permit modification. Depending on the level of the changes, a meeting with JEA’s Development Team may be required. Revised hydraulic analysis may also be required.

3.7.1 Revision to Approved Plans

- a. Cloud and number the revision on each applicable sheet; PROVIDE A DESCRIPTION OF THE REVISION ON THE COVER WITH LIST OF THE PAGES EFFECTIVE.
- b. Number and describe the nature of the revision on each applicable sheet in the revision block;
- c. Reference the revision number and the date on the cover page;
- d. Provide one pdf of the revision that have been electronically signed and sealed by a registered Professional Engineer licensed to practice in the state of Florida with the cover sheet listing all revised pages along with all revisions clouded

To submit Approved Plan Revisions:

- Log into www.sagesgov.com
- Select Step 3
- Enter your availability number
- Select “Approved Plan Revision Submittal”

Plan revision submittals that are missing required information will be rejected for correction before they are routed to a plan reviewer.

3.7.2 Revision to Approved Plans with Permit

See [JEA Permit Modification Request](#) for instructions on submitting permit modifications.

If your revision requires a permit modification you must submit both within the SagesGov site at the same time, otherwise they will not be approved.

3.8 Permits

The Developer and Engineer are responsible for ensuring that all permits, permit criteria, permit fees, forms, and other permitting requirements are met for the proposed project.

The Engineer shall submit all completed permit applications with electronic signatures. The Developer's Engineer shall fill out the permit checklists and submit with all pertinent data on the [permit forms](#), found at www.jea.com.

Water and/or wastewater mains 12-inch inside diameter and smaller located in Duval County may be permitted through JEA's Self-Permitting process.

All water and wastewater mains located outside of Duval County must be permitted through the FDEP. In addition, all water and/or wastewater mains within Duval County exceeding 12-inch in diameter will require a FDEP permit. All private wastewater facilities shall be permitted through FDEP or, if applicable, the Environmental Quality Division of the City of Jacksonville.

Right of Way permits are required for work within the city, county and state rights-of-way. Contact the appropriate agency for R/W permitting requirements.

If a FDOT permit is required, the applicant (aka Permittee) is required to complete a FDOT Utility Permit Application within the FDOT One Stop Permitting database, <https://osp.fdot.gov/#/login>. Include the [Special FDOT Instructions](#) form, signed by both the permittee and JEA. Reference the JEA availability number either in the project name or in the attached documents file name. Do not submit the FDOT permit application for review until you have received approved JEA plans. Any revision change FDOT requests will need to go back to JEA for review prior to being approved and transmitted to FDOT.

3.8.1 Water & Wastewater Permit Submittal

To submit all water and/or wastewater permits:

- Log into www.sagesgov.com;
- Select Step 3;
- Enter your availability number;
- Select "Permit Determination";
- Select "Water & Wastewater Permit Submittal";
 - Be sure that the permits are electronically signed and sealed per 61G15-23.003 and 61G15-23.004;
 - If your permit needs to go to DEP or EQD for signoff you will need to upload the final signed off permit to your Sages permit process to proceed to the next step.

3.8.2 JEA Permit Extension Request

To submit a permit extension request:

- Log into www.sagesgov.com;
- Select Step 3;
- Enter your availability number;
- Select “Permit Determination”;
- Select “JEA Permit Extension Request”;
 - Request can only be made by EOR;
 - You must request this extension before your permit expires, no extensions will be granted for expired permits.

3.8.3 JEA Permit Transfer Request

To submit a permit request:

- Log into www.sagesgov.com;
- Select Step 3;
- Enter your availability number;
- Select “Permit Determination”;
- Select “JEA Permit Transfer Request”;
 - Request can only be made by EOR or owner;
 - You must request this transfer before you submit for permit COC.

3.8.4 JEA Permit Modification Request

To submit a permit extension request:

- Log into www.sagesgov.com;
- Select Step 3;
- Enter your availability number;
- Select “Permit Determination”;
- Select “Modification”;
 - Request can only be made by EOR;
 - Request needs to be submitted at the same time the Approved Plan Revisions are submitted.

3.9 Shop Drawings

Any by-pass pump plan, specialty pump station structures, pumps, panels, or materials not included in the JEA Water and Wastewater Standards Manual will require a complete set of shop drawings, in pdf format, to be submitted to JEA's Development Team for review and approval prior to ordering materials. The JEA availability number associated with the project shall be shown on the shop drawings. The Developer's Engineer shall review and approve shop drawings prior to submittal to JEA for review and approval. For additional details, refer to JEA Water, Wastewater, and Reclaimed Water Inspection Guidelines.

By-pass pumping plan shall include pump-out and discharge locations, pumping mechanism, construction sequencing, and any other stipulations as necessary.

To submit Shop Drawings:

- Log into www.sagesgov.com;
- Select Step 3;
- Enter your availability number;
- Select "Shop Drawing Submittal".

Shop Drawings must be approved prior to requesting a pre-construction meeting.

3.10 Real Estate

JEA is now accepting all real estate applications and submittals through SagesGov.

To submit Real Estate Application or Package:

- Log into www.sagesgov.com;
 - Select Step 3;
 - Enter your availability number;
 - Select the type of submittal you have;
 - Easement Approval Request;
 - Hold Harmless Agreement;
 - Plat Approval Request;
 - Temporary Construction Easement Request;
 - Deed Submittal.

3.11 Pre-Construction Meeting

Before you can request a pre-construction meeting you must meet the following pre-requisites, as applicable:

- Approved Plans
- Issued Permits
- Approved Shop Drawings
- Temporary Construction Easements in place and approved by JEA

To submit a Pre-Construction Meeting Request:

- Log into www.sagesgov.com;
- Select Step 4;
- Enter your availability number;
- Select “Pre-Construction Meeting Request”.

The following information will need to be uploaded, as applicable:

- Contractor license
- Subcontractor license
- Jack & Bore qualifications and license
- HDD Contractor qualifications and license
- HDD work plan

How to provide required uploads:

- Upload licensing information and qualifications into the program (will only have to do this one time, until license expires) **RECOMMENDED**
 - Log into www.sagesgov.com;
 - Select “Admin” menu;
 - Select “My Profile”;
 - Select “My Licenses” tab at the top;
 - Select blue “add” button;
 - Fill out the application, upload your qualifications;
 - Select blue “save” button.

JEA Water, Wastewater, and Reclaimed Water Design Guidelines

The screenshot shows the 'Add License' form in the SagesGov system. The form is divided into several sections:

- License #**: A text input field.
- Issued By**: A text input field.
- License Type**: A dropdown menu with '-- Select --' as the current selection.
- Is Issued By 3rd Party?**: Radio buttons for 'Yes' and 'No'.
- Effective Date**: A text input field.
- Expiration Date**: A text input field.
- Staff Notes**: A large text area for notes.
- Notes**: A large text area for general notes.
- Documents**: A section for uploading documents, showing 'No documents uploaded' and a 'Choose File' button. A note below states: 'Please note, you can use Google's Chrome browser with Adobe's Flash Player plug-in to upload multiple files at the same time.'

At the bottom of the form are 'Cancel' and 'Save' buttons.

- Upload all required files on Pre-Construction Meeting Process upload page
 - This is not recommended because you will have to do this EVERY time you are applying for a pre-construction meeting.

Pre-Construction meetings will be scheduled and held as either a conference call or a Webex meeting. Meeting information and details to connect will be provided in the meeting invitation email.

3.12 Construction and Inspection

With distribution of the final design drawings, the project will be turned over to the Developer's Engineer for coordination of construction. JEA will assign a representative from JEA Construction Support Services who will be responsible for JEA's inspection activities of any facilities constructed for dedication to JEA. The representative will maintain communication with all applicable parties throughout the project construction.

The utility system shall be installed by a Florida licensed underground contractor, as depicted on the approved project drawings and in accordance with the JEA Water and Wastewater Standards Manual. Any changes will need to be evaluated by JEA's Development Team for revision determination.

Any utility adjustments resulting from finish grade changes made after plan approval must be approved by JEA Construction Support Service and shall be the sole responsibility of the Developer. In no case shall maximum or minimum slopes or depth of bury be exceeded because of the field finish grade changes.

The actual field locations of utility appurtenances (i.e. fire hydrants, line valves, services, flushing hydrants) shall be approved by JEA Construction Support services prior to construction.

JEA certified “Record of Pressure and Leakage Test” and “Locate Wire Test” must be completed within 90-calendar days prior to the line being cleared for service by the regulatory agencies. If these tests are older than 90-days, the tests are considered not acceptable and must be re-done. Water bacteriological test results are acceptable for a period of 60-days from date of issuance.

For additional details, refer to JEA Water, Wastewater, and Reclaimed Water Inspection Guidelines.

All inspection requests will be made through SagesGov. You will not be able to request any inspection until you have had a pre-construction meeting.

To submit an inspection request:

- Log into www.sagesgov.com;
- Select Step 4;
- Enter your availability number;
- Select “Inspections”.

3.13 As-Built Drawings

Upon completion of the project, and prior to dedication of utilities to JEA, or final payment under a contract with JEA, the Contractor shall furnish to JEA a completed JEA As-Built Submittal Requirements Checklist (found in section 501 of the JEA [Water and Wastewater Standards Manual](#)), an electronic file containing the drawings in pdf and AutoCAD dwg format, , revised in accordance with the JEA Water and Wastewater Standards Manual Section 501. The Contractor shall deliver initial As-Built drawings within 30-days of substantial completion.

JEA shall review the documents to ensure accuracy with respect to actual construction and JEA Standards.

As-Built drawings must include recording document numbers for all utility work located within easements.

A copy of the JEA Water and Wastewater Standards Manual can be found at www.jea.com.

To submit an As-builts:

- Log into www.sagesgov.com;
 - Select Step 4;
 - Enter your availability number;
 - Select “As-Built Submittal”.

As-Built submittals that are missing required documents will be returned without review.

All construction must be completed before as-builts will be reviewed. Exceptions can be made where potable water COC’s are required to move forward with water main construction.

In the event that data is missing, the as-built drawings will be disapproved and the contractor will be provided a marked-up set showing the required changes. Upon approval, the as-built process in SagesGov will be marked as “approved” and you can proceed to the next step, clearing your permits.

DO NOT include your permit COC applications with your as-built submittal. See [Permit COC](#) for instructions on closing out your permit(s).

3.14 As-Built for Water COC Only

In the event that you need only your Water COC issued:

- Clear a water main so you can get a fire hydrant on-site to proceed to vertical construction;
- Clear water main so that you can fill a downstream main for pressure testing (only applicable when the downstream main will require a large volume of water);
- Clear water main so that a loop can be completed (transferring existing services to new main so you can abandon the old main).

If you have any of these situations, you can apply for As-Built for Water COC only.

Please note, if you select this option you will need to resubmit the water as-builts again with the rest of your as-built package when your project is complete.

To submit an As-Built for Water COC Only:

- Log into www.sagesgov.com;
- Select Step 4;
- Enter your availability number;
- Select “As-Built for Water COC Only”;

After this has been approved you will still need to submit your Water Permit COC, see next section for instructions.

3.15 Permit COC

Upon as-built approval you can submit your permit COC application(s).

To submit a Permit COC:

- Log into www.sagesgov.com;
- Select Step 4;
- Enter your availability number;
- Select “Permit COC”;
 - Be sure that the permit COC applications are electronically signed and sealed per 61G15-23.003 and 61G15-23.004;
 - If your permit COC application needs to go to DEP or EQD for signoff you will need to upload the final signed off permit COC to your Sages Permit COC process to proceed to the next step.

3.16 JEA Construction Substantial Completion Walk Through Field Meeting

Upon substantial completion of the project, JEA will perform a walk through with JEA’s Operations and Maintenance personnel, the developer’s engineer and the contractor. The purpose of the walk through is to generate a punch list of items that need to be addressed to meet JEA standards, to field verify As-Built drawings submitted, test run pumping equipment for proper operation and to operate all valves.

3.17 JEA Final Inspection and Acceptance of the System

Upon as-built approval, the engineer will need to clear their project permits. Links to the applicable [permit COC forms](#) can be found at www.jea.com. Upon receipt of all permit COC’s, the engineer will submit the project acceptance package within SagesGov.

To submit a Project Acceptance Package:

- Log into www.sagesgov.com;
- Select Step 5;
- Enter your availability number;
- Select “Acceptance Package Submittal”;

A list of required documents can be found at www.jea.com.

Once the package has been reviewed and verified to be complete, all parties will be notified to conduct a final inspection. Upon completion of a final inspection and all punch-list items, the project will be accepted by JEA.

The transfer of ownership and maintenance of the constructed infrastructure per approved plans is required prior to rendering of service.

Unless approved otherwise by JEA, the applicant must submit and obtain JEA's approval of all project acceptance documents within 90-days after the date of FDEP "Certification of Construction Completion" for the associated water, wastewater, and/or reclaim utilities. Otherwise, JEA reserves the right to require the developer to up-grade the utilities to current JEA rules and/or construction standards. The system cannot be placed into service without the FDEP "Certification of Construction Completion."

3.18 System Warranty

All portions of the installed utility system shall be unconditionally guaranteed, in accordance with the JEA Water and Wastewater Standards Manual, against material defects or improper workmanship. The Developer shall repair and/or replace defective material and/or installations to JEA standards, at no cost to JEA. In the event of failure by the Developer to provide complete replacement, delivery to the site of materials and installation of same to replace defective materials or defective workmanship with new materials/workmanship conforming to the JEA Water and Wastewater Standards Manual, or during emergency events or in the event of imminent danger to JEA facilities or customers, repairs may be made by JEA at the Developer's expense.

If any facilities, including service lines that are installed, do not conform to the final lot layout, it shall be considered a misplacement of the installed system, and all costs incurred by JEA for relocation shall be paid in advance by the Developer, or its successor.

3.19 JEA Connection and Fees

Prior to connection to JEA's utility systems and/or issuance of meters, project acceptance must be obtained and all applicable fees must be paid..

JEA is now accepting all new service applications through SagesGov. To obtain draft fees you can access the New Service Applications as described below.

To submit a New Service Application:

- Log into www.sagesgov.com;
 - Select Step 2;
 - Enter your availability number;
 - Select the type of service application you want to apply for;
 - Residential New Service;
 - Commercial New Service;
 - Multi-Family New Service.

3.20 Dedication of Existing Privately-Owned Systems

- A. JEA will not accept existing privately owned, operated, and maintained systems for dedication. These systems include, but are not limited to, the following:
 - a. Existing master metered onsite water distribution systems;
 - b. Existing private pump stations;
 - c. Existing private onsite gravity wastewater collection systems.
- B. On a case-by-case basis, JEA may consider exceptions to the above given one or more of the following criteria are met.
 - a. JEA's system reliability or capacity may be improved or increased as a result of system dedication;
 - b. Additional customers who currently are not served will be provided service via the dedicated facilities;
 - c. Dedication of the system is warranted to eliminate or prevent potential environmental damage.
- C. In the event JEA agrees to accept a privately-owned system, the following events shall occur:
 - a. JEA will evaluate the system, at the Owner's expense, to determine repairs and/or upgrades needed to bring the system into compliance with current JEA standards and regulatory requirements;
 - b. System owner shall, at no cost to JEA, repair or improve the system accordingly;
 - c. Repairs or improvements shall be designed and permitted in accordance with all Local and State rules and regulations;
 - d. Repairs and improvements shall be inspected by JEA during construction;
 - e. System shall be tested by owner's contractor and witnessed by JEA. This includes, but is not limited to; water and wastewater pressure tests, gravity wastewater television inspection, and pump station start up testing;
 - f. The system owner shall prepare an As-Built of the system and submit to JEA for approval;
 - g. The system owner shall submit a dedication package to JEA;
 - h. The system owner shall provide or obtain any easements required for JEA to own and operate the system.

Once these items are complete, JEA will submit a written letter of system acceptance to the owner informing them that JEA has accepted the system for ownership and maintenance.

3.21 Public and Private Point of Service

A customer's point of service is defined by JEA as the location of the connection points identified in the JEA Water and Wastewater Availability response. Points of connection provided by JEA are located in the Right-of-Way at a utility owned by JEA.

JEA Water, Wastewater, and Reclaimed Water Design Guidelines

From the customer's point of service, JEA is obligated to own, operate, and maintain only those utilities that will be constructed in existing or proposed Right -of-Way. Proposed utilities which will be constructed in an approved JEA utility easement must be located adjacent to or abut existing or proposed Right-of-Ways.

With the exception of proposed dedicated Right-of-Ways, JEA is under no obligation to accept ownership, operations, or maintenance responsibilities associated with utilities that will be constructed on private property and in those cases, developers and their engineers should design their projects with private utilities that meet or exceed their service requirements.

3.22 Utility Easements

Utilities shall not be located in easements unless approved by JEA's Development Manager. Approval shall be requested at the pre-application meeting (prior to plan review submittal). Cross-property easements or utilities located within easements between lots are discouraged and will be allowed only with JEA Development Director approval. Blanket easements are not permitted.

If not parallel to the right-of-way, easements must be on separate tracts owned by the community operation and maintenance entity, not an individual owner.

Easements, where allowed, shall be identified as unobstructed and shall have a minimum width of 20-feet for water only or as shown in Table 2.1. Refer to [JEA Water and Wastewater Standards](#) for additional requirements, as applicable.

Landscaping, other than grass, is considered an obstruction.

A Hold Harmless Agreement may be required when installing any improvements including special landscaping, special paving, and/or other specialties in right-of-way or easements over JEA utilities.

Table 2.1: Minimum Easement Width

Pipe Depth (FT)	Minimum Easement Width (FT)		
	One Utility	Two Utilities	Three Utilities
<6	20	25	30
≥ 6 < 8	25	35	40
≥ 8 < 10	30	40	45
≥10 < 12	35	45	50
> 12	N/A	N/A	N/A

Gravity wastewater mains greater than 12-feet deep shall not be located within easements unless approved by the JEA Development Manager.

When easements are adjacent to and parallel to a public right-of-way, the minimum easement width shall be 10-feet for a single utility, or 20-feet for both water and wastewater mains. If an electrical easement is proposed adjacent to the right-of-way and a water, reclaimed water or wastewater easement is also proposed adjacent to the right-of-way, then a water, reclaimed water or force main easement with a minimum width of 5-feet each is required adjacent to and in addition to JEA electric easements.

If a proposed electrical easement is not JEA owned, the water, reclaimed water, or wastewater easement must be 10-feet wide adjacent to and in addition to the electric easements.

3.23 Revision to Dedicated Infrastructure

JEA may allow construction revisions to water and wastewater utilities for developments that have already been fully dedicated to JEA. This may occur in special cases where the applicant intends to modify property lines within an existing development in which water, wastewater, and/or reclaim utilities have been recently constructed and fully dedicated to JEA. JEA reserves the right to require that all construction revisions to dedicated utilities be performed by JEA forces.

- a. All revisions to existing JEA water, wastewater, and/or reclaim utilities must be reviewed and approved by JEA prior to any construction. The developer/engineer must submit the following support documentation to JEA's Development Team: Copy of Approved Addressing Map for the original design;
- b. Copy of Recorded Plat for the original design;
- c. Copy of JEA Approved As-Built drawings for the original design;
- d. Proposed re-designed drawings;
- e. Purpose of re-design;
- f. COJ/County development Services Approval Correspondence;
- g. COJ/County development Proposed Re-addressing Map.

Required electronic files can either be submitted via cd, included with the hard copy submittal and delivered to the JEA Mail Room, emailed to wsedevprojrequests@jea.com, **attention Plan Revision (include project name and availability number)**, or via JEA's FTP site.

Plan review submittals that are missing required information will be returned as incomplete submittals.

The City/County will require a Right-of-Way permit for all work in the R/W. The City/County will define the limits of road re-construction or overlay limits. JEA will not be responsible for any repairs to asphalt, sidewalk, or other non-JEA infrastructures.

The following subparagraphs provide general design guidance for redesign of existing dedicated facilities; however, site conditions may dictate variants to these guidelines as provided and approved by JEA on a case-by-case basis. All construction work shall be in accordance with the JEA Water, Wastewater and reuse Inspection Guidelines for New Development Projects and JEA Water and Wastewater Standards.

3.23.1 Water and Reclaimed Water Services

- a. Water meter boxes shall be constructed in accordance with JEA Water Construction detail W-1 (see JEA Water and Wastewater Standards Manual). As shown in this standard detail, meter boxes shall be located 2-feet from the property line (P/L), unless there is an electric box on the P/L, in which case the water meter box will be 5-feet from the P/L;
- b. Meter boxes shall not be located in an existing or future driveway (D/W) or sidewalk (S/W);
- c. If the applicant wants to move the P/L (see special case description above), JEA will require the meter box to be relocated to meet the above standard (i.e. 2-feet from the new P/L);
- d. JEA may allow relocation of an existing meter box up to 2-feet horizontally;
- e. If the relocation of the water service exceeds 2-feet, then the existing water service will be removed or abandoned including shutting-off and capping existing corporation stop at the water main and a new water service will be constructed;
- f. Locate wire will be required on all new or modified water services (Along the poly service lines) and only one water service will be allowed for each lot;
- g. The meter box and brass fittings may be reused if in excellent condition, as determined by JEA;
- h. Existing curb shall be re-marked accordingly including the grinding and removal of existing curb markings as required;
- i. JEA will require re-submittal of As-Built drawings, which must be approved by JEA;
- j. If no additional services are installed JEA will only require a new 12-month warranty to be provided for the affected area;
- k. If any additional or removal of services occur, an executed JEA Application to construct and dedicate form and revised schedule of values in addition to the new 12-month warranty will be required.

3.23.2 Fire Hydrants

Generally, fire hydrants will be located at the property lines (P/L) between two lots. If developer or engineer moves property lines then:

- a. JEA will require fire hydrants to be relocated to the property line between two lots;
- b. JEA will allow extension of the existing fire hydrant branch main up to 15-feet (locate wire is required);

- c. If more than 15-feet is required, than a new 6-inch tap and valve is required. In this case, the existing hydrant branch will be plugged at the valve; the valve box shall be removed from the plugged valve since it will not serve any future use. For maintenance reasons, this plugged valve should remain on the water As-Built drawings;
- d. Fire hydrant may be reused if in excellent condition, as determined by JEA;
- e. Existing curb shall be re-marked accordingly including the grinding and removal of existing curb markings as required;
- f. JEA will require re-submittal of As-Built drawings, which must be approved by JEA;
- g. If no additional hydrants are installed, JEA will only require a new 12-month warranty to be provided;
- h. If any additional hydrants or removal of hydrants occur, an executed JEA Application to Construct and Dedicate form and revised schedule of values in addition to the new 24-month warranty will be required.

3.23.3 Wastewater Services

Normally, one 6-inch wastewater service shall be provided for each single-family lot. The wastewater service shall generally be perpendicular to the main and terminate in the center portion of the lot. To allow field modifications, to minimize tree and other conflicts and to allow general flexibility in the construction, the center portion of the lot shall be defined to include the center 50% of the lot width. That is, if the lot is 100-feet wide, then the wastewater service may be located inside the 50-linear feet center portion of the lot. Wastewater service laterals within the right-of-way shall avoid being located under an existing or future D/W. If the applicant wants to move property lines then:

- a. In rare instances, JEA may allow more than one 6-inch wastewater service to remain for each residential lot and not enforce the above center 50% rule;
- b. No horizontal adjustments will be allowed to the existing wastewater service lateral;
- c. The applicant shall refrain from abandoning any existing 6-inch wastewater service. If absolutely required, the abandonment of an existing 6-inch wastewater service would include permanently capping the 6-inch pipe (capped within 2-feet back of curb). Existing curb markings for all existing wastewater laterals shall not be removed, but shall remain for locate purposes. Curb marking shall be amended for “abandoned” services by adding an “A” in front of the “S” to designate abandonment;
- d. JEA will require re-submittal of As-Built drawings, which must be approved by JEA. As-Built drawings will include any abandoned infrastructure left in place;
- e. If no additional wastewater services are installed JEA will only require a new 12-month warranty to be provided for the affected area;

- f. If any additional wastewater services or removal occurs, an executed JEA Application to Construct and Dedicate form and revised schedule of values in addition to the new 24-month warranty will be required.

3.23.4 Construction and Dedication of Redesigned Infrastructure

Upon JEA preliminary approval, the applicant will submit all applicable required documents as outlined in these guidelines. Once JEA reviews final plan submittal and issues approval, the applicant will proceed with the project as outlined in the JEA Water, Wastewater, and Reclaimed Development Design Guidelines. In other words, a redesign of dedicated infrastructure is considered a new project and any changes to existing infrastructure requires As-Built drawings, dedication and warranty of any additional assets or notification of any removed assets.

3.24 Revisions to Infrastructure Pre-Dedication

For projects long idled by economic conditions or other factors, much of the provisions of 2.20 (a) through (g) and 2.20.1 through 2.20.3 will apply. When, in the opinion of JEA, the modifications to previously constructed infrastructure would compromise system integrity, JEA will require complete replacement rather than modification.

3.25 Pre-Acceptance Letters

For projects located within St. Johns County, the county will not issue building permits provided one of the following;

- Project Acceptance Letter;
- Receipt showing water services were paid for;
- Pre-Acceptance Letter.

The Pre-Acceptance Letter will only allow the customer to receive the building permit, not the building CO.

To request a Pre-Acceptance Letter:

- Log into www.sagesgov.com;
- Select Step 4;
- Enter your availability number;
- Select “Pre-Acceptance Letter”.

The letter will be emailed. Project must be under construction to request a Pre-Acceptance Letter.

3.26 Pump Out Agreement

It is JEA's policy to not issue water meters before project acceptance. Under the following conditions JEA will enter into a Pump Out Agreement with a customer:

- JEA Lift Station backup power is delayed (generator or pump); OR
- Delayed permanent power to a JEA lift station.

The Pump Out Agreement will expire on the date of project acceptance.

3.26.1 Pump Out Agreement Requirements

- All applicable water and wastewater permits must be cleared
- No more than 20% of permitted lots, with a maximum of 20 lots
- If the backup power is delayed:
 - Developer agreement and bond to cover the cost of the backup power
- Applicable water services and sewer mains must be cleared for use by the inspector prior to agreement issuance
- Agreement will be between Developer and JEA
- Developer will be responsible for the following costs:
 - Plugging the manhole;
 - Pumping out and disposal of waste;
 - Removal of plug;
 - Cleaning line prior to project acceptance.

3.26.2 Applying for a Pump Out Agreement

To request a Pump Out Agreement:

- Log into www.sagesgov.com;
- Select Step 5;
- Enter your availability number;
- Select "Pump Out Agreement Request";
- Fill out the application and submit.

The Development team will review the application to ensure all requirements have been met. The inspector will perform a final inspection on the lots requested and the sewer main indicated for the Pump Out Agreement. Permitting will review the request to ensure the area requested has been cleared. Once these reviews have been completed and approved, the agreement will be emailed. At this point you will be able to apply for the meters you indicated in the agreement.

Section 4.0

Potable Water and Reclaimed Water Design Guidelines

4.0 General

This section provides the minimum guidelines for the design of potable water and reclaimed water transmission and distribution systems. The method of design and/or construction shall be according to accepted engineering practices, this manual, the most current JEA Water and Wastewater Standards Manual, the American Water Works Association (AWWA), Chapter 62-555 and 62-610 of the Florida Administrative Code and all applicable Sections of the Florida Department of Environmental Protection Rules and Regulations for Water and Sewer Systems as well as all applicable federal, state, and local requirements.

4.1 Design Flows

All systems should be sized to provide at least maximum day domestic requirements, peak flow, plus fire flow at residual pressures of not less than 20-psi at all points in the system.

4.1.1 Average Daily Flow (ADF)

The developer's submittal to JEA should clearly state the basis for the design flows.

4.1.2 Single Family Residential

An Equivalent Dwelling Unit (EDU) is the equivalent flow that can be anticipated from one residential connection. Design flows for new water distribution systems shall be based upon 250-gpd/EDU in areas where reclaim water is not available. In areas served by reclaim water, design flows for new water distribution systems may be based upon 200-gpd/EDU with the approval of the Manager of Development.

4.1.3 Multi-Family Residential

Design flows for new water distribution systems may be based upon 80 gpd/bedroom, [Table 1](#) of the Florida Administrative Code Chapter 62-6.008, Standards for Onsite Sewage Treatment and Disposal Systems, Section 1a and 1b (requirements for flow comparisons), or fixture counts.

Flow by fixture count must include final plumbing plans with fixture summary.

4.1.4 Commercial and Industrial

Design flows for new water distribution systems may be based upon the [JEA Sewer Flow Schedule](#) in the Service Availability Request form in Sages or via flow comparisons based on the Florida Administrative Code Chapter 62-6.008, Standards for Onsite Sewage Treatment and Disposal Systems, Section 1a and 1b (requirements for flow comparisons).

Flow by fixture count must include final plumbing plans with fixture summary.

Flow comparisons can be used for projects that are not food operations.

4.1.5 Flow Comparison Analysis

If not utilizing Table 1, a flow comparison analysis will need to be submitted. The analysis must include backup documentation; monthly bills with address and flow, number of units, percent occupancy (if applicable), for the properties in which the comparison is being made, and be signed and sealed by a registered Professional Engineer licensed to practice in the State of Florida. **This option is not applicable for residential projects or food operations.**

Included shall be a summary of each month of use, per address, as well as an overall summary supporting the flow recommendation for the property in question.

The analysis must be submitted with final plans.

4.1.6 Reclaimed Water

The design daily water demand for a typical residential reclaimed water service shall be 600-gpd minimum. Water mains shall be sized utilizing 2.5-gpm/residential units (at a minimum). This water main design rate shall be utilized for all residents in the development, which already takes into consideration the even-odd day irrigation schedule. Multifamily residential, commercial, and industrial flow demand shall be estimated on an individual case-by-case basis. A minimum average daily irrigation rate of 3,900-gpd per acre of irrigable areas during Daylight Savings Time is acceptable unless deemed otherwise by State WMD, FDEP, or JEA.

4.2 Fire Flow

The Developer shall furnish calculations that have been signed and sealed by a registered Professional Engineer licensed to practice in the State of Florida supporting fire protection requirements in accordance with applicable county codes. The applicable County Fire Marshall's Office shall perform its own review. At a minimum, the following fire flow requirements shall be provided.

4.2.1 Single Family Residential

For fire protection purposes, single family residential is defined as detached buildings of no more than one living unit. In single-family residential developments, the developer's engineer shall design for fire flows of at least 1,000-gpm at a minimum residual pressure of 20-psi at the hydrant. If automatic sprinklers are used, then 500-gpm at a residual pressure of 20-psi is acceptable.

4.2.2 Multi-Family Residential

Buildings containing two or more units are defined as multi-family. In multi-family developments, the developer's engineer shall design for fire flows of at least 1,500-gpm from two fire hydrants (750-gpm minimum at each hydrant) with a residual pressure of at least 20-psi at the hydrant.

4.2.3 Manufactured Home Communities

In Manufactured Home Communities, design for fire flows of at least 750-gpm at a residual pressure of at least 20-psi at the hydrant.

4.2.4 Commercial

Minimum fire flow requirements for commercial developments are the same as for multi-family residential developments. The developer's engineer shall design for fire flows of at least 1,500-gpm from two fire hydrants (750-gpm minimum at each hydrant) with a residual pressure of at least 20-psi at the hydrant.

4.2.5 Institutional and Industrial

The developer's engineer shall design for fire flows of at least 2,000-gpm from two fire hydrants (1,000-gpm minimum at each hydrant) with a residual pressure of at least 20-psi at the hydrant.

4.2.6 Fire Hydrant Test Data

JEA will perform a fire hydrant test on an existing JEA fire hydrant for a fee. To submit a Hydrant Flow Test Application:

- Log into www.sagesgov.com;
- Select Step 1;
- Enter your availability number;
- Select "Hydrant Flow Test Application";
- Your results will be emailed to you.

The results of hydrant flow tests are used primarily to evaluate the distribution system's capacity to provide water for fighting fires. The standard formula for converting the test flow to the distribution capacity at some desired residual pressure – usually 20-psi – was developed by the Insurance Services Office (1963), and is given on AWWA M-17 (1989) as:

$$Q_r = Q_t \left[\frac{(P_s - P_r)}{(P_s - P_t)} \right]^{0.54}$$

Q_r = fire flow at residual pressure P_r (gpm)

Q_t = hydrant discharge during test (gpm)

P_s = static pressure (psi)

P_r = desired residual pressure (psi)

P_t = residual pressure during test (psi)

The value of Q_r is referred to as the distribution main capacity in that location, and is used in evaluation of water systems for JEA and insurance purposes. This Q_r value is provided in all JEA fire hydrant test reports. This equation can also be rearranged to provide a rough estimate of residual pressure for some future flow (typically 1500-gpm), given hydrant flow test results according to:

$$P_r = P_s - \left[(P_s - P_t) \left(\frac{Q_r}{Q_t} \right)^{1.85} \right]$$

Q_r = the estimated flow (usually 1,500-gpm)

P_r = the pressure that will exist at that flow rate, given that all other conditions remain the same.

Minimum fire flow requirements for commercial and industrial developments are the same as for multi-family residential developments. The developer's engineer shall design for fire flows of at least 1,500-gpm from two fire hydrants with a residual pressure of at least 20-psi at the hydrant.

Fire hydrant test data results reflect system conditions at the time of the test. Flow and pressure will fluctuate over time in a dynamic system and should be taken into consideration when interpreting or using this data. Fire hydrant test results over one year old shall not be used as a basis of a hydraulic analysis.

4.3 Sizing Water and Reclaimed Water Mains

The pipe sizes as listed herein represent the approximate inside diameter (ID). For HDPE piping, the pipe size will require "up-sizing" to maintain the ID.

4.3.1 Major Transmission Mains

Size of major transmission mains shall conform to JEA Water Master Plan and JEA Water and Wastewater Standards Manual, where applicable.

4.3.2 Distribution Mains

In non-residential areas, distribution mains shall be a minimum of 12-inch diameter, unless they are in a closely interconnected grid, in which case they shall be a minimum of 8-inch diameter.

It is preferred that residential subdivisions are designed with two feeds from distribution mains external to the subdivision to increase hydraulic reliability. Without two feeds from distribution mains external to the project, water mains serving hydrants in residential developments shall be a minimum of 8-inch diameter arranged so that they form a closely interconnected grid.

Single main extensions supplying a looped grid or long lengths of dead-end mains (greater than 1,000-feet) serving more than one hydrant shall not be less than 8-inch diameter.

The use of dead end mains shall be minimized where possible. When necessary, a 2-inch dead-end water main shall be a maximum of 600-feet and shall serve no more than five EDU's.

The maximum number of services on a looped or interconnected 2-inch water main that is interconnected with a minimum of 6-inch water mains shall be limited to 10 EDU's. Any deviation shall be up to the discretion of the JEA W/WW Planning and Development Director, or designee.

All reclaimed water mains shall be sized after hydraulic analysis based upon estimated flow demands and available system pressures. The reclaimed water distribution system shall be designed to maintain 30-psi at a minimum.

Dead end water mains shall terminate with a JEA standard stub-out and a 2-inch flushing hydrant or 6-inch fire hydrant.

4.3.3 Velocities

Velocities shall be a minimum of 2.5-fps and less than 5-fps at peak hour.

4.3.4 "C" Factor

Use the following Hazen-Williams roughness coefficients for new construction:

Pipe Size / Type	Coefficient of Roughness
Less than 16-inch diameter cement-lined ductile iron pipe	120
16-inch diameter and larger cement-lined ductile iron pipe	130
PVC (all sizes including HDPE)	140

4.4 Water Main and Reclaimed Water Main Materials

Materials for potable water mains and reclaimed water mains shall be in accordance with the most recent JEA Water and Wastewater Standards Manual Sections 350 and 351. For 6-inch and larger HDPE pipe, the pipe size shall require up sizing to maintain a consistent inside diameter of the main. For 20-inch and larger pipe, ductile iron pipe will be required.

Water and Reclaimed Water Mains shall have restrained joints for changes in direction. Bends 45-degrees or less should be used in lieu of 90-degree bends.

4.5 Water Main and Reclaimed Water Main Bury Depths

All water mains less than 24-inch diameter shall be designed meeting minimum depth of cover requirements of 30-inches in unpaved areas and 36-inches in paved areas with a maximum of 60-inches in arterial or collector roadways where reconstruction is anticipated. Water mains of 24-inch diameter or greater shall be designed meeting minimum depth of cover requirements of 36-inches (paved and unpaved areas) unless approved otherwise by JEA. Cover for pipe under pavement shall be measured from finished grade.

For 12-inch and larger mains, the proper installation and depth requirements for gate valves may require additional depth of cover. In cases of a 16-inch or larger water main, side actuated valve operators may be required to minimize the depth of bury of the main.

If a utility conflict is encountered and is located in a non-traffic area (no traffic loads), and the new pipe is Ductile Iron, the minimum cover may be reduced to 24-inches, only in the area of the conflict.

In FDOT and railroad rights-of-way, the minimum cover shall be established by the FDOT and railroad respectively.

4.6 Water Main and Reclaimed Water Main Locations

Preferred utility locations within the City of Jacksonville, St Johns County, Nassau County, or Clay County rights-of-ways are to be as established by the City/County Department of Public Works. Water mains shall be designed to be a minimum of 3-feet from right-of-way lines depending on size and depth and a minimum of 3-feet from outside of edge of pavement (or back of curb), and a minimum of 4-feet from gas mains. Exceptions may be granted as appropriate by JEA, provided the City/County agencies are in agreement with the proposed location.

Unless otherwise defined below in [Water Main and Reclaimed Water Main Separation Requirements](#):

- a. Water mains shall have a minimum of 3-feet of horizontal distance between the outside of the water main and the outside of **another water and reclaimed water mains and minimum of 6-feet horizontal distance between the outside of the water main and the outside of force main and gravity sewer main** parallel underground utility;
- b. Water mains shall have a minimum horizontal separation as defined by Section 350 III.4. Water Main and Non-Water Main Separation Requirements of the JEA Water and Wastewater Standards Manual.

Where possible, water mains shall not be designed below open ditch bottoms due to difficulties with utility access and potential damage from future dredging of the ditch.

Water mains shall be designed to be located above box culverts & drainage pipes. As approved by JEA on a case-by-case basis, Ductile Iron Pipe (DIP) will be required if the minimum cover is not possible. In locations where water/reclaim mains cross

JEA Water, Wastewater, and Reclaimed Water Design Guidelines

under a box-culvert, or 30-inch diameter and larger storm water main, JEA will require DIP to be utilized for the main.

Parallel water mains are not allowed, unless approved by the JEA Development Manager. If a proposed water main is to be constructed in a right-of-way or easement where there is an existing JEA water main, the existing main must be abandoned for the length of the new main being installed. All affected services and fire hydrants shall be transferred to the new main, and the remaining portion of the existing main shall be connected to the new main.

Water mains shall be located outside of paved areas, except at roadway crossings. Exceptions to this requirement may be considered within town home, multi-family or commercial development projects, provided the mains do not lie under parking areas.

Proposed development main extensions required to achieve connection to the point of service identified in the JEA Availability response shall be designed within existing or proposed public right-of-way, and in easements if approved by the JEA Development Manager.

4.7 Water Main and Reclaimed Water Main Separation Requirements

Water main separation (from, structures and hardwood trees) shall be in accordance with Sections 350, 428 and 429 of the JEA Water and Wastewater Standards Manual (including JEA Standard Construction Details W-10, W-11, S-26 and S-27).

Pressure Main (Water & Wastewater) Nominal Size (inches) (See Note 1)	Horizontal Separation Requirements (Min)
up to 6-inches	10 feet
8-inches	14 feet
10-inches and 12-inches	18 feet
14-inches and larger	See Note 4
For gravity wastewater mains, see Note 2.	

NOTES:

1. The table above provides the minimum horizontal separation requirements between the proposed JEA maintained utilities (including water mains, reclaimed water mains, meter boxes and wastewater force mains) and existing, proposed and future structures (including above ground structures, concrete footers and top of bank of ponds).

2. For gravity wastewater mains, the horizontal separation from existing, proposed, and future structures (including above ground structures, concrete footers, and top of bank of ponds) shall be a minimum of 3 times the vertical depth of the deepest portion of the manhole-to-manhole wastewater run.
3. Pressure mains with pipe cover greater than 36-inches will require additional horizontal separation as reviewed and approved by JEA O&M Manager.
4. Pressure mains 14-inch and larger may require structural analysis as requested by JEA Development Manager, and will require additional horizontal separation as reviewed and approved by JEA O&M Manager.
5. All depth measurements will be based upon final finished grade elevations, unless approved otherwise by JEA.

4.8 Swabbing Launching Stations

When determined necessary by the design engineer, and in conjunction with the JEA Planning Team, swabbing launching stations will be required on force mains as per the details in the latest JEA Water and Wastewater Standards Manual, Plate W-45 and W-45A-D.

4.9 System Connections

After permit COC has been issued, connections and ties to the JEA Water System and transfer of services shall be performed by a licensed master plumber or underground utility contractor under supervision of JEA. Taps shall be scheduled at least 72-hours in advance by contacting the JEA inspector.

JEA will install a permanent meter, upon project acceptance, application, and payment of all fees by the requestor.

Unless approved by JEA, size-on-size taps are limited on PVC mains to 12-inch and smaller. Size-on size taps are acceptable on DIP (all sizes). For size-on-size taps on 8-inch and larger mains, the actual tap hole size shall be reduced by 1-inch.

No taps shall be made within 5-feet of a joint. When connecting a 2-inch main to an existing main, a minimum 4-inch gate valve shall be used with a 4-inch plug with a 2-inch tap. No 2-inch main valves will be allowed.

Taps requiring meter installations of size 2-inch and smaller shall include the service pipe, meter box, and corporation stop sized ready to accept the meter installation by JEA. (JEA Water Standard Construction Detail W-2). Service tap and line size must follow the table below:

Tap Size (inches)	Size of Service (inches)	Meter Size (inches)
1	1	3/4
1	1	1
2	1.5	1.5
2	2	2
4	3	3

Taps requiring meter installation of size 3-inch and larger must include the service pipe and meter vault. For meters 3-inch and larger, JEA will build and install the meter assembly. After installation, JEA will install the meter vault (furnished by the developer's contractor) to grade. (JEA Water Standard Construction Detail W-6). For reclaimed water meters 3-inch and larger, the construction requirements will be similar to Detail W-6, but without the bypass piping. Service tap and line size must match the meter size.

Taps shall be piped straight through where the meter is to be set according to the following laying lengths as measured between the control valve and the backflow prevention device:

- Meters size 3-inch and 4-inch shall have a laying length of at least 14-feet
- Meters size 6-inch and 8-inch shall have a laying length of at least 20-feet
- Meters size 10-inch shall have a laying length of at least 24-feet

4.10 Fire Hydrant Locations

4.10.1 General

Hydrants shall be painted and installed in accordance with the applicable county fire codes. Private fire hydrants shall be painted red unless otherwise specified in the local county's standards. (See JEA Water Standard Construction Details W-12, W-13 and W-14).

Fire hydrants shall not be connected to reclaimed water mains.

Fire hydrants shall be constructed on the same side of the road as the water main. Exceptions may be approved depending on a specific situation.

Fire hydrants shall be located in easily visible and accessible locations. They should be located at entrances and intersections whenever possible, or fire hydrants should be located at property corners just inside the right-of- way.

Fire hydrants should not be located at the same corners as water meters or electric transformers.

Fire hydrants should have a minimum clearance of 3-feet from the edge of pavement or the back of curb to the face of the hydrant.

New or relocated fire hydrants shall be located so that the hydrants are at least:

- a. 3-feet from any existing or proposed storm sewer, or reclaimed water main;
- b. At least 6-feet, and preferably 10-feet, from any existing or proposed gravity, vacuum-type, or pressure-type wastewater main or wastewater force main.

Fire hydrants shall be located with the steamer nozzle (largest opening) directed towards the street or parking area.

There shall be no trees or permanent structures within 10-feet of any hydrant.

There shall be no obstructions (fences, landscaping, signs, etc.) within 5-feet of any hydrant.

4.10.2 Single-Family Residential

Single-family residential areas shall have fire hydrants located not more than 500-feet apart when measured along streets or acceptable access ways, except in a cul-de-sac or dead-end street where a fire hydrant shall be located not more than 600-feet from the center of the turnaround. Single-family detached residential property shall have a fire hydrant located within 500-feet of each building location. No more than one fire hydrant shall be provided on a dead end 6-inch water main.

4.10.3 Multi-Family Residential, Commercial and Industrial

Fire hydrants in commercial, industrial, or multi-family residential areas shall be located not more than 500-feet apart when measured along streets or acceptable access ways, and shall be within 500-feet of the most distant corner of each commercial or multifamily structure.

All fire hydrants and independent valves are to be located within the street right-of-way or easement.

Multiple fire hydrants within commercial and multi-family residential projects shall be served with a minimum 8-inch water main.

If the proposed project is to be served by a well, fire protection must be addressed and approved per the Fire Marshal's requirements and indicated on the design plans. The Fire Marshal will require an on-site water storage tank or alternate water source.

All fire hydrant spacing must be approved by the Fire Marshal or authority having jurisdiction.

4.10.4 Open Rural Areas

For open rural areas with few services (excluding the service areas described above), water mains larger than 6-inch shall include a fire hydrant every 1,000-linear feet (max) for JEA line maintenance, unless otherwise approved by JEA.

4.11 Water and Reclaimed Water Valves

There shall be a sufficient number of valves designed such that single mains in the network can be isolated from the remainder of the system thereby providing flexibility for operation and maintenance while minimizing number of customers out of service.

Valves shall be provided at 800-foot (maximum) intervals within single-family residential areas.

Valves shall be provided at 500-foot (maximum) intervals within multi-family residential projects as well as industrial and commercial areas.

On transmission mains less than or equal to 16-inch diameter, with a limited number of service connections, valves shall be installed at a maximum of 1,000-foot intervals, and at distribution branches. On transmission mains greater than 16-inch diameter, valves shall be located at a maximum of 2,500-foot intervals, and at distribution branches. Where applicable, valves on transmission mains should be located next to the fire hydrant tees to facilitate field location.

Valves shall be installed on all water main branches as follows: two directions on a tee.

Valves should be located so as not to conflict with curb and gutter or be in the normal path of tires and should be located near the tee fitting.

Valves shall be marked with a “V” scribed in the curb closest/adjacent to the below grade valves. The “V” cut shall be painted blue for potable water or pantone purple for reclaimed water.

4.12 Flushing Hydrants and Sample Points on Water Mains

A 2-inch flushing hydrant assembly or a 6-inch fire hydrant shall be provided at the end of all dead-end, non-circulating water mains and stub-outs.

1-inch temporary sample points shall be provided, at minimum:

- At the end of all water mains and stub-outs of 40-feet or greater;
- At 1,000-foot maximum intervals on long main extensions;
- On all looped mains;
- In accordance with permit conditions;
- At the point of connection to the existing water main.

Fire hydrants shall not be used as sample points. The contractor shall remove all temporary sample points after clearance from JEA and DEP.

4.13 Flushing Hydrants on Reclaimed Mains

A 2-inch flushing hydrant assembly shall be provided at the end of all dead-end, non-circulating reclaimed mains and stub-outs.

Must use reclaimed (purple) poly.

Curb stop must have the reclaimed emblem.

Reclaimed meter box must be used.

4.14 Air Relief Valves

When necessary, at high points in water mains where air can accumulate, provisions shall be made to remove the air by means of air relief valves.

4.15 Water and Reclaimed Water Services

Water services shall be provided to each lot, building, or parcel requiring a separate water meter.

Single long and short side water services shall be 1-inch for single-family residential subdivisions, and shall be located at adjacent property lines along the front of the property to be served as shown in JEA Water Standard Construction Detail W-1 of the JEA Water and Wastewater Standards Manual.

Single 2-inch long side service serving two services, or gang water services may be utilized and shall terminate with a 1-inch service for each adjacent lot per JEA Water Standard Construction Detail W-1 of the JEA Water and Wastewater Standards Manual. Gang water services (three or more services in one area) are discouraged if property lines may be modified in the future.

Gang services are acceptable if constructed in accordance with JEA Water Standard Construction Detail W-1 of the JEA Water and Wastewater Standards Manual.

No more than five domestic service connections are allowed on a 2-inch water or reclaimed water main in a new subdivision.

The service size shall be smaller than or equal to the main size to which it is connecting. For 4-inch and larger meters, domestic service size shall not exceed meter size. 3-inch meters can be served either by a 3-inch or a 4-inch service size.

No service shall be allowed beyond the valve on a phase line water or reclaimed water main stub-out.

No 2-inch or smaller service taps shall be permitted on water or reclaimed water mains which are greater than or equal to 20-inch diameter.

The maximum length of a water or reclaimed water service (distance from the connection at the main to the water meter) shall be 100-feet, unless approved otherwise by JEA.

Water service locations shall be marked with a “W” scribed in the curb and painted blue.

Reclaimed water service locations shall be marked with a “R” scribed in the curb and painted purple.

Residential services using reclaimed water for irrigation must have a JEA approved backflow preventer installed on each potable water service, per detail W-15, prior to the installation of a JEA reclaimed water meter. The installation of a backflow preventer shall be in accordance with the [JEA Rules and Regulations for Water, Sewer, and Reclaimed Water Services](#), Appendix B, Cross Connection Control Policy.

In developments where there is not sufficient lot frontage to meet separation requirements JEA may allow, on a case-by-case basis, the use of reclaim master meter(s).

4.16 Water Meters

4.16.1 General

All water meters shall be located in accordance with the JEA Water and Wastewater Standards Manual, unless otherwise approved. For typical residential layout, refer to JEA Water Standard Construction Detail W-1. This location varies in St. Johns and Nassau Counties. Contact the appropriate County Engineering department for correct water meter location criteria.

Water meter installation shall be in accordance with the [JEA Rules and Regulations for Water, Sewer, and Reclaimed Water](#), Chapter 3. (In accordance with these Rules and Regulations, the installation of two or more meters in lieu of one large meter serving a single service is prohibited (potable or reclaimed water meters).

Water meters shall have a minimum 10 ft. separation from all fixed objects (buildings, signage, shade trees, etc.).

For non-active services, the meter box shall be located adjacent to the right of way at the property, lot, or parcel that it is serving, and clearly marked with a 2-in X 2-in X 4-ft pressure treated post.

Water meter boxes shall not be located within driveways or sidewalks. Exceptions may be approved by JEA on a case-by-case basis.

A separate water supply meter and a separate fire service is required for projects with on-site fire protection. JEA policy does not allow the installation of wastewater deduct meters. In order to achieve a metering/billing arrangement that would reduce wastewater charges when less sewage enters the JEA system than water consumed, the site can be designed with irrigation or water only meters or a separate wastewater flow meter to correctly establish metering/billing service. Examples of this type of service include cooling tower evaporation, industrial process water, etc.

4.16.2 Water Meter Sizing

Design Engineer shall supply calculations, signed and sealed by a registered Professional Engineer licensed to practice in the state of Florida, supporting meter size selection for all meters sized 1-inch and larger.

JEA utilizes SENSUS meters (www.sensus.com) and Badger meters (www.badgermeter.com) for both potable and reclaimed water use. The meter size shall be selected by the design engineer based upon many design factors including the maximum continuous 24-hour flow rate (MCFR) (1/2 the safe maximum operating capacity) as listed below:

Meter Size	Sensus	Badger Positive Displacement	Badger Turbine Flow	Sensus OMNI C2	Sensus OMNI T2	Sensus OMNI F2
3/4"	15	15	n/a	n/a	n/a	n/a
1"	25	35	n/a	n/a	n/a	n/a
1.5"	n/a	60	100	80	80	n/a
2"	n/a	85	155	80	100	n/a
3"	n/a	n/a	n/a	200	250	n/a
4"	n/a	n/a	n/a	400	500	500
6"	n/a	n/a	n/a	800	1000	1000
8"	n/a	n/a	n/a	1350	1750	1750
10"	n/a	n/a	n/a	2000	2750	2750

4.16.3 Portable Fire Hydrant Meters for Construction Activities

Portable fire hydrant meters will not be issued for building construction sites where the water system has not been accepted for operation and maintenance by JEA. A portable fire hydrant meter provided by JEA consists of a 2-inch meter and backflow device.

Fire hydrant meters shall be issued to the specific party who will utilize the meter and who will be responsible for the meter and payment for water usage. Hydrant meters are issued by JEA and can be used in:

- Duval County;
- Parts of St. Johns County to include Ponte Vedra, and some parts of St. Augustine around the area of CR-210;
- Nassau County (JEA Service Territory).

Meters are issued for periods of 6-months. At the end of the 6-month period, the meter must be returned and a new meter issued. Failure to exchange the backflow assembly within the specified time period is a violation of JEA's Cross Connection Control Program Policy(JEA Rules and Regulations for Water, Sewer, and Reclaimed Services, Appendix B) (JEA shall have the authority to refuse service to customers who are found to be chronic violators of the Fire Hydrant Meter Policy. Violations include the failure to report meter readings, exchange the meters on time and make regular invoice payments.

4.16.4 Multi-Family, Commercial or Industrial Development Metering

Unless otherwise approved, multi-family developments and commercial developments serving multiple tenants where the entire project is to remain under single ownership, the entire site will be master metered with all on-site utilities remaining under private ownership and operation unless otherwise approved by JEA. If the site is master metered, the property owner must provide for sub-metering of individual units as a condition of water service from JEA.

When pre-approved by JEA's Development Manager, on-site utilities for projects under single ownership serving multiple tenants (individually metered) may be accepted for operation and maintenance provided that, the dedicated on-site utilities are contained within an acceptable, dedicated right-of-way or similar quality, dedicated, unobstructed, exclusive JEA utility easement sized as per these guidelines.

For multi-family and commercial projects, water meters shall be located in:

- Accessible areas;
- Outside of landscaped and paved areas;
- A minimum of 10-feet from buildings or other permanent structures;
- Behind sidewalks;
- Generally adjacent to parking areas or roadways;
- A minimum of 3-feet from the edge of pavement.

For water meters 1-inch and larger, the engineer shall submit a detailed water demand estimate with the average daily flow and peak hourly demand indicated for review (signed and sealed by registered Professional Engineer licensed to practice in the State of Florida) and approval by JEA.

A 3-inch or larger meter shall be located in a 15-foot by 20-foot minimum easement provided adjacent to the right-of-way line.

4.17 Backflow Preventers

A metered detector check backflow preventer shall be required on all projects requiring automatic sprinkler (AS) system services and/or the use of on-site private fire hydrants for fire protection.

Backflow preventers shall be in accordance with JEA Rules and Regulations for Water, Sewer and Reclaimed Water Services, Appendix B, Cross Connection Control Policy and shall be located on private property within 10-feet of the meter. Alternative locations must be approved by JEA prior to installation.

A backflow device is required on all potable water services installed on private property after the meter where reclaimed water is available. (See JEA Water Standard Construction Detail W-15).

Freeze protection may be required on a backflow device associated with fire mains. The design engineer shall consult with the local Fire Marshall to determine if freeze protection is required. JEA recommends freeze protection on all backflow devices.

A backflow device is not required on any reclaimed water service unless deemed otherwise by JEA.

In the event that reclaimed water is not yet available in a required reclaimed water area, a jumper line will be designed and installed between the potable and the reclaimed line. JEA will provide the required backflow device for this jumper line; the developer's contractor will install it.

4.18 Water Treatment Plants

JEA requires water treatment plants to be dedicated on an individual basis. It is the developer's responsibility to contact JEA in the planning stage for direction.

4.19 Stub-Outs and Terminal Point

All proposed water main extensions shall terminate with a JEA standard stub-out past the proposed project connection and shall consist of a minimum of 20-feet of pipe, a resilient seat gate valve or plug valve installed adjacent to the last tee or tapping sleeve and a plug. The plug fitting shall be tapped and include a 2-inch (bronze) corporation stop (MIP) on the dead end. If there is potential for future development at the upstream property, the proposed water main may be required to extend past the project connection point to the upstream property line or other suitable location. In the event that the line extends past the property or phase line, a temporary access easement will be granted. See JEA Standard Construction Detail W-37.

Section 5.0

Wastewater Design Guidelines

5.0 General

This section provides the minimum guidelines for the design of wastewater collection and force main systems. The method of design and/or construction shall be according to accepted engineering practices, this manual, the most current JEA Water and Wastewater Standards Manual, the latest edition of the Recommended Standards for Sewage Works (Ten State Standards), and all applicable Sections of the Florida Department of Environmental Protection Rules and Regulations for Water and Wastewater Systems.

Wastewater hydraulic design notes (signed and sealed) shall be submitted to JEA for review and approval and will be submitted to the regulatory agencies for permit approval. The hydraulic design notes submittal shall include the hydraulic design, catalog data for the pumps, electrical system, controls, and up-lift calculations for the wet-well.

5.1 Design Flows

5.1.1 Average Daily Flow (ADF)

Design flows for new sewer collection systems shall be based on [Table 1](#) of the F.A.C. Chapter 62-6.008, Standards for Onsite Sewage Treatment and Disposal Systems, or on Flow Comparison Analysis as identified in Section 4.1

5.1.2 Equivalent Dwelling Units

An Equivalent Dwelling Unit (EDU) is the equivalent flow that can be anticipated from one residential connection. In all JEA sewage treatment areas, assume 80-gallons per capita per day (gpcd) to calculate the average daily flow (ADF). To calculate the ADF from a single EDU, multiply the gpcd by an occupancy factor of 2.5.

5.1.3 Peak Flow

Wastewater systems and facilities shall be designed for peak flows calculated in accordance with the Recommended Standards for Sewage Works, latest edition (Ten State Standards), and as shown below.

$$\text{Peaking Factor} = \frac{18 + \left(\sqrt{\frac{\text{Population}}{1000}} \right)}{4 + \left(\sqrt{\frac{\text{Population}}{1000}} \right)}$$

Peak Flow = Peaking Factor * Average Daily Flow (ADF)

5.2 Gravity Wastewater Mains

5.2.1 Sizing Gravity Wastewater Mains

Design all wastewater mains to carry peak design flow when flowing full (no hydraulic head allowed). Peak design flow may not exceed pipe capacity.

Gravity wastewater mains shall be a minimum 8-inch diameter in the JEA right-of-way (R/W) and/or private R/W (easements).

Gravity wastewater mains shall be installed on a uniform alignment and grade between manholes.

Collection systems serving more than two buildings, lots, or parcels shall be 8-inch gravity mains with manholes.

Upsizing of sewer gravity lines for purposes of a flatter slope design will not be permitted.

5.2.2 Gravity Wastewater Slope Requirements

All sewers shall be designed and constructed to give mean velocities, when flowing full, of not less than 2.0-feet per second, based on Manning's Equation using a "n" value of 0.013. The following are the recommended minimum slopes that should be provided for sewers 42-inches or less. However, slopes greater than these may be desirable for construction, to control sewer gases, or to maintain self-cleansing velocities at all rates of flow within the design limits. The maximum slope for all pipe diameters shall be such that the velocity in the pipes does not exceed 5-fps when calculated using Manning's Equation. Maximum slope may be used on terminal pipe runs only, unless otherwise approved by JEA. In the event that an applicant wishes to use a slope less than the minimum listed below, they will require written approval from the Development Manager. JEA reserves the right to require specific slopes as needed to insure future service and maintenance needs.

Pipe Diameter (Inch)	Minimum Slope (ft/ft)
8	0.004
10	0.0028
12	0.0022
15	0.0015
16	0.0014
18	0.0012
21	0.001
24	0.0008
30	0.0006
36	0.0005
42	0.0004

Sewers 48-inches or larger should be designed and constructed to give mean velocities, when flowing full, of not less than 3.0-fps, based on Manning's Equation using a "n" value of 0.013.

Prior to preliminary review, the applicant must obtain JEA Development Manager pre-approval, in writing, for any deviation from the minimum slope.

5.2.3 Gravity Wastewater Main Materials

Materials shall be in accordance with the most recent JEA Water and Wastewater Standards Manual, Section 428.

The type, class, grade, and alignment of wastewater pipe may be changed only at manholes.

All gravity mains must be PVC SDR-26 heavy wall wastewater pipe.

DIP pipe is not allowed for gravity wastewater.

Where the mains or laterals are above ground or otherwise exposed as in bridge crossings or ditch crossings, wastewater mains shall be stainless steel.

5.2.4 Gravity Wastewater Main Depth

Gravity wastewater mains shall be designed for minimum depth requirements of 30-inches in unpaved areas and 36-inches in paved areas.

No gravity wastewater main with wastewater service laterals shall be constructed with a greater than 12-foot depth of cut from finished grade. Wastewater service laterals associated with gravity wastewater mains that are deeper than 12-feet must be routed to a gravity wastewater main high-line, a manhole, or other JEA approved method (see JEA Wastewater Standard Construction Details S-4 and S-5 for manholes with highline connections).

No gravity wastewater main shall be constructed with greater than 15-foot depth of cut from finished grade.

5.2.5 Gravity Wastewater Main Location

Gravity wastewater mains shall be designed for installation on the centerline of roadways where possible. On curved roads, the wastewater main and manholes shall be located such that the pipe and manholes remain within the limits of the paved area.

Install gravity wastewater mains with a straight alignment between manholes.

Locate gravity wastewater manholes a minimum distance of 4-feet from the face of the curb to the edge of the manhole.

Locate trunk wastewater 24-inch and larger 5-feet west of, or 5-feet south of the centerline of the public rights-of-way or private rights-of-way (easements), unless approved otherwise by JEA.

Gravity main stub-outs shall:

- a. Be extended to the property line, plat line or phase line;
- b. Shall extend a minimum of 10-feet past the edge of pavement or a distance of 1.5 times the wastewater main depth, whichever is greater;
- c. Terminate with a manhole, to allow for future wastewater main extension.

All proposed gravity wastewater mains, located in easements that cross wetlands, must be approved in writing by JEA's Development Manager prior to design. If approved by JEA, the following design features shall be included:

- a. Long runs of gravity wastewater main located in easements that cross wetlands, which are restored as wetlands, shall be encased in a steel casing;
- b. Those runs which include manholes, located across wetlands or limited access areas, shall be accessible to vehicles and heavy equipment;
- c. A stabilized access road 12-feet wide with a minimum of 12-inch deep subbase with a minimum Limerock Bearing Ratio of 40 shall be provided over the gravity pipe and shall be indicated on the drawings;
- d. The access road should be designed to provide adequate drainage and to prevent erosion from storm runoff;
- e. A truck turnaround area may be required at the end of all access roads;
- f. In some cases, JEA will require the addition of 6-inch thick gravel or crushcrete along the 12-foot wide access road.

5.3 Wastewater Main Separation Requirements

A horizontal distance of 6-feet shall be maintained from all gravity wastewater mains to drainage structures, telephone duct banks, electrical transformers, signal relays, power poles, and other structures in the right-of-way as well as any other parallel underground utility with the exception of water mains, unless approved by JEA's Development Manager in writing. Where gravity mains cross other underground utilities with the exception of water mains, a vertical separation of 12-inches shall be maintained, unless approved by JEA's Development Manager in writing. (See below for water main and gravity wastewater main separation requirements.) All distances shall be measured from the outside edge of the pipes.

Distance from building foundations, or tops of banks, to gravity wastewater mains must be a minimum distance of three times the vertical depth of the deepest portion of the manhole-to-manhole wastewater run.

In locations where gravity wastewater mains cross under a box-culvert, or 48-inch diameter and larger storm water main, JEA will require an approved flowable fill material surrounding the wastewater main. In these cases, provide 12-inches of excavatable flowable fill around the outside of the wastewater main, approximately 10-feet in each direction from the crossing point. On a case-by-case basis, JEA may require DR-18 pipe for the main as well.

Gravity wastewater mains located adjacent to retention pond areas shall be designed with sufficient distance from pond to avoid side slope collapse based on three to one side slopes, anticipated pond water elevations and depth of bury. JEA reserves the right to require casing pipe as necessary to maintain the utility.

5.4 Gravity Services

In areas where on-site sewage disposal systems exist, new gravity service termination at the right-of-way shall be established by the designer to accommodate rerouting of yard piping to the service termination elevation via gravity flow; otherwise, an on-site permitted private pump station will be required.

JEA shall not connect any customer that does not abut Water, Wastewater, or Reclaimed Water mains without requiring the construction of a main line extension. Single gravity services shall be provided to each lot, building, or parcel, provided that adequate and unobstructed easements are dedicated to JEA for maintenance. Easements must be approved by JEA.

New 6-inch wastewater service laterals which tap into existing JEA terminal manholes or existing JEA wastewater collection mains shall be constructed by JEA only, unless approved otherwise by JEA.

No 6-inch gravity wastewater service connection is permitted on JEA gravity wastewater mains which are 16-inch or larger. A high-line may be acceptable for these situations.

If a project site is currently served by a private well for potable water supply, a JEA approved water meter, reading in gallons must be installed on the service side of the well for the purpose of wastewater billing. Upon receipt of a Private Well Meter Application along with payment of fees, the JEA approved meter will be delivered and installed by a licensed plumber contracted by the property owner. Upon completion of the installation, JEA shall be contacted to perform an inspection of the installation to ensure compliance with JEA standards.

Single gravity services shall not exceed the size of the gravity main. For 8-inch connections to an 8-inch main, provide manhole at connection to main.

Saddle/Doghouse manholes are not allowed.

Single services shall be a minimum of 6-inch diameter at 1/8-inch per foot minimum slope.

Stub-outs for services shall be marked with a 2-in X 2-in X 4-ft pressure treated pine post painted green. Services shall be marked with a "S" scribed in the curb and painted green.

Double services or multiple connected wastewater services (gang services) are not acceptable. However, they may be used for privately owned and maintained commercial and multi-family systems under single ownership. Double or multiple services may be allowed in the case of a condominium project where the onsite wastewater systems are the property of the condominium association (see JEA Standard Construction Detail S-51).

Private clean-outs shall not be installed in the R/W or JEA easement. Private clean-outs, if installed, must be installed on private property and shall be maintained by the customer.

Services shall be designed with a 30-inch minimum cover and shall terminate 30-inches to 60-inches deep at the R/W line where not in conflict with water mains, drainage pipes, and other existing utilities or buried electric.

A service shall be designed to connect to the gravity main with a wye fitting rotated 45-degrees up. The invert elevation of the service at the main shall be at or above the crown of the mainline pipe. (See JEA Standard Construction Details S-19 and S-20).

Gravity wastewater service laterals shall be provided to all undeveloped property and future phases of the project in accordance with the wastewater master plan. The location and length of wastewater service lateral shall be designed to minimize future maintenance of traffic, roadway repairs, and restoration work.

5.4.1 Single Family Residential Services

Single services shall be installed at the center of the lot and front the property being served. Services shall be installed perpendicular to the wastewater main. Deviations from this criterion must be pre-approved in writing by JEA. The center portion of the lot shall be defined to include the center 50% of the lot width. That is, if the lot is 100-feet wide, then the wastewater service may be located inside the 50-linear foot center portion of the lot.

6-inch single services shall be limited to 60-foot maximum length (length between wastewater main or manhole and the customer's property line).

Terminal manholes located in residential cul-de-sacs are allowed three service connections (6-inch diameter maximum) provided the service connection inverts are a minimum of 3-inches above that of the manhole and provide 45 degrees of separation between each service..

5.4.2 Multi-Family Residential, Commercial and Industrial Services

6-inch services shall serve no more than six multi-family units as shown on JEA Standard Construction Detail S-51.

All 8-inch and larger wastewater services shall be connected into manholes, not the wastewater main.

Wastewater inflow from a general dumpster area, including storm-water runoff, is not permitted to enter the JEA wastewater system.

Service Connections to manholes are allowed as follows:

- a. Inline manhole connections (8-inch diameter and larger) are limited to 2-services, one from each side of the street.
- b. Services shall not be connected to stub-outs without a manhole.
- c. 8-inch diameter and larger service stub will require a manhole.

5.4.3 Wastewater Service Locates

JEA will perform a physical locate of a wastewater connection point for a fee. For locate services, submit a completed application and applicable fee to JEA.

If no connection point is located, the fee may be credited towards the installation cost of a wastewater connection, as approved on a case-by-case basis. See [Sewer Locate](#) for instructions on applying.

5.5 Wastewater Meters

JEA policy does not allow the installation of wastewater deduct meters. In order to achieve a metering/billing arrangement that would reduce wastewater charges when less sewage enters the JEA system than water consumed, the site can be designed with irrigation or water only meters or a separate wastewater flow meter to correctly establish metering/billing service. Examples of this type of service include cooling tower evaporation, industrial process water, etc. All wastewater flow metering designs shall conform to JEA Commercial Meter Services, and Sewer Flow Metering Design Guidelines. Contact Meter Services O&M with any questions at mgrs40700@jea.com.

5.6 Wastewater Manholes

Manholes shall be installed at the end of each main and at all changes in grade, pipe size, pipe material, alignment, and at all pipe intersections.

Unless otherwise approved by JEA, a minimum 0.1' drop between incoming and outgoing inverts shall be provided at all manholes.

Manholes where main pipe size changes occur shall place the 0.8-depth point of both wastewater mains at the same elevation.

The maximum spacing of manholes shall be 400-feet for wastewater mains less than or equal to 16-inch diameter and 500-feet for wastewater mains greater than 16-inch diameter. A gravity main exceeding the maximum length may be allowed, with prior written approval from JEA's Development Manager, if it is required to complete a terminal run. If this occurs, a note shall be added instructing the contractor "not to exceed the additional length required to complete the run".

Manholes shall be located:

- a. Along the centerline of city or private roadways (including parking lots);
- b. Out of the tire lane;
- c. A minimum of 4-feet from the edge of the manhole to the face of curb and gutter.

Manholes shall not be installed in the flow line of inverted crown roads or within the design high water limits of gutters, swales, storm water ditches, or retention/detention areas.

Terminal manholes may be required on stub-outs for the purpose of inspection and maintenance, or future extension of the system.

Manholes shall be assigned an ID number, beginning at the junction or deepest manhole as number one, and subsequent manholes being numbered consecutively up to the shallowest manhole.

5.6.1 Invert and Rim Elevations

All manhole rings and covers shall be installed at the final grade level.

Design depth for all terminal manholes is to be at no less than 4-feet from the final elevation of the top of the manhole ring and cover to the pipe invert, and must include at least one course of manhole adjustments.

5.6.2 Drop Connections

Outside drop connections are only allowed for 12-inch drop pipe size and larger per JEA Standard Construction Detail S-7.

Inside drop construction is required for 2-foot or greater drops, and shall be constructed per JEA Standard Construction Detail S-4.

5.6.3 Lining

At a minimum, all junction manholes (manholes located closest to the pump station wet well), manholes which include a 24-inch or larger pipe, and manholes receiving a force main shall be coated internally as outlined in Section 446 of JEA Water and Wastewater Standards Manual. In addition, for new construction projects, additional manholes downstream of the point of connection of a 6-inch or larger force main may be required to be lined based on flow quantities and/or velocities.

5.7 Force Mains

5.7.1 Pipe Diameter

Force mains shall be a minimum of 4-inch diameter in the right-of-way, or within JEA easement if the main is to be dedicated. Exceptions may be granted for low-pressure systems, which discharge directly into a gravity wastewater system.

Force mains shall be sized for peak flow at a minimum velocity of 2.0-fps (feet per second) and less than 5.0-fps unless otherwise approved by the JEA Development team. Force mains shall be designed so as to not exceed a maximum allowable sewer force main pressure of 60 psi. If approved by JEA, 4-inch force mains may be initially sized at less than 2-fps. Exceptions may be made, by the Development Manager in writing, on a case-by-case basis during the plan review process.

A plan and profile shall be provided for all horizontal directional drill (HDD) pipe and for all force main (open-cut) extensions. The plan and profile shall conform to the requirements laid out in Section 2.4.6 Horizontal Directional Drill/Jack & Bore Plan Submittal requirements and shall be in accordance to JEA Water and Wastewater Standards Sections 750 and 755.

5.7.2 Depth of Bury

Force mains less than 24-inch diameter shall be designed meeting minimum depth requirements of 30-inches in unpaved areas and 36-inches in paved areas, with a maximum of 60-inches in arterial or collector roadways where reconstruction is anticipated, unless approved otherwise by JEA. Force mains of 24-inch or greater diameter shall be designed with minimum depth requirements of 36-inches (paved and unpaved areas) unless approved otherwise by JEA. Cover for pipe under pavement shall be measured from finished grade.

For 12-inch and larger mains, the proper installation and depth requirements for gate valves may require additional depth of cover.

If a utility conflict is encountered and is located in a non-traffic area, using DR18 PVC, the minimum cover may be reduced to 24-inches only in the area of conflict. Any reduction in pipe cover will require written approval from JEA Development Manager.

In FDOT and railroad rights-of-way, the minimum cover shall be established by the FDOT and railroad respectively.

Force mains shall be designed to reduce or minimize the number of high points. Changes in elevation, which exceed 2-feet, will require an air release valve. (See JEA Standard Construction Detail S-29 and S-29A).

5.7.3 Material and Fittings

Materials shall be in accordance with the most recent JEA Water and Wastewater Standards Manual Section 429 and 430. For 6-inch and larger HDPE pipe, the pipe size shall require up sizing to maintain a consistent inside diameter of the main.

Force mains shall have restrained joints for changes in direction. Bends 45-degrees or less should be used in lieu of 90-degree bends.

All proposed force main extensions shall terminate with a JEA standard stub-out past the proposed project connection and shall consist of 40-feet of pipe, a resilient seat gate valve or plug valve installed adjacent to the last tee or tapping sleeve and a plug. The plug fitting shall be tapped and include a 2-inch (bronze) corporation stop (MIP) on the dead end. If there is potential for future development at the upstream property, the proposed force main may be required to extend past the connection point to the upstream property line or other suitable location. In the event that the line extends past the property or phase line, a temporary access easement will be granted. The length of the stub-out may be reduced to a minimum of 20-feet, if approved by JEA Development Manager in writing, to avoid installation conflicts in the right-of-way. See JEA Standard Construction Detail S-43 and S-44.

5.7.4 Location

Install force mains, where feasible, on the opposite side of the street from the water main, unless otherwise approved by JEA. Force mains shall be designed to be a minimum of 4-feet from the right of way line and a minimum of 3-feet from the edge of pavement or back of curb. Larger pipes and greater depths of cover may require greater distances from the right of way line and edge of roadway.

A minimum horizontal distance of 6-feet, unless approved in writing by JEA's Development Manager, shall be maintained from all force mains to drainage structures, telephone duct banks, electrical transformers, signal relays, power poles, and other structures in the right-of-way as well as any other parallel underground utility with the exception of water and reclaimed water mains. Where mains cross other underground utilities with the exception of water and reclaimed water mains, a minimum vertical separation of 6-inch shall be maintained. See [Force Main Separation Requirements](#). All distances shall be measured from the outside edge of the pipes.

Force main connections to manholes shall connect at the bottom of the manhole matching the crown of the existing pipe as shown in JEA Standard Construction Detail S-18. Manholes that force mains are discharging in to shall be lined with a protective coating as specified in Section 446 of the Water and Wastewater Standards Manual. The angle between influent force main and effluent gravity pipe shall be between 135-degrees and 225-degrees unless approved otherwise by JEA. The flow from the force main should be directed into the effluent gravity pipe of the manhole in an effort to reduce turbulence.

Force mains shall not be constructed below open ditch bottoms unless no other location is available due to crowded corridor conditions caused by other utilities.

Wastewater force mains shall be located outside of paved areas except at roadway crossings. Exceptions to this pavement rule may be considered within commercial development projects provided the mains do not lie under parking areas.

If new main extension is parallel with an existing main, the existing main and services shall be transferred to the new main. The existing main shall be properly abandoned after the new main is cleared for service.

5.7.5 Swabbing Launching Stations

When determined necessary by the design engineer, and in conjunction with the JEA Planning Team, swabbing launching stations will be required on force mains as per the details in the latest JEA Water and Wastewater Standards Manual, Plates S-54 and S-54A-D.

5.7.6 Force Main Separation Requirements

Force main separation (from structures and hardwood trees) shall be in accordance with Sections 350 and 429 of the JEA Water and Wastewater Standards Manual including JEA Standard Construction Details W-10, W-11, S-26 and S-27.

The table below provides the minimum horizontal separation requirements between the proposed utility and structures (see notes).

Pressure Main (Water & Wastewater) Nominal Size (inches) (See Note 1)	Horizontal Separation Requirements (Min)
up to 6-inches	10 feet
8-inches	14 feet
10-inches and 12-inches	18 feet
14-inches and larger	See Note 4
For gravity wastewater mains, see Note 2.	

NOTES:

1. The table above provides the minimum horizontal separation requirements between the proposed JEA maintained utilities (including water mains, reclaimed water mains, water service laterals, meter boxes and wastewater force mains) and existing, proposed and future structures (including above ground structures, concrete footers and top of bank of ponds).
2. For gravity wastewater mains, the horizontal separation from existing, proposed, and future structures (including above ground structures, concrete footers, and top of bank of ponds) shall be a minimum of 3 times the vertical depth of the deepest portion of the manhole-to-manhole wastewater run.
3. Pressure mains with pipe cover greater than 36-inches will required additional horizontal separation as reviewed and approved by JEA O&M Manager.
4. Pressure mains 14-inch and larger will require additional horizontal separation as reviewed and approved by JEA O&M Manager.
5. All depth measurements will be based upon final finished grade elevations, unless approved otherwise by JEA.

5.7.7 Valves

Wastewater valves and appurtenances shall conform to JEA Water and Wastewater Standards Manual, Section 430.

Valves shall be marked with a “V” scribed in the curb closest/adjacent to the below grade valves. The “V” cut shall be painted green.

Resilient seat gate valves shall be installed at a maximum of 1,000-foot intervals and at branches of intersecting force mains on tees and wyes, and at force main stubs.

A resilient seat gate valve shall be provided on the force main in the right-of-way adjacent to the discharge manhole. (See JEA Standard Construction Detail S-18).

Generally, resilient seat gate valves are preferred on wastewater force mains (main valves and tapping valves), but must be in the vertical position (stem in vertical position). If a gate valve must be in the horizontal position (stem horizontal), then a double disc gate valve must be utilized. Horizontal valves are to be utilized only in extreme cases and as approved by JEA. When gate valves are not practical, plug valves may be utilized. Plug valves 8-inches and larger must be equipped with worm-gear actuators.

Valves shall be located so as not to conflict with curb and gutter, not be located in the tire tracks and shall be located outside of pavement when possible.

For private pump stations with JEA dedicated off-site force mains, a JEA pump-out box is required per JEA Standard Construction Detail S-46. A 4-inch (minimum) gate valve is required at the right-of way-line, adjacent to the pump out box. The gate valve is not required on force main piping where the connection at the JEA main is located on the same side of the street as the pump-out box and consists of 15-feet or less within the City right-of-way area. This gate valve defines the “JEA Point of Service”. If no gate valve exists, the right-of-way line defines the “JEA Point of Service”.

Air release valve assemblies (2-inch) with manholes shall be provided at all force main high points and when change of elevation is 2-feet or greater. The design engineer shall size the air release valves. If an air release valve larger than 2-inch is required, multiple 2-inch assemblies shall be provided. Air release valves on force mains hung from bridges should be manual if accessible. Air release valves shall be constructed as per JEA Standard Construction Detail S-29. Combination valves (air release and vacuum valves) shall only be utilized if a major vacuum condition exists as specified by the design engineer.

5.7.8 Force Main Connections to Existing Force Mains

5.7.8.1 Taps

Unless approved otherwise by JEA, size-on-size taps are limited on PVC mains to 12-inch size and smaller. Size-on-size taps are acceptable on DIP (all sizes). For size-on-size taps, on 8-inch and larger mains, the actual tap hole shall be reduced by 1-inch.

5.7.8.2 To Existing Force Mains >12-inch diameter

Taps on existing JEA force mains larger than 12-inch diameter must be pre-approved by JEA. In these cases, some restrictions may apply. Approval is based on each individual development project. Developer shall request a pre-application meeting. JEA will perform a site visit to determine upstream and downstream mainline valve locations, and to verify the mainline can be isolated by operating the valves. If valves are unable to be located, are inoperable, or spacing is not a reasonable distance (depends on number of manifold stations, size of main, location, etc.), Developer may be required to provide an insert a-valve(s), as required by JEA, to make the connection.

5.8 Access Road

Long runs of force mains or gravity wastewater located in easements that cross wetlands, which shall be restored as wetlands, shall be encased in a steel casing. Those runs that include manholes located across wetlands shall be accessible. A stabilized access road, 12-foot wide with a minimum Limerock Bearing Ratio (LBR) of 40 shall be provided and indicated on the drawings for easements requiring multiple manholes. The access road should be designed to provide adequate drainage and to prevent erosion from storm runoff. A truck turnaround area should be provided at the end of all access roads.

Section 6.0

Pump Station Design Guidelines

6.0 JEA Dedicated Pump Stations

6.0.1 General

Design wastewater pump stations in accordance with applicable sections of the Department of Environmental Protection Rules and Regulations, Recommended Standards for Sewage Works (Ten State Standards), JEA Water and Wastewater Standards Manual, latest editions, and as specified herein.

See Section 433 of JEA Wastewater Pump Stations Standards Manual for specific design requirements.

Pump stations shall be designed specifically to pump domestic sewage containing solids and fibrous materials.

Pump stations shall be designed and located on the site to minimize the effects resulting from odor, noise, and lighting.

Pump stations shall be designed to pump, at a minimum, the anticipated peak hourly flow with one pump out of service.

The engineer must submit buoyancy calculations for the wet well to demonstrate design precludes flotation.

A master pump station shall be utilized if multiple pump stations are required for the proposed development.

Station piping shall be sized to meet 5-10 fps.

6.0.2 Site Plan

The pump station site is to be located outside of the street right-of-way (R/W) and/or private R/W (easement) on a parcel of property indicated on the record plat or dedicated to JEA by Warranty Deed. Prior to recording, the applicant must submit the plat and/or Warranty Deed to JEA Real Estate for review and signature. Upon JEA signature, the applicant shall then proceed with recording the document.

The pump station site plan shall conform to the latest JEA Pump Station Site Plan Detail Sheet, unless otherwise approved. See www.jea.com for detail sheets.

If lift station location is not adjacent to a paved ROW, paved driveway access up to the station parcel is required.

On-site elevations shall be indicated to establish that the concrete on-site is sloped between 1/8-inch per foot (minimum) and 1/2-inch per foot (maximum) to allow for drainage toward the public R/W. The site elevation shall be set at a minimum of 1-foot above the design high water level, or 100-year flood elevation of adjacent storm water areas, whichever is the higher elevation. The driveway shall be designed with a tee for turning around when, in the opinion of JEA, the station location and the roadway traffic conditions prohibit backing in and out of the site safely. The paved driveway should have a uniform elevation along the wet well and, if possible, shall slope at 1%-5% away from the station.

The trees and ground cover to be used at the site shall be identified on the site landscape plan and shall conform to the JEA Water and Wastewater Standards Manual. For sites within Duval County, landscape and irrigation design shall conform to the JEA Standard Pump Station Landscape Plan (see www.jea.com).

No catch basin shall be located within the pump station site.

6.0.3 Junction Manhole

Pump stations shall be equipped with a junction manhole with only one influent main to the wet well to facilitate bypass pumping. The junction manhole shall be 5-foot diameter (minimum).

The junction manhole shall be located on the same side of the driveway as the pump-out connection, and within 60-feet of the wet well as accessed from the entrance gate.

At a minimum, there should be 1-foot of separation for every 1-foot of wet well depth between the junction manhole and the wet well to avoid disturbing both structures if construction work on either is necessary in the future.

The junction manhole shall be located in the grass area and not located in the driveway or in the traffic lane of the street.

An approved JEA liner shall be installed on junction manhole.

6.0.4 Class One and Class Two Lift Stations

The wet well shall have a minimum inside diameter of 8-feet.

No wet well shall exceed 27-feet in depth unless pre-approved in writing by JEA. The wet well shall have only one influent main, 8-inch diameter minimum, known as “control elevation”.

The wet well’s operating water levels shall be arranged to insure pump operation without cavitation, and insure the gravity wastewater system is not surcharged.

The wet well’s storage volume shall be calculated assuming a 12-minute cycle time, without considering pump alternation, for the pump rate at design flow condition.

If JEA has approved an “initial/ultimate” station design, the storage volume must be sized for the ultimate pumps and flows. Minimum storage volume depth shall be 24-inches.

The storage height (distance between “Lead Pump On” and “Pumps Off” elevations) should be calculated and rounded up to the next highest increment divisible by 0.25-feet. If JEA has approved an “initial/ultimate” station design, the storage height should be designed for the ultimate pumps.

The Mercoird Operating Level (emergency high-level alarm) should be set at 0.5-feet above the invert elevation.

The operating levels for High Water Level, Lag Pump On, and Lead Pump On are established in 0.5-feet increments as follows:

High Water Level Alarm = Control Elevation – 0.5 feet

Lag Pump On = High Water Level Alarm – 0.5 feet

Lead Pump On = Lag Pump On – 0.5 feet

Both Pumps Off = Lead Pump On – Storage Height

The wet well bottom elevation should be set at a minimum of 3-feet below the “Pumps Off” elevation.

An approved JEA liner shall be installed on all wet well concrete surfaces exposed to sewage or wastewater gases, including the underside of the concrete top slab.

6.0.5 Wet Well-Class Three Lift Station

The wet well shall have a minimum inner diameter of 10-feet for 8-inch and smaller pump discharge size and 12-feet for greater than 10-inch pump discharge size, unless otherwise approved.

No wet well greater than 27-feet deep shall be allowed unless approved otherwise by JEA.

The wet well shall have only one influent main, set at the “control elevation.”

The wet well’s operating water levels shall be arranged to insure pump operation without cavitation, provide cycle times not less than the manufacturer’s recommendations, and insure the gravity wastewater system is not surcharged.

The wet well's storage volume should be calculated assuming a 12-minute cycle time, without considering pump alternation, for the pump rate at design flow condition. The storage volume is determined as shown below:

$$SV_1 = Q_1 \left[\frac{\text{Cycle Time}}{4} \right] = Q_1 (3 \text{ min})$$

$$SV_2 = (Q_2 - Q_1) \left[\frac{\text{Cycle Time}}{4} \right] = (Q_2 - Q_1)(3 \text{ min})$$

Where:

SV_1 = Volume between pumps off and lead pump on

SV_2 = Volume between lead pump on and #1 lag pump on

Q_1 = Flow of One Pump at design flow Condition

Q_2 = Flow of Two Pumps at design flow Condition

The "Storage Height 1" (distance between "Lead Pump On" and "Pumps Off" elevations) should be calculated by dividing the SV_1 by the wet well area and rounding up to the next highest increment divisible by 0.25-feet.

The "Storage Height 2" (distance between "Lead Pump On" and "#1 Lag Pump On" elevations) should be calculated by dividing the SV_2 by the wet well area and rounding up to the next highest increment divisible by 0.25-feet.

The Mercoird Operating Level (emergency high water level alarm) should be set at 0.5-feet above the influent invert elevation.

The operating levels are established in 0.5-foot increments as follows:

High Water Level Alarm = Control Elevation – 0.5-feet

#2 Lag Pump On = High Water Level Alarm – 0.5-feet

#1 Lag Pump On = #2 Lag Pump On -0.5-feet

Lead Pump On = #1 Lag Pump On – Storage Height 2

All Pumps Off = Lead Pump On – Storage Height 1

The wet well bottom elevation should be set at 3-feet below the "Pumps Off" elevation.

If two pumps are to be installed initially (third pump to be installed in the future), piping and valves for the third pump must still be installed complete through the base elbow.

An approved JEA liner shall be installed on all wet well concrete surfaces exposed to sewage or wastewater gases, including the underside of the concrete top slab.

6.0.6 Pumps

Pumps shall be in accordance with the latest version of the JEA Water and Wastewater Standards Manual and as listed in Wastewater Approved Materials (AS-603).

Pump curve should be downward sloping throughout the entire operating range.

Pump Head Rise to Shut-Off (HRSO) shall be a minimum of 15% greater than the pump design head for the “all pumps on” condition, such that a pump with a design point of 500-GPM at 85 FT TDH must provide a shut-off head greater than 100 FT TDH. Design head is the head at the operation point on the pump curve.

$$HRSO = \frac{\text{Shut-off Head} - \text{Design Head}}{\text{Shut-off Head}}$$

Pump Shut-off Head shall be less than 230 FT.

The pump impeller shall be a non-clog design, capable of passing a nominal 3-inch solid.

Screw impellers are not acceptable.

Pump motors shall be of sufficient horsepower to be non-overloading throughout the curve.

Pump motors shall be a minimum 3-Hp unless otherwise approved by JEA.

Pump motors shall be 3600-rpm or less, unless approved by JEA.

All JEA dedicated pump stations shall be rated at 80-gpm (minimum).

For Pony Pump Calculations Only:

Net Positive Suction Head (NPSH) shall be calculated at the “station only” condition flow rate and use the pump off elevation.

All motors shall be suitable for operation with a 3-phase electric supply. Any special exception for single-phase motors must be pre-approved through JEA.

Shutoff and check valves shall be provided on the discharge main of each pump. The check valve shall be between the shutoff valve and the pump’s discharge elbow. The check valve shall not be placed in the vertical position. Valves shall be accessible above ground. No valves shall be located inside the wet well.

Check valves shall be sized with adequate velocity to operate fully-open.

Header piping shall be sized for 5-10 ft/sec to allow the check valve to operate fully-open.

All pump stations shall be equipped with an easily accessible pump out connection assembly, on the driveway side, for use with portable pumps to allow bypass operation of the pump station.

Where JEA has approved the station to be designed as “initial/ultimate”, the pump’s base elbow should be sized for the ultimate pumps. The pump manufacturer shall provide an adapter plate for the initial pumps. The minimum pump base shall be 4-inch x 4-inch.

Pump access covers shall be suitably sized to provide adequate clearances for installation and removal of the pumping units.

The access hatch shall be designed for a minimum width of 42-inches, or 6-inches beyond the manufacturer’s minimum required width, whichever is greater.

The minimum hatch length should be:

- 48-inches for standard duplex stations;
- 96-inches for triplex stations or the sum of the pump width, centerline pump separation, and 12-inch, whichever is greater;
- If JEA has approved an “initial/ultimate” pump station design, the hatches shall be sized for the “ultimate” pump design.

6.0.7 Electrical Control Panel

The panel and all electrical components shall be in accordance with the latest version of the JEA Water and Wastewater Standards Manual, Section 433.

The enclosure shall be sized to enable all breakers and controls to be located not more than 5-feet above the walkway.

If JEA has approved the station to be designed as an “initial/ultimate” station, the pump breakers should be sized for the initial pumps, but a note should be added to the drawings stating: “Pump breakers shall be spaced to accommodate future pump breakers.”

The Main breaker size is determined by adding the pump breaker size, the full load amperage (FLA) of additional pump motors (beyond the one), and any auxiliary loads and rounding down to the nearest breaker size. If the total load for a 240-volt service is less than or equal to 200-Amps, 200-Amp emergency and main breakers should be used. If the total is greater than 200-Amps, the service size shall be the same as the main breaker size. Where JEA has approved an “initial/ultimate” station, the main breaker, as well as service size shall be designed for ultimate design conditions.

Starter type should be sized in accordance with JEA Water and Wastewater Standards Manual, Section 433.

If JEA has approved the station to be designed as an “initial/ultimate” station, the starters shall be sized for the ultimate pumps with a note added to the drawings stating: “Heater coil shall be sized to protect the initial pumps.”

6.0.8 Emergency Operations

6.0.8.1 Class One Pump Stations

For Class One pump stations with Low Flow up to 100 GPM for commercial or multi-family developments, emergency operation system is not required to be provided.

For Class One pump stations that meet the following criteria, the design will require an emergency operation system:

- Receive flow of 101 GPM or more;
- Receive flow from one or more pump stations through a force main (re-pump);
- Pump stations discharging through pipes 12-inches or larger.

The emergency operating system shall be in accordance with the latest Wastewater Pump Stations Standards Section 433, Selection of Pump Station Standards. JEA prefers an auxiliary diesel pump system as means for lift station emergency operation.

The developer shall be responsible for all costs associated with the installation of the emergency operating system. The generator system shall conform to the JEA Water and Wastewater Standards Manual, Section 472. The emergency pump engine shall conform to the JEA Water and Wastewater Standards Manual, Section 470.

Any development triggering the requirements for an emergency operation system on an existing JEA Lift Station downstream may be required to add in the emergency operation system as part of their development plans. Discuss this with the Development and Planning team.

6.0.8.2 Class Two, Three and Four Pump Stations

Shall be emergency powered as specified in the JEA Water and Wastewater Standards Manual.

6.0.9 Water Service

The pump station site shall include a 1.5-inch Commercial Irrigation meter to be utilized for the hose station. Where allowed, the water from this irrigation meter may be utilized for irrigation use. Associated fees shall be paid by the Developer/Owner.

Water service piping for the pump station site shall be 1.5-inch diameter (minimum) and shall meet material and installation standards for water service construction as detailed in JEA Water and Wastewater Standards Manual.

For other water service information, see Water and Wastewater Standards, Section 433, paragraph XVI.3.

6.1 Private Pump Stations

Private pump stations shall be permitted only for commercial developments on single parcels owned by a single owner. Commercial and residential developments containing multiple fee simple parcels must design and construct a JEA dedicated pump station per the design requirements outlined in section 6.0 of this document.

All private pump stations discharging to the collection or treatment systems owned by JEA must be designed in accordance with FDEP Regulations and EPB Rule 3 criteria (in Duval County).

Pump stations shall be designed specifically to pump domestic sewage containing solids and fibrous materials.

Pump stations shall be designed and located on the site to minimize the effects resulting from odor, noise, and lighting.

Pump stations shall have a minimum of two pumps, with each pump being of the same capacity.

Pump stations should be designed to pump the design peak hourly flow with one pump out of service.

Pump stations must be designed to withstand floatation when empty.

Pump stations shall be equipped with an audible and visible high water level alarm. A 24-hour emergency contact number shall be posted at the station.

Pump stations shall have a locked fence or other appropriate features (such as locking hasps for wet well, control panel, and valve box) to discourage unauthorized entry.

Control panel shall be equipped with lightning arrestors, surge capacitors, and phase protection.

For pump stations that receive flow from one or more pump station through a force main or pump stations discharging through pipes 12-inches or larger, the design requires uninterrupted pumping capability to be provided, including an in-place emergency generator.

Where portable pumping and/or generating equipment or manual transfer is used, the design includes sufficient storage capacity with an alarm system to allow time for

detection of pump station failure and transportation and connection of emergency equipment.

A shut-off and check valve shall be provided in the discharge main of each pump. The check valve shall be between the shut-off valve and the pump's discharge. The check valve shall not be placed in the vertical position. Valves shall be accessible either above ground or in a dry valve pit.

No valves shall be located inside the wet well.

A pump out at the station shall be required. A pump out is an appropriate coupling device and valving to the discharge pipe to allow for connection of portable pumps.

Private pump stations manifolded with force mains owned or to be owned by JEA shall require a JEA pump-out box consisting of the installation of a check valve, pump out tee, and shut-off valve in a valve pit located on the property adjacent to the right-of-way as per Detail No. S-46 of the JEA Water and Wastewater Standards Manual. This pump out shall be accessible to JEA at all times. Operation and Maintenance of this pump out shall be the private owner's responsibility.

The JEA pump-out box is not required if the private pump station is within 25-feet of the right of way. In the case where the JEA pump-out box is not required, a 4-inch minimum gate valve at the property line/right of way line shall be provided.

All pump out assemblies shall be accessible to JEA at all times.

A Single Family Home connection to a JEA force main are prohibited.

6.2 Low-Pressure Systems (LPS)

The Environmental Protection Agency defines a Pressure Sewer as an alternative wastewater collection system in which household wastewater is pretreated by a septic tank or grinder and pumped through small plastic sewer pipes buried at shallow depths to either a conventional gravity sewer or a treatment system. For the purposes of this document, Pressure Sewer Systems will be referred to as Low-Pressure Sewer Systems (LPS), and shall be for residential customers only. Calculations in support of the Low-Pressure Sewer System will be based on the Design and Specification Guidelines for Low Pressure Sewer Systems, FDEP, June 1981 and shall be constructed in accordance with the JEA Water and Sewer Standards Manual.

Low-pressure sewer systems are not allowed for new developments. Exceptions may be approved on a case-by-case basis by JEA's Alternative Connections Review Team (ACRT). For ACRT consideration, and plan approval, include with submittal an updated model, including pipe size and pump selections. **Low-Pressure Sewer Systems cannot be installed via horizontal directional drill.**

It is the policy of JEA to construct gravity wastewater collection systems to serve customers within the JEA's service territory. Low-Pressure Sewer Systems may only be allowed when the project meets any of the following criteria:

JEA Water, Wastewater, and Reclaimed Water Design Guidelines

- a. A gravity wastewater collection system, designed in accordance with JEA standards, will be placed at a depth greater than 12-feet with service laterals or at a depth greater than 15-feet without service laterals.
- b. Less than 80 customers will be served by the low-pressure system.
- c. The surrounding land is fully developed or cannot be developed due to environmental constraints and a gravity sewer system would not be economically feasible.
- d. An on-site sewage treatment system can be constructed but would not be in the best interest of JEA and/or the City of Jacksonville, Nassau County or St. Johns County.

A low-pressure pump station shall not be allowed to connect into a JEA force main per FDEP and EPB Rule No. 3. No exceptions will be allowed.

Upon approval of the LPS by the ACRT, the following steps will need to take place prior to sewer service being established:

1. A signed and witnessed “JEA ALTERNATIVE SEWER SYSTEMS (NON-GRAVITY) CUSTOMER OWNED, OPERATED AND MAINTAINED” agreement will need to be submitted to the JEA Development Manager by the customer or their representative, for approval and signature. **JEA will provide this document upon your request;**
2. The fully executed document will need to be recorded by the customer;
3. The customer will submit a copy of the recorded document to the JEA Development Manager prior to submitting an application to set up sewer service.

6.2.1 Low Pressure Design Requirements

Low pressure force main connections shall conform to EPB Rule 3 criteria (in Duval County) and FEDP regulations.

Low pressure force mains shall be sized to meet a minimum velocity of 2.0 ft/s at the peak hourly rate where practical and shall generally be sized as follows:

Pipe Diameter, in	No of Homes
2	0 – 6
3	7 – 60
4	61 – 120

Material selection shall be as follows:

- 2” and 3” – Schedule 80 PVC, solvent-weld joints, green or grey in color;

- 4" – as provided in JEA standards for force mains;
- Locate wire and green tracer tape shall be used;

Low pressure force main testing shall follow current JEA standards for force mains.

Valves and Air release valves shall be as provided in JEA standards for force mains.

No more than one single family residence will be allowed per grinder pump station.

Low pressure force main in-line cleanouts to be provided as follows:

- Located at terminal ends of mains;
- Located at pipe diameter size changes;
- Spaced every 1,000 feet on straight runs, located near inline valves;
- Located where two or more mains come together and feed into another main, located near valves;
- Located within the right-of-way and out of pavement where possible;
- Stainless steel fittings shall be used within the structure.

Stainless steel fittings, tees, valves and plugs shall be used for all pipes less than 4 inches. Schedule 80 PVC slip by thread unions or stab couplings with teeth may be used instead of stainless nipples on each side of the tee.

All homes being designed to connect to a low pressure force main will require an Low Pressure Sewer Individual Customer agreement prior to project acceptance or meter issuance, whichever is applicable. At your request, JEA will prepare this agreement and send it to you via email. You will need to sign and return a hard copy to our offices for JEA signature and recording. Once we receive your signed agreement we will process any new service application related to the property.

To submit a request for a Low Pressure Sewer Individual Customer Agreement:

- Log into www.sagesgov.com;
- From the home screen;
- Select "Low Pressure Sewer Individual Customer Agreement".