



engineers | scientists | innovators

2025 ANNUAL CCR LANDFILL INSPECTION REPORT

Byproduct Storage Area B St. Johns River Power Park

Prepared for

JEA/St. Johns River Power Park
11201 New Berlin Road
Jacksonville, FL 32226

Prepared by

Geosyntec Consultants, Inc.
4595 Broadmoor Ave SE
Grand Rapids, MI 49512

Project GLW8091A

January 15, 2026

2025 Annual CCR Landfill Inspection Report

Byproduct Storage Area B St. Johns River Power Park

Prepared for

JEA/St. Johns River Power Pak

Prepared by



Samuel F. Stafford, PE
Senior Engineer



Rachel A. Klinger, PE, BCEE
Senior Principal

Project Number: GLW8091A
January 15, 2026

TABLE OF CONTENTS

1. INTRODUCTION	1
2. AVAILABLE INFORMATION REVIEW (§257.84(B)(1)(I))	1
3. INSPECTION SUMMARY (§257.84(B)(1)(II))	1
4. CHANGES IN GEOMETRY (§257.84(B)(2)(I))	1
5. APPROXIMATE VOLUME OF CCR (§257.84(B)(2)(II)).....	1
6. STRUCTURAL WEAKNESS OR DISRUPTING CONDITIONS (§257.84(2)(III)).....	2
7. CHANGES AFFECTING STABILITY OR OPERATIONS (§257.84(2)(IV))	2
8. SUMMARY	2

1. INTRODUCTION

Geosyntec Consultants, Inc. (Geosyntec) conducted the annual coal combustion residual (CCR) landfill inspection of Byproduct Storage Area B (BSA-B) at the St. Johns River Power Park (SJRPP) on December 8, 2025. The inspections and this 2025 Annual CCR Landfill Inspection Report (Report) are intended to comply with the requirements of CCR Rule¹ requirements pursuant to §257.84.

2. AVAILABLE INFORMATION REVIEW - §257.84(b)(1)(i)

Pursuant to §257.84(b)(1), Geosyntec reviewed available information regarding the condition and status of BSA-B including operating records. The documents reviewed include:

- Closure Design Plan, May 2019;
- Closure Plan, February 2021;
- Post-Closure Care Plan, February 2021;
- Run-On and Run-Off Control System Plan, October 2021;
- Long Term Maintenance Plan, November 2024; and
- Operating Records: Routine Inspection Logs.

3. INSPECTION SUMMARY - §257.84(b)(1)(ii)

Samuel Stafford, PE (professional engineer licensed in Florida) of Geosyntec conducted a visual inspection of BSA-B on December 8, 2025. The inspection observed cover conditions, exterior slope conditions, vegetative conditions, stormwater management system conditions, placement of CCRs, slope stability and any other signs of distress or malfunction.

4. CHANGES IN GEOMETRY - §257.84(b)(2)(i)

Geosyntec reviewed recent aerial photography and inspection records for changes in geometry of BSA-B. There are no significant changes in geometry since the last inspection of BSA-B. Closure construction was completed prior to the last inspection.

5. APPROXIMATE VOLUME OF CCR - §257.84(b)(2)(ii)

The volume of materials in BSA-B is estimated at approximately 1.8 million cubic yards based on the closure plans.

¹ 40 Code of Federal Regulations 257, Subpart D – Standards for Disposal of Coal Combustion Residuals in Landfill and Surface Impoundments

6. STRUCTURAL WEAKNESS OR DISRUPTING CONDITIONS - §257.84(2)(iii)

No indications of actual or potential structural weakness were noted during the 2025 annual inspection or during the review of available information.

7. CHANGES AFFECTING STABILITY OR OPERATIONS - §257.84(2)(iv)

No changes from the previous inspection conducted on December 16, 2024 were observed that may affect the stability or operation of BSA-B. Operations have ceased, closure construction is complete, and the facility is in post-closure care.

8. SUMMARY

Based on our review of available information noted above and our December 8, 2025, the inspection, the design, operation, and maintenance of BSA-B appear to be consistent with recognized and generally accepted good engineering standards.

