

January 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

15882 Canoe Creek Dr

Jacksonville, FL 32218

1/10/2026 @ 9:15 PM

Estimated gallons released: 200

Action Taken: Washed down and vacuumed impact area. Sampling began 1/11/2026.

Preliminary Cause: Grease

7300 Buffalo Ave

Jacksonville, FL 32208

1/12/2026 @ 8:30 AM

Estimated gallons released: 20500

Action Taken: Pipe replaced. Recovered sewer. Washed down impacted areas. No sampling due to inaccessibility to the river.

Preliminary Cause: Pipe Failure

10690 Beach Blvd

Jacksonville, FL 32246

1/13/2026 @ 8:40 PM

Estimated gallons released: 7000

Action Taken: Pipe replaced. Recovered sewer. Washed down impacted areas. No waterways impacted.

Preliminary Cause: Pipe Failure

6801 Blanding Blvd

Jacksonville, FL 32244

1/15/2026 @ 12:00 PM

Estimated gallons released: 12000

Action Taken: Storm swale and road were vacuumed up. Road was washed down and swale had hydrated lime applied.

Preliminary Cause: Other

3180 Philips Hwy

Jacksonville, FL 32207

1/21/2026 @ 11:22 AM

Estimated gallons released: 600

Action Taken: Removed blockage. Washed down impacted area. Recovered sewer. Spread hydrated lime. Sampling begins 1/22/26.

Preliminary Cause: Blockage

5802 Harris Ave

Jacksonville, FL 32211

1/31/26 @ 10:52 PM

Estimated gallons released: 160000

Action Taken: Road way and plant vacuumed up and washed down, once the temperatures no longer caused equipment to freeze up.

Preliminary Cause: Equipment Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

6671 Epping Forest Way N

Jacksonville, FL 32217

1/4/2026 @ 6:13 PM

Estimated gallons released: 100

Action Taken: Washed down and vacuumed impact area.

Preliminary Cause: Grease

4506 San Juan Ave

Jacksonville, FL 32210

1/15/2026 @ 6:00 PM

Estimated gallons released: 300

Action Taken: Catch basin and storm swale vacuumed out and lime applied to affected ground.

Preliminary Cause: Equipment Failure

4506 San Juan Ave

Jacksonville, FL 32210

1/17/2026 @ 10:30 AM

Estimated gallons released: 400

Action Taken: Replaced pipe. Recovered sewer out of swale and catch basin. Washed down area.

Preliminary Cause: Pipe Failure

5802 Harris Ave

Jacksonville, FL 32211

1/20/26 @ 11:25 AM

Estimated gallons released: 100

Action Taken: Vac trucks sprayed down the area and recovered from ditch

Preliminary Cause: Contractor Error

757 Eagle Point Dr

Jacksonville, FL 32092

1/23/26 @ 5:42 PM

Estimated gallons released: 800

Action Taken: Vacuumed and washed down impacted roadway.

Preliminary Cause: Blockage

65 Sentosa Dr

St. Johns, FL 32259

1/27/26 @ 4:00 PM

Estimated gallons released: 200

Action Taken: Road washed down and vacuumed up, and storm drains vacuumed out.

Preliminary Cause: Equipment Failure

450 Arlington Rd N

Jacksonville, FL 3211

1/27/26 @ 6:00 PM

Estimated gallons released: 50

Action Taken:

Preliminary Cause:

7099 Collins Rd

Jacksonville, FL 32244

1/29/26 @ 11:00 PM

Estimated gallons released: 100

Action Taken: Road washed down after repairs were made.

Preliminary Cause: Equipment Failure

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

4905 San Pablo Rd South

Jacksonville, FL 32224

1/5/2026 @ 10:47 AM

Estimated gallons released: 30

Action Taken: Road washed down and all wash water recovered.

Preliminary Cause: Pipe Failure

10304 Briarcliff Rd E

Jacksonville, FL 32218

1/24/26 @ 12:41 PM

Estimated gallons released: 10

Action Taken: NA

Preliminary Cause: Grease

Preliminary Cause: Blockage

Other Events Reported To The State Watch Office

None

February 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

11180 Vera Dr
Jacksonville, FL 32218
2/2/2026 @ 9:20 AM
Estimated gallons released: 200
Action Taken: Washed down and vacuumed impact area. Sampling began 2/3/2026.
Preliminary Cause: Grease

1250 Imeson Park Blvd
Jacksonville, FL 32218
2/6/2026 @ 11:55 AM
Estimated gallons released: 2000
Action Taken: Washed down and vacuumed impact area. Sampling began 2/7/2026.
Preliminary Cause: Broken

96237 Amelia Concourse
Yulee, FL 32097
2/7/2026 @ 7:00 PM
Estimated gallons released: 2000
Action Taken: Washed down and vacuumed impact area. Sampling began 2/11/2026
Preliminary Cause: Pipe Failure

5535 Moret Dr E
Jacksonville, FL 32244
2/11/2026 @ 4:00 PM
Estimated gallons released: 1100
Action Taken: Pipe replaced. Sewer recovered from stormwater channel. Sampling begins 2/12/2026.
Preliminary Cause: Broken

13208 Moby Dick Dr W
Jacksonville, FL 32218
2/12/2026 @ 8:30 PM
Estimated gallons released: 71000
Action Taken: Pipe replaced. Sewer recovered in creek. Sampling began 2/13/2026.
Preliminary Cause: Broken

6927 Hanson Dr N
Jacksonville, FL 32210
2/13/2026 @ 12:19 PM
Estimated gallons released: 10100
Action Taken: Blockage removed. Sewer recovered in woods. Spread lime. Impacted areas

washed down. Sampling begins 2/14/26.
Preliminary Cause: Blockage

10383 Scott Mill Rd
Jacksonville, FL 32257
2/13/2026 @ 1:00 PM
Estimated gallons released: 600
Action Taken: Blockage removed. Unable to recover sewer due to location. Spread lime.
Sampling begins 2/14/26.
Preliminary Cause: Blockage

1721 University Blvd N
Jacksonville, FL 32211
2/15/2026 @ 3:36 PM
Estimated gallons released: 4000
Action Taken: Pipe replaced. Sewer recovered in pit. Area washed down. Sampling begins 2/16/26.
Preliminary Cause: Broken

1646 W 45th St
Jacksonville, FL 32208
2/26/2026 @ 11:51 AM
Estimated gallons released: 800
Action Taken: Removed dirt from impact area. Sampling began 2/27/2026.
Preliminary Cause: Grease

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

4334 E Castlewood Dr
Jacksonville, FL 32206
2/3/2026 @ 4:31 PM
Estimated gallons released: 50
Action Taken: Washed down and vacuumed impact area.
Preliminary Cause: Grease

2004 Figaro Ln
Jacksonville, FL 32210
2/3/2026 @ 9:30 PM
Estimated gallons released: 100
Action Taken: Washed down and vacuumed impact area.
Preliminary Cause: Grease

646 E 31st St
Jacksonville, FL 32206
2/4/2026 @ 3:36 PM
Estimated gallons released: 100

Action Taken: Washed down and vacuumed impact area.
Preliminary Cause: Grease

6008 Jammes Rd
Jacksonville, FL 32244
2/12/2026 @ 10:25 AM
Estimated gallons released: 50
Action Taken: Turned off ARV. ARV replaced. Sewer recovered.
Preliminary Cause: Failed ARV

1555 Millcoe Rd
Jacksonville, FL 32225
2/12/2026 @ 10:27 AM
Estimated gallons released: 900
Action taken: Sewer recovered. Pipe replaced.
Preliminary Cause: Equipment Failure

103 Trout River Dr
Jacksonville, FL 32208
2/12/2026 @ 1:19 PM
Estimated gallons released: 300
Action Taken: Sewer recovered. Pumps refueled and replaced.
Preliminary Cause: Third Party

1292 Peacefield Dr
Jacksonville, FL 32205
2/17/2026 @ 2:24 PM
Estimated gallons released: 50
Action Taken: Line jetted to clear blockage. Area washed down with disinfectant.
Preliminary Cause: Blockage

8507 Belfort Lndg Dr
Jacksonville, FL 32216
2/25/2026 @ 10:42 AM
Estimated gallons released: 50
Action Taken: Full recovery was made. Street was washed down and recovered.
Preliminary Cause: Blockage

850 Aries Rd W
Jacksonville, FL 32216
2/27/2026 @ 9:17 AM
Estimated gallons released: 50
Action Taken: Washed down and vacuumed impact area. Sampling began 2/28/2026.
Preliminary Cause: Blockage

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

2434 N Pearl St
Jacksonville, FL 32206
2/2/26 @12:40 PM
Estimated gallons released: 50
Action Taken: Wash and recover.
Preliminary Cause: Other

8819 Brier Way N
Jacksonville, FL 32221
2/10/2026 @ 12:46 PM
Estimated gallons released: 10
Action Taken: Blockage removed. Sewer recovered. Area washed down.
Preliminary Cause: Blockage

8885 Scott Woods Dr E
Jacksonville, FL 32208
2/10/2026 @ 4:14 PM
Estimated gallons released: 10
Action Taken: Blockage removed. Sewer recovered. Area washed down.
Preliminary Cause: Blockage

7612 Plumwood Dr
Jacksonville, FL 32256
2/22/2026 @ 5:05 PM
Estimated gallons released: 20
Action Taken: Cleared blockage.
Preliminary Cause: Blockage

Other Events Reported To The State Watch Office

536 Saddlestone Dr
Jacksonville, FL 32259
2/24/2026 @ 10:00 PM
Estimated gallons released: 5000
Action Taken: Throttled main down and replaced saddle then tied back into long side poly.
Preliminary Cause: Broken

8752 Bayleaf Rd
Jacksonville, FL 32256
2/28/2026 @ 7:00 AM
Estimated gallons released: 50
Action Taken: Contractor coordinated cleanup efforts.
Preliminary Cause: Contractor Error

March 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

9119 Tamworth Rd
Jacksonville, FL 32208
3/14/2026 @ 2:36 PM
Estimated Gallons Released: 1500
Action Taken: Road cleaned, full recovery no waters impacted
Preliminary Cause: Grease

1102 Mc Conihe St
Jacksonville, FL 32209
3/25/26 @ 2:00 PM
Estimated Gallons Released: 5000
Action Taken: Impacted areas washed down. Sewer recovered from storm drains and in system.
No waterways impacted.
Preliminary Cause: Third Party

I-95 and CR 108
Yulee, FL 32097
3/31/26 @ 10:40 AM
Estimated Gallons Released: 18700
Action Taken: Sewer recovered from impacted land. No waterways impacted.
Preliminary Cause: Third Party

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

9540 San Jose Blvd
Jacksonville, FL 32257
3/11/2026 9:46 AM
Estimated Gallons Released: 100
Action Taken: Closed valve. Washed down road and recovered. No waterways impacted.
Preliminary Cause: Failed ARV

11525 Village Crossing Dr
Jacksonville, FL 32256
3/18/2026 10:42 AM
Estimated Gallons Released: 400
Action Taken: Washed down road and recovered. No waterways impacted.
Preliminary Cause: Debris

12426 W Beaver St
Jacksonville, FL 32209
3/20/2026 8:45 AM
Estimated Gallons Released: 200
Action Taken: Washed down impacted area
Preliminary Cause: Grease

3780 University Club Blvd
Jacksonville, FL 32277
3/20/2026 10:00 AM
Estimated Gallons Released: 500
Action Taken: Washed down impacted area
Preliminary Cause: Broken

796 Sailor Grove Ln
Jacksonville, FL 32221
3/31/2026 7:55 AM
Estimated Gallons Released: 100
Action Taken: Washed down road and recovered. No waterways impacted.
Preliminary Cause: Debris

796 Sailor Grove Ln
Jacksonville, FL 32221
3/31/2026 7:55 AM
Estimated Gallons Released: 100
Action Taken: Washed down road and recovered. No waterways impacted.
Preliminary Cause: Debris

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

None

Other Events Reported To The State Watch Office

1840 Cedar Bay Rd
Jacksonville, FL 32218
3/3/2026 @ 9:45 AM
Estimated gallons released: 3700
Action Taken: Bypass was opened back up to stop spill. Recovered partially treated sewer in plant. Washed down impacted areas. Spread lime.
Preliminary Cause: Equipment Failure

April 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

6405 Cooper Ln
Jacksonville, FL 32210
4/8/2026 @ 3:30 PM
Estimated gallons spilled: 300
Action Taken: Blockage removed. Sampling began 4/9/2026.
Preliminary Cause: Blockage

118th St and Faulkner Dr
Jacksonville, FL 32244
4/8/2026 @ 7:00 PM
Estimated gallons spilled: 200
Action Taken: Blockage removed. Washed down road. Recovered sewer. Sampling began 4/9/2026.
Preliminary Cause: Blockage

3945 San Jose Park Dr
Jacksonville, FL 32217
4/10/2026 @ 2:00 PM
Estimated gallons spilled: 3000
Action Taken: Pipe replaced. Recovered sewer in pit and storm drain. No waterways impacted.
Preliminary Cause: Third Party

7070 Salamanca Ave
Jacksonville, FL 32217
4/14/2026 @ 12:00 PM
Estimated gallons spilled: 610
Action Taken: Pipe replaced. Recovered sewer from drainage ditch and flushed. Sampling began 4/14
Preliminary Cause: Pipe Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

4009 Corrientes Ct E
Jacksonville, FL 32217
4/2/2026 @ 9:51 AM
Estimated gallons spilled: 100
Action Taken: Washed down road and recovered. No waterways impacted.
Preliminary Cause: Blockage

5632 Falcon St W
Jacksonville, FL 32244
4/9/2026 @ 2:20 PM
Estimated gallons spilled: 50
Action Taken: Blockage removed. Recovered sewer. Washed down road. Spread lime. No waterways impacted.
Preliminary Cause: Blockage

710 Haines St
Jacksonville, FL 32202
4/23/2026 @ 12:19 PM
Estimated gallons spilled: 250
Action Taken: Blockage removed. Washed down impacted areas. Recovered sewer from storm drain. No waterways impacted.
Preliminary Cause: Blockage

211 S Arlington Rd
Jacksonville, FL 32216
4/23/26 @ 4:30 PM
Estimated gallons spilled: 200
Action Taken: Recovered sewer.
Preliminary Cause: Third Party

11078 Skylark Dr
Jacksonville FL 32257
Event Date: 4/28/2026 @ 12:00 PM
Estimated gallons spilled: 150
Action Taken: Washed down and made full recovery. No waterways impacted
Preliminary Cause: Valve

6983 103rd St
Jacksonville FL 32210
Event Date: 4/28/2026 @ 4:01 PM
Estimated gallons spilled: 100
Action Taken: Washed down and recovered. No waterways impacted
Preliminary Cause: Pipe Failure

1499 Zoo Pkwy
Jacksonville FL 32218
Event Date: 4/30/2026 @ 7:16 AM
Estimated gallons spilled: 100
Action Taken: Blockage cleared. No waterways impacted.
Preliminary Cause: ARV

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment.

Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

7434 Everett Frst Dr
Jacksonville, FL 32219
Event Date: 4/16/26 @ 11:00 AM
Estimated gallons spilled: 10
Action Taken: Washed down road and recovered.
Preliminary Cause: Blockage

1615 Chateau Dr
Jacksonville, FL 32221
Event Date: 4/28/26 @ 4:10 PM
Estimated gallons spilled: 10
Action Taken: Rinsed down and recovered
Preliminary Cause: Blockage

May 2026

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

4733 Mandarin Station Dr N
Jacksonville, FL 32257
5/1/2026 @ 9:00 AM
Estimated gallons spilled: 1000
Action Taken: Rinsed down and recovered. Sampling began 5/2/2026.
Preliminary Cause: Pipe Failure

3742 Southside Blvd
Jacksonville, FL 32216
5/18/2026 @ 5:00 AM
Estimated gallons spilled: 1000
Action Taken: Rinsed down and recovered. No surface water impacted
Preliminary Cause: Failed ARV

9955 Merlin Dr E
Jacksonville, FL 32257
5/19/2026 @ 6:20 PM
Estimated gallons spilled: 69900
Action Taken: Pipe repaired. Recovered sewer out of pit and storm drains. Spread hydrated lime.
Washed down impacted areas. Sampling begins 5/21/2026.
Preliminary Cause: Broken

6370 Sauterne Dr
Jacksonville FL 32210

5/28/2026 1:28:00 PM

Estimated gallons spilled: 300

Action Taken: Rinse down curb and sidewalk and recover from cleanup. Sampling begins

5/29/2026

Preliminary Cause: Broken

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

7019 San Fernando Pl

Jacksonville FL 32217

Event Date: 5/1/2026 @ 11:38 AM

Estimated gallons spilled: 100

Action Taken: Full Recovery

Preliminary Cause: Pipe Failure

661 Riverside Ave

Jacksonville, FL 32202

Event Date: 5/5/2026 @ 11:40 AM

Estimated gallons spilled: 100

Action Taken: Recovered sewer. Washed down impacted area.

Preliminary Cause: Blockage

5420 Tellaro Ln

Jacksonville, FL 32210

Event Date: 5/7/2026 @ 10:09 PM

Action Taken: Pipe replaced. Washed down curb. Recovered sewer.

Preliminary Cause: Third Party

96237 Amelia Concourse

Yulee, FL 32097

Event Date: 5/11/2026 @ 8:00 AM

Action Taken: Turned off ARV.

Preliminary Cause: Failed ARV

576 Hawthorn Park Cir

Yulee, FL 32097

Event Date: 5/25/2026 @ 4:47 PM

Estimated gallons spilled: 300

Action Taken: Recovered sewer. Washed down impacted area.

Preliminary Cause: Third party

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor

events do not require external reporting however, they will also be listed to provide transparency of all releases.

N Julia St and Church St

Jacksonville, FL 32202

Event Date: 5/7/2026 @ 11:35 AM

Estimated gallons spilled: 10

Action Taken: Blockage removed. Washed down impacted area and recover sewer.

Preliminary Cause: Blockage

Other Events Reported To The State Watch Office

None