



# POST-CLOSURE CARE PLAN

## POST-CLOSURE CARE PLAN

St. Johns River Power Park  
Byproduct Storage Area B  
Phase I Development

**Submitted to:** St. Johns River Power Park  
11201 New Berlin Road  
Jacksonville, FL 32226 USA

**Submitted by:** Golder Associates Inc.  
9428 Baymeadows Road, Suite 400  
Jacksonville, FL 32256 USA

October 2016

A world of  
capabilities  
delivered locally


15-26356






### PROFESSIONAL ENGINEER CERTIFICATION

I, Samuel F. Stafford, being a registered Professional Engineer in the state of Florida, do hereby certify to the best of my knowledge, information, and belief, that the information contained in this Post-Closure Care Plan dated October 11, 2016 was conducted in accordance with the requirements of 40 CFR §257.104, is true and correct, and had been prepared in accordance with recognized and generally accepted good engineering practices.

  
 No. 78648  
 Samuel F. Stafford, PE  
 Florida Professional Engineer No. 78648  
 Certificate of Authorization No. 11012  
 Date 11/01/2016





## Table of Contents

PROFESSIONAL ENGINEER CERTIFICATION..... PE-1

1.0 INTRODUCTION..... 1

2.0 POST CLOSURE CARE PLAN ..... 1

    2.1 Facility Contact Information..... 1

    2.2 Monitoring and Maintenance Activities ..... 1

    2.3 Groundwater Monitoring..... 1

3.0 POST-CLOSURE PROPERTY USE ..... 2

4.0 POST-CLOSURE CARE COMPLETION..... 2

5.0 CLOSING ..... 2

### List of Appendices

Appendix A Facility Contact Information



## 1.0 INTRODUCTION

This Post-Closure Care Plan was prepared for the Phase I development Byproduct Storage Area B (Area B Phase I) at the St. Johns River Power Park (SJRPP). This plan was prepared in accordance with Title 40, Part 257, Subpart D of the Federal Regulations. Specifically, this plan was prepared to meet the requirements for a written post-closure care plan as required by §257.104(d) for post-closure care of coal combustion residual (CCR) landfills. The information contained in this plan will be used to assist SJRPP in the active maintenance and monitoring required during the post-closure care period.

## 2.0 POST CLOSURE CARE PLAN

### 2.1 Facility Contact Information

The name, address, telephone number, and email address of the person or office to contact during post-closure period in accordance with §257.104(d)(ii) is included in Appendix A.

### 2.2 Monitoring and Maintenance Activities

In accordance with §257.104(b), monitoring and maintenance activities will be performed to maintain the integrity of the final cover system. During the post-closure care period of the site, the final cover system of Area B Phase I will be inspected at least annually. The following components will be monitored:

- Final cover system for signs of erosion, evidence of subsidence, signs of ponding water, and overall general condition;
- Surface water management system for signs of sedimentation, erosion, positive drainage, excessive vegetation, blockages, and overall general condition;
- Condition of vegetative growth for distressed vegetation, excessive vegetation, unwanted vegetation (woody growth); and
- Condition of groundwater monitoring wells.

Post-closure monitoring will be documented and include the date, components and item monitored, name of individual performing the monitoring, a description of deficiencies observed (if any), and maintenance/repairs performed including completion date (if any). Completed post-closure monitoring forms will be placed in the facility operating record.

### 2.3 Groundwater Monitoring

Groundwater monitoring activities will continue through the 30-year post-closure care period in accordance with §257.90 through §257.95. If at the end of the 30-year post-closure care period, Area B Phase I is in assessment monitoring (or corrective action), post-closure care of the unit will continue until the site can revert to detection monitoring under §257.95.

Maintenance of the groundwater monitoring system will be performed on an as-needed basis. The monitoring wells will be inspected during each sampling event for siltation within the well, damage to



protective casing, lock condition, concrete pad condition, dedicated pump operation, and dedicated tubing conditions. Necessary maintenance will be performed prior to or during the next scheduled sampling event depending on the repairs/maintenance required.

### 3.0 POST-CLOSURE PROPERTY USE

No post-closure use of Area B Phase I is proposed at this time. SJRPP will maintain control of and limit access to the facility. If the post-closure planned use is changed, the post-closure plan will be revised and any necessary demonstrations will be prepared in accordance with §257.104(d)(1)(iii).

### 4.0 POST-CLOSURE CARE COMPLETION

Within 60 days following the completion of the post-closure care period, a notification verifying that post-closure care has been completed will be prepared in accordance with §257.104(e). This notification will be certified by a qualified professional engineer licensed in Florida and will be placed in the facility's operating record.

### 5.0 CLOSING

This Post-Closure Care Plan has been prepared for Area B Phase I to describe the post-closure monitoring and maintenance activities, provide contact information, and describe the intended post-closure property use.

#### GOLDER ASSOCIATES INC.

Samuel F. Stafford, PE  
Senior Project Engineer

Gregory M. Powell, PhD, PE  
Practice Leader and Principal

SFS/GMP/ams

FN: G:\Projects\15-15-26356\Task 0700 Closure Plan\Final\SJRPP CCR Post-Closure Plan.docx

**APPENDIX A**  
**FACILITY CONTACT INFORMATION**

## **FACILITY CONTACT INFORMATION**

St. Johns River Power Park  
11201 New Berlin Road  
Jacksonville, FL 32226

Facility Contact: James Peacock  
Telephone: (904) 665-7528  
Email: [PeacJT@jea.com](mailto:PeacJT@jea.com)