

## January 2022

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)  
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

3996 Arbor Mill Cir  
Orange Park, FL 32065  
Clay County  
Sunday, January 2, 2022 @ 12:00 AM  
Estimated gallons spilled: 3000  
Action Taken: Vacuum up sewer/wash down water from impacted area and storm drain, apply hydrated lime.  
Preliminary Cause: Equipment Failure

7834 Holiday Rd S  
Jacksonville, FL 32216  
Duval County  
Sunday, January 16, 2022 @ 1:45 PM  
Estimated gallons spilled: 90,000  
Action Taken: Area was washed down and impact site flushed. Unable to recover due to landscape. Impacted area of lift station was applied with hydrated lime.  
Preliminary Cause: Equipment Failure

13340 Collen Rd.  
Jacksonville, FL 32218  
Duval County  
Friday, January 21, 2022 @ 3:30 PM  
Estimated gallons spilled: 300  
Actions Taken: Area was washed down, and wash water recovered. Impacted land had hydrated lime applied. 3000 gal of water was removed from impact area of waterway.

220 Davis Pond Blvd  
Fruit Cove, FL 32259  
St. Johns County  
Monday, January 24, 2022 @ 9:21 AM  
Estimated gallons spilled: 1400  
Action Taken: The sand filters are currently on bypass, the plant is in reject and we have two new air compressors onsite to be installed  
Preliminary Cause: Other

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)  
All releases between 50-999 gallons are reported to local agencies.

1338 Lake Shore Blvd  
Jacksonville, FL 32205  
Duval County

Estimated gallons released: 200

Action Taken: Blockage was removed, sewer stayed below culvert and was not escaping. Vac truck set up and washed all sewer water from storm water conveyance area to vac truck for full recovery. large section of pipe was replaced to stop leak.

Preliminary Cause: Other

2221 Buckman St

Jacksonville, FL 32206

Duval County

Friday, January 28, 2022 @ 1:40 PM

Estimated release amount: 50 gallons

Action Taken: Vacuum truck recovered sewer/sludge from ground. Washed down area.

Preliminary Cause: Equipment Failure

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

178 Bedstone Dr 1/4/22 @ 10:07 AM - 10 gallons

7825 Porch Swing Ln 1/10/22 @ 8:40 AM - 15 gallons

2637 Myra St 1/17/2022 @ 4:00 PM – 25 gallons

14190 Beach Blvd 1/28/2022 @ 4:41 PM – 30 gallons

#### Other Events Reported To The State Watch Office

220 Davis Pond Blvd

Fruit Cove, FL 32259

St. Johns County

Monday, January 24, 2022 @ 9:21 AM

Estimated gallons spilled: 1400

Action Taken: The sand filters are currently on bypass, the plant is in reject and we have two new air compressors onsite to be installed

Preliminary Cause: Other

#### February 2022

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

3416 Debussy Rd

Jacksonville, FL 32277

Duval County

Sunday, February 13, 2022 @ 9:00 AM

Estimated release amount: 200 gallons

Action Taken: Hydrated lime was applied to impacted land.

Preliminary Cause: Blockage

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

7245 Blanding Blvd

Jacksonville, FL 32244

Duval County

Wednesday, February 2, 2022 @ 4:40 PM

Estimated release amount: 200 gallons

Action Taken: Wash down and vacuum up wash down water and sewer from impacted area.

Preliminary Cause: Other

13325 Egrets Marsh Drive

Jacksonville, FL 32224

Duval County

Friday, February 4, 2022 @ 5:09 PM

Estimated release amount: 75 gallons

Action Taken: Wash down and vacuum up sewer/wash down water

Preliminary Cause: Grease

760 Riverside Ave

Jacksonville, FL 32204

Duval County

Thursday, February 24, 2022 @ 10:37 AM

Estimated release amount: 100 gallons

Action Taken: Sewer from manhole was vacuumed out to stop overflow. Source of stoppage is undetermined. Road was washed down and sewer recovered from storm drain.

Preliminary Cause: Blockage

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

30 Ramona St 2/1/2022 10:55 AM - 15 gallons

1600 Jesse St 2/3/2022 1:29 PM - 25 gallons

6527 Alvin Rd 2/18/2022 10:00 AM - 2 gallons

#### Other Events Reported To The State Watch Office

None

#### March 2022

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

I-95 and Kenmore St  
Jacksonville, FL 32208  
Duval County  
Tuesday, March 1, 2022 @ 2:00 PM  
Estimated gallons spilled: 10000  
Action Taken: Blockage was removed, overflow was stopped. Ditch line was washed down and all wash water recovered. Sewer was also recovered further down ditch line before creek.  
Sampling to begin 3/2/2022.  
Preliminary Cause: Other

5747 Atlantic Blvd  
Jacksonville, FL 32207  
Duval County  
Thursday, March 17, 2022 @ 10:30 PM  
Estimated gallons spilled: 300  
Action Taken: Unable to recover sewer, wash down impacted area  
Preliminary Cause: Equipment Failure

6733 London Bridge Ln  
Jacksonville, FL 32210  
Duval County  
Saturday, March 26, 2022 @ 1:45 PM  
Estimated gallons spilled: 1600  
Action Taken: JEA is going to replace bypass pump with another to prevent another overflow. JEA vacuum trucks recovered loads off of the storm drain. Sampling of Fishing Creek will begin on 3/27/2022.  
Preliminary Cause: Equipment Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

5900 Southpoint Parkway  
Jacksonville, FL 32216  
Duval County  
Saturday, March 5, 2022 @ 12:53 PM  
Estimated release amount: 50 gallons  
Action Taken: Ball valve was replaced, affected area was washed down. All sewer/wash water recovered. No impacts to storm drains or water bodies.  
Preliminary Cause: Equipment Failure

8013 Voltaire Ct W  
Jacksonville, FL 32277  
Duval County  
Saturday, March 5, 2022 @ 6:33 PM

Estimated release amount: 50 gallons  
Action Taken: Blockage was cleared and affected area was washed down. All wash water recovered. Sampling of lake to begin 3/6/22.  
Preliminary Cause: Blockage

7710 Holiday Rd S  
Jacksonville, FL 32216  
Duval County  
Tuesday, March 8, 2022 @ 10:32 AM  
Estimated release amount: 200 gallons  
Action Taken: Blockage was removed, overflow stopped. Sewer was recovered from backyard, hydrated lime placed on affected area.  
Preliminary Cause: Blockage

Astral St and Cassat Ave  
Jacksonville, FL 32205  
Duval County  
Saturday, March 12, 2022 @ 10:09 AM  
Estimated release amount: 500 gallons  
Action Taken: Washed down and vacuumed impacted area.  
Preliminary Cause: System overload due to heavy rains.

2332 Riverside Ave  
Jacksonville, FL 32204  
Duval County  
Tuesday, March 22, 2022 @ 11:17 AM  
Estimated release amount: 50 gallons  
Action Taken: All sewer was recovered from roadway and washed down.  
Preliminary Cause: Blockage

14992 Bartram Creek Blvd  
St. Johns, FL 32259  
St. Johns County  
Sunday, March 27, 2022 @ 1:17 PM  
Estimated release amount: 100 gallons  
Action Taken: JEA crew turned valve on air release valve to stop overflow. Sewer from grass was recovered, road washed down and recovered. Lime was placed on affected area on 3/28/2022.  
Preliminary Cause: Other

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

12936 Palmetto Bluff Dr 3/7/2022 3:35 PM - 10 gallons  
128 Lighthouse Rd W 3/7/2022 10:27 PM - 5 gallons  
10914 Falkland Rd 3/9/2022 8:41 AM - 3 gallons

431 West 21st St 3/14/2022 4:00 PM - 10 gallons  
6625 Diane Rd 3/18/2022 9:42 PM - 25 gallons  
8012 Lenox Ave 3/19/2022 2:00 PM - 25 gallons

#### Other Events Reported To The State Watch Office

None

#### **April 2022**

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)  
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

Alta Dr & Alta Lakes Blvd  
Jacksonville, FL 32226  
Duval County  
Tuesday, April 5, 2022 @ 12:00 AM  
Estimated gallons spilled: 5000  
Action Taken: Forcemain was valved off to replace the broken brass valve with a steel valve.  
Vaccon recovered standing sewer on site.  
Preliminary Cause: Contractor Error

3800 St. Johns Bluff Rd S  
Jacksonville, FL 32224  
Duval County  
Thursday, April 7, 2022 @ 12:00 AM  
Estimated gallons spilled: 13475  
Action Taken: Vac truck crews recovered sewer from manhole and maintained level for employees to turn valve to stop flow to the air release valve. Area was washed down and all water/sewer recovered. Sampling to begin on 4/8/2022.  
Preliminary Cause: Pipe Failure

5730 Bowden Rd  
Jacksonville, FL 32216  
Duval County  
Friday, April 8, 2022 @ 10:00 AM  
Estimated gallons spilled: 100  
Action Taken: Blockage removed, roadway washed down and all wash water/sewer recovered. Loads were taken out of the storm water catch basin. Sampling of water way to being 4/9/2022.  
Preliminary Cause: Blockage

7909 Paseo Drive East  
Jacksonville, FL 32256  
Duval County  
Saturday, April 16, 2022 @ 12:00 AM  
Estimated gallons spilled: 5000  
Action Taken: Vacuum up sewer

Preliminary Cause: Contractor Error

8469 Western Way  
Jacksonville, FL 32256  
Duval County

Saturday, April 30, 2022 @ 10:16 PM

Estimated gallons spilled: 63828

Action Taken: Full circle clamp was installed on the damaged pipe. Vac trucks recovered sewer from impacted conveyance channels. Sewer soaked in to ground. Lime was applied to impacted land.

Preliminary Cause: Contractor Error

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

7897 Blanding Blvd  
Jacksonville, FL 32244  
Duval County

Monday, April 4, 2022 @ 11:55 PM

Estimated release amount: 100 gallons

Action Taken: Blockage was removed, all sewer recovered from storm drain.

Preliminary Cause: Blockage

7045 Jammes Rd  
Jacksonville, FL 32244  
Duval County

Tuesday, April 5, 2022 @ 9:29 PM

Estimated release amount: 150 gallons

Action Taken: Vac truck jetted gravity main clearing the grease blockage. The sewer in the stormwater ditch was recovered and the ditch was washed down.

Preliminary Cause: Blockage

11496 Amelia Cove Dr  
Jacksonville, FL 32226  
Duval County

Sunday, April 24, 2022 @ 10:30 AM

Estimated release amount: 50

Action Taken: Repairs made, impacted dirt replaced. Sewer recovered from surcharged storm drain.

Preliminary Cause: Contractor Error

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

11703 Magnolia Falls Dr 4/6/2022 9:56 AM - 20 gallons  
9687 Kendle Point Dr 4/11/2022 4:06 PM - 30 gallons  
451 North Catherine St 4/11/2022 9:40 PM - 1 gallon  
1833 Boulevard St 4/15/2022 11:02 AM - 5 gallons

#### Other Events Reported To The State Watch Office

1555 Milcoe Rd  
Jacksonville, FL 32225  
Duval County  
Monday, April 4, 2022 @ 5:17 PM  
Estimated gallons spilled: 14000  
Action Taken: Vacuum trucks and bypass pump maintained spill in the pit while crews repaired the line. Affected area was washed down and soaked into dirt. No impacts to storm drains or water bodies.  
Preliminary Cause: Contractor Error

Corner of Zoo Parkway and Imeson Park Blvd  
Jacksonville, FL 32218  
Duval County  
Thursday, April 7, 2022 @ 10:00 AM  
Estimated gallons spilled: 1,100  
Action Taken: Force main isolated and repaired. Vac truck flushed impacted storm drain and separate vac truck recovered flush water and sludge at downstream storm drain. Impacted land washed down and treated with lime.  
Preliminary Cause: Equipment Failure

Monument Rd and Monument Oaks Dr  
Jacksonville, FL 32225  
Duval County  
Saturday, April 23, 2022 @ 11:00 AM  
Estimated gallons spilled: 2,000  
Action Taken: Repairs made and roadway cleared.  
Preliminary Cause: Pipe Failure

#### May 2022

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)  
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

9980 New Kings Road  
Jacksonville, FL 32219  
Duval County  
Friday, May 6 @ 16:00 PM  
Estimated gallons spilled: 2500  
Action Taken: Valve was replaced, area was flushed. Ditch water, sewer and wash water recovered. Sampling to begin 5/7/22.



Preliminary Cause: Equipment Failure

13857 North Main St  
Jacksonville, FL 32218  
Duval County

Tuesday, May 10, 2022 @ 8:52 AM

Estimated gallons spilled: 9,000

Action Taken: Sewer valves were turned to slow flow down through manhole, new saddle and valve placed on force main. Area washed down and sewer/wash water recovered. Lime applied to all affected area.

Preliminary Cause: Equipment Failure

9827 Spottswood Dr W  
Jacksonville, FL 32208  
Duval County

Monday, May 30, 2022 @ 10:00 PM

Estimated gallons spilled: 300

Action Taken: Area was washed down.

Preliminary Cause: Grease

Edgewood Ave and W 5th St  
Jacksonville, FL 32254  
Duval County

Tuesday, May 31, 2022 @ 8:00 AM

Estimated gallons spilled: 312,000

Action Taken: Forcemain was valved off to slow flow, pipe was repaired. Multiple vac trucks maintained spill inside of excavated pit.

Preliminary Cause: Contractor Error

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

9349 N Main St  
Jacksonville, FL 32218  
Duval County

Thursday, May 5, 2022 @ 11:30 AM

Estimated release amount: 50 gallons

Action Taken: Small vacuum truck washed down area and recovered standing sewer. Pipe repaired. No impacts to Waters of the State.

Preliminary Cause: Contractor Error

1826 Fair St  
Jacksonville, FL 32210  
Duval County

Friday, May 6, 2022 @ 2:15 PM

Estimated release amount: 100 gallons

Action Taken: Line was repaired, area was washed down. Wash water and sewer recovered out of basin.

Preliminary Cause: Equipment Failure

9012 New Kings Road

Jacksonville, FL 32219

Duval County

Saturday, May 7, 2022 @ 1:30 PM

Estimated release amount: 900 gallons

Action Taken: Area was washed down, wash water and sewer recovered. Affected ditch was applied with hydrated lime.

Preliminary Cause: Blockage

7584 Wheat Rd

Jacksonville, FL 32244

Duval County

Thursday, May 12, 2022 @ 7:31 PM

Estimated release amount: 50 gallons

Action Taken: ARV was valved off to stop overflow. All sewer and wash water recovered from roadway.

Preliminary Cause: Equipment Failure

6545 Trade Center Dr

Jacksonville, FL 32254

Duval County

Friday, May 13, 2022 @ 9:36 AM

Estimated release amount: 100 gallons

Action Taken: Open conveyance bermed off to stop flow of sewer to storm drain. Area washed down and all sewer/wash water recovered.

Preliminary Cause: Equipment Failure

10470 Docksider Dr E

Jacksonville, FL 32257

Duval County

Monday, May 23, 2022 @ 6:00 PM

Estimated release amount: 150 gallons

Action Taken: Impacted area washed down and all sewer/wash water recovered.

Preliminary Cause: Grease

331 Laurina St

Jacksonville, FL 32216

Duval County

Tuesday, May 31, 2022 @ 5:25 PM

Estimated release amount: 100 gallons

Action Taken: Due to dam in place, vac truck was able to recover all sewer spilled.

Preliminary Cause:

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

5/2/2022 7:17 PM - 457 Firebush Ln - 10 gallons  
5/5/2022 8:35 AM - 219 Queen Victoria Ave - 20 gallons  
5/14/2022 10:20 AM - 20 Mile Rd and Stone Ridge Dr - 10 gallons

#### Other Events Reported To The State Watch Office

None

#### June 2022

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)  
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

Corner of McCormick and Kernan  
Jacksonville, FL 32225  
Duval County  
Thursday, June 2, 2022 @ 11:42 AM  
Estimated gallons spilled: 143,400  
Action Taken: Multiple vacuum trucks were able to maintain spill to prevent sewer escaping from the pit dug to repair the pipe. Crews were able to valve off the line and the forcemain was repaired.  
Preliminary Cause: Contractor Error

1219 Picketville Rd  
Jacksonville, FL 32220  
Duval County  
Monday, June 6, 2022 @ 2:45 PM  
Estimated gallons spilled: 94,000  
Action Taken: Vac trucks recovered from broken pipe until valves could be turned to stop flow from pipe. Vac trucks continued to maintain lift station until pipe was repaired. Pump was set up on pond to mitigate release to water. Sampling of area beginning 6/7/2022.  
Preliminary Cause: Contractor Error

1171 Lane Avenue South  
Jacksonville, FL 32205  
Duval County  
Wednesday, June 8, 2022 @ 11:10 AM  
Estimated gallons spilled: 50  
Action Taken: Blockage removed. 60,500 gallons recovered from the stormwater system.  
Investigative sample results received 6/10/2022 determined that the pond and downstream conveyance channel had been impacted by the spill. Monitoring of impacted areas to continue.  
Preliminary Cause: Blockage

Daisy Ln and Amelia Concourse  
Jacksonville, FL 32034  
Nassau County  
Saturday, June 25, 2022 @ 7:18 PM  
Estimated gallons spilled: 10000  
Action Taken: Repairs made, impacted area washed down, vacuumed and hydrated lime applied.  
Preliminary Cause: Equipment Failure

10601 San Jose Blvd  
Jacksonville, FL 32257  
Duval County  
Monday, June 27, 2022 @ 5:00 PM  
Estimated gallons spilled: 5000  
Action Taken: Blockage cleared, impacted area washed down and vacuumed.  
Preliminary Cause: Grease

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)  
All releases between 50-999 gallons are reported to local agencies.

1419 Belvedere Ave  
Jacksonville, FL 32205  
Duval County  
Sunday, June 19, 2022 @ 7:49 PM  
Estimated release amount: 100 gallons  
Action Taken: Washed down road and recovered sewer that released onto the ground and into the stormwater drain.  
Preliminary Cause: Equipment Failure

5330 Mays Dr  
Jacksonville, FL 32209  
Duval County  
Saturday, June 25, 2022 @ 6:16 PM  
Estimated release amount: 50 gallons  
Action Taken: Washed down and vacuumed impacted areas.  
Preliminary Cause: Blockage

7773 Collins Ridge Blvd  
Jacksonville, FL 32244  
Duval County  
Saturday, June 25, 2022 @ 7:15 PM  
Estimated release amount: 75 gallons  
Action Taken: Washed down and vacuumed impacted area. Full recovery.  
Preliminary Cause: Grease

9207 Dale View Ln W

Jacksonville, FL 32225

Duval County

Estimated release amount: 750

Action Taken: Impacted concrete was washed down by small vac. Hydrant used to flush pond with freshwater while crews simultaneously pumped water from impacted pond to nearby manhole.

Preliminary Cause: Blockage

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

11559 Summer Tree Rd N 6/17/22 @ 3:28PM - 15 gallons

#### Other Events Reported To The State Watch Office

None

#### July 2022

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

7721 Blanding Blvd

Jacksonville, FL 32244

Duval County

Friday, July 1, 2022 @ 4:00 PM

Estimated gallons spilled: 750

Action Taken: Sewer was removed from vault so ARV could be valved off to stop release. Sewer recovered from roadway. Sampling of waterway/pond to begin 7/2/2022.

Preliminary Cause: Equipment Failure

4147 Ferber Rd

Jacksonville, FL 32277

Duval County

Friday, July 8, 2022 @ 11:29 AM

Estimated gallons spilled: 37,250

Action Taken: Crews excavated pit to repair the forcemain. Vac trucks recovered sewage from pit until repairs could be made.

Preliminary Cause: Pipe Failure

5219 Carder St

Jacksonville, FL

Duval County

Sunday, July 17, 2022 @ 10:00 PM

Estimated gallons spilled: 1300

Action Taken: All water from overflow and rainwater had discharged into storm drain and flowed into the storm system once ERC was on site. No cleanup/recovery options available.

Preliminary Cause: Other

4605 Plymouth St

Jacksonville, FL 32205

Duval County

Wednesday, July 20, 2022 @ 6:01 PM

Estimated gallons spilled: 600

Action Taken: Overflow occurred until system could catch up. Roadway washed down and all wash water recovered. Sampling of creek to begin 7/21/2022.

Preliminary Cause: Storm Event

3058 Fitzgerald St

Jacksonville, FL 32254

Duval County

Thursday, July 21, 2022 @ 5:00 PM

Estimated gallons spilled: 10

Action Taken: Storm drain was flowing at time of arrival, unable to recover sewer in storm drain. Area washed down and recovered. Sampling of creek to begin 7/22/2022.

Preliminary Cause: Blockage

6659 Wellington Place Ln

Jacksonville, FL 32216

Duval County

Saturday, July 23, 2022 @ 8:25 PM

Estimated gallons spilled: 900

Action Taken: Blockage cleared on its own. Area washed down and loads were pulled out of storm drain to mitigate spill. Sampling of creek to begin on 7/24/2022.

Preliminary Cause: Blockage

2600 Blanding Blvd

Jacksonville, FL 32210

Duval County

Saturday, July 30, 2022 @ 5:16 PM

Estimated gallons spilled: 275

Action Taken: Crews stopped the leak by closing a downstream valve and using vac trucks to maintain upstream lift stations and recover the standing sewer from the leaking main.

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

3593 North Ride Drive

Jacksonville, FL

Duval County

Friday, July 15, 2022 @ 8:32 AM

Estimated release amount: 300 gallons

Action Taken: Blockage was removed to allow proper flow, street and curb was washed down, storm drain catch basins were vacuumed out.

Preliminary Cause: Blockage

14200 Duval Rd

Jacksonville, FL 32218

Duval County

Friday, July 22, 2022 @ 1:37 PM

Estimated release amount: 100 gallons

Action Taken: The blockage was removed, a load was taken off the sewer system within the complex to stop the overflow. Loads were taken off the storm water system to remove the sewer that escaped.

Preliminary Cause: Blockage

#### Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

7/21/2022 @ 10:29 AM - 11305 Harts Rd - 10 gallons

7/21/2022 @ 10:46 AM - 13162 Glen Kernan Pkwy - 30 gallons

7/22/2022 @ 2:00 PM - 804 La Marche Dr - 25 gallons

#### Other Events Reported To The State Watch Office

None