

January 2021

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

8388 Locke Dr
Jacksonville, FL 32244
Duval County
Thursday, December 31, 2020 @ 4:30 PM
Estimated gallons spilled: 120
Action Taken: The blockage was removed and spill stopped. Road was washed down and all wash water was recovered. Sampling to begin 1/1/2021.
Preliminary Cause: Grease

3759 Bess Rd
Jacksonville, FL 32277
Duval County
Friday, January 1, 2021 @ 2:00 AM
Estimated gallons spilled: 1350
Action Taken: Crew replaced air release valve on sewer pipe to stop leak. Road was washed down.
Preliminary Cause: Equipment Failure

Lane Ave & Old Kings Rd
Jacksonville, FL 32254
Duval County
Sunday, January 3, 2021 @ 2:45 PM
Estimated gallons spilled: 1750
Action Taken: Maintained until crew could remove broken air release valve and place full circle on pipe. Sewer soaked into ground. Lime applied to affected area.
Preliminary Cause: Equipment Failure

1143 Scotten Rd
Jacksonville, FL 32205
Duval County
Monday, January 4, 2021 @ 2:30 PM
Estimated gallons spilled: 100
Action Taken: Blockage was cleared and road was washed down. All wash water was recovered.
Preliminary Cause: Blockage

5141 Nile Rd
Jacksonville, FL 32254
Duval County
Wednesday, January 6, 2021 @ 8:25 AM
Estimated gallons spilled: 1000
Action Taken: Valve was opened, road was washed down. All wash water and sewer was recovered.

Preliminary Cause: Contractor Error

8691 Moss Haven Rd
Jacksonville, FL 32221
Duval County
Sunday, January 17, 2021 @ 9:55 AM
Estimated gallons spilled: 150
Action Taken: Wash down impacted area
Preliminary Cause: Blockage

3882 Cedar Point Rd
Jacksonville, FL 32226
Duval County
Monday, January 18, 2021 @ 12:00 AM
Estimated gallons spilled: 64,500
Action Taken: Washed down, vacuumed and applied hydrated lime to impacted area.
Preliminary Cause: Contractor Error

5444 Matanzas Way
Jacksonville, FL 32211
Duval County
Monday, January 25, 2021 @ 09:02 PM
Estimated gallons spilled: 400
Action Taken: Washed area down recovered wash water and sewer.
Preliminary Cause: Grease

SE corner JTB & San Pablo Rd S
Jacksonville, FL 32224
Duval County
Tuesday, January 26, 2021 @ 4:20 PM
Estimated gallons spilled: 2500
Action Taken: Spill was contained in pit. Affected area was washed down and wash water/sewer were recovered.
Preliminary Cause: Contractor Error

1300 Broad St
Jacksonville, FL 32202
Duval County
Saturday, January 30, 2021 @ 4:06 PM
Estimated gallons spilled: 200
Action Taken: Washed down affected area and recovered sewer/wash water out of storm drain.
Preliminary Cause: Grease

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

2710 Eaverson St

Jacksonville, FL 32209

Duval County

Saturday, January 2, 2021 @ 3:51 PM

Estimated release amount: 300 gallons

Action Taken: Blockage was removed, street washed down and all sewer from street and storm drain recovered.

Preliminary Cause: Grease

3516 Rio Grande Ave

Jacksonville, FL 32254

Duval County

Tuesday, January 5, 2021 @ 8:47 AM

Estimated release amount: 100 gallons

Action Taken: Repaired force main, washed down road and recovered wash water/sewer.

Preliminary Cause: Equipment Failure

6304 Lake Plantation Dr

Jacksonville, FL 32244

Duval County

Wednesday, January 6, 2021 @ 2:23 PM

Estimated release amount: 50 gallons

Action Taken: Repaired low pressure step pump, washed down road and recovered wash water/sewer.

Preliminary Cause: Equipment Failure

7601 Mayapple Court

Jacksonville, FL 32211

Duval County

Wednesday, January 13, 2021 @ 5:29 PM

Estimated release amount: 60 gallons

Action Taken: Wash down impacted area, vacuumed up wash down water and impacted sand from drain.

Preliminary Cause: Grease

5204 Mays Dr

Jacksonville, FL 32209

Duval County

Tuesday, January 19, 2021 @ 5:30 PM

Estimated release amount: 100 gallons

Action Taken: Washed down and vacuumed impacted area for full recovery.

Preliminary Cause: Pipe Failure

10423 Gailwood Cir E

Jacksonville, FL 32218

Duval County

Thursday, January 21, 2021 @ 8:48 AM

Estimated release amount: 200 gallons

Action Taken: Crew removed blockage to stop overflow. All sewer was recovered and area washed down with disinfectant.

Preliminary Cause: Blockage

1111 Knobb Hill Dr

Jacksonville, FL 32221

Duval County

Thursday, January 28, 2021 @ 11:52 AM

Estimated release amount: 150 gallons

Action Takeb: Washed down street and recovered from catch basin.

Preliminary Cause: Blockage

15051 Bartram Springs Rd

Jacksonville, FL 32259

Duval County

Friday, January 29, 2021 @ 1:02 PM

Estimated gallons released: 150

Action Taken: Crew repaired broken pipe and spread lime on affected area.

Preliminary Cause: Equipment Failure

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

138 Villa Sovana Ct 1/7/2021 @ 4:30 PM - 10 gallons

3475 Hartley Rd 1/9/2021 @ 2:37 PM - 10 gallons

234 General Doolittle Dr 1/14/2021 @ 2:20 PM - 40 gallons

2310 Edwards Ave 1/18/2021 @ 8:30 AM - 25 gallons

131 E 9th St 1/2/2021 @ 8:48 AM - 15 gallons

Other Events Reported To The State Watch Office

Durbin Lake Drive & Village Lake Drive 1/14/2021 @ 3:00 PM - 2500 gallons reclaimed water

6234 Harlow Blvd 1/21/2021 @ 1:17 PM - 30 gallons Hydraulic Oil

February 2021

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

2754 Southside Blvd

Jacksonville, FL 32216

Duval County

Wednesday, February 3, 2021 @ 2:00 PM

Estimated gallons spilled: 21000

Action Taken: 6,000 gallons released onto ground. 15,000 gallons recovered by vacuum trucks from manhole until repairs completed. Road and driveway washed down. Lime placed on customers yard per their request.

Preliminary Cause: Equipment Failure

7232 Secret Woods Dr

Jacksonville, FL

Duval County

Sunday, February 7, 2021 @ 4:00 PM

Estimated gallons spilled: 300

Action Taken: Curb washed down, storm drain flushed and vacuumed out, and hydrated lime applied around ARV.

Preliminary Cause: Equipment Failure

2369 Hawkcrest Dr

Fruit Cove, FL 32259

St. Johns County

Tuesday, February 9, 2021 @ 9:48 AM

Estimated gallons spilled: 63,500

Action Taken: All sewage contained onsite and in hole that was dug for repairs.

Preliminary Cause: Pipe Failure

Mossy Way and Lake Ride Dr

Jacksonville, FL 32223

Duval County

Tuesday, February 16, 2021 @ 6:00 PM

Estimated gallons spilled: 4300

Action Taken: Repaired broken force main and washed down area. Recovered wash water and sewer from storm drain. Applied hydrated lime to the affected area.

Sampling to begin 2/17/21

Preliminary Cause: Pipe Failure

5253 West 12th Street

Jacksonville, FL 32254

Duval County

Wednesday, February 17, 2021 @ 11:52 pM

Estimated gallons spilled: 1000

Action Taken: Wash down and vacuum up sewer from impacted area, apply hydrated lime

Preliminary Cause: Equipment Failure

7784 Blanding Blvd

Jacksonville, FL 32244

Duval County

Wednesday, February 24, 2021 @ 11:25 AM

Estimated gallons spilled: 8000

Action Taken: JEA crews recovered two loads to reach shut off valve in manhole to stop release. No sewer recoverable based on location of spill. Affected area washed down with clean water to eliminate odor.

Preliminary Cause: Contractor Error

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

8681 Longshore Way

Jacksonville, FL 32226

Duval County

Monday, February 1, 2021 @ 9:38 AM

Estimated release amount: 50 gallons

Action Taken: Blockage removed. Roadway washed down and recovered.

Preliminary Cause: Blockage

Lunar Dr & Skymark Dr

Jacksonville, FL 32218

Duval County

Monday, February 8, 2021 @ 6:42 AM

Estimated release amount: 500 gallons

Action Taken: ARV was valved off to stop spill. Road was washed down and wash water recovered. Storm drains were surcharged and recovered two loads out of drain.

Preliminary Cause: Equipment Failure

4377 Hecksher Dr

Jacksonville, FL 32226

Duval County

Wednesday, February 10, 2021 @ 12:01 PM

Estimated release amount: 100 gallons

Action Taken: JEA vacuum trucks will remove sewer from tank.

Preliminary Cause: Operator Error

8137 Point Meadows Way

Jacksonville, FL 32256

Duval County

Friday, February 12, 2021 @ 2:31 PM

Estimated release amount: 150 gallons

Action Taken: Blockage was removed to stop overflow. Wash water and sewer from storm drains recovered for full recovery.

Preliminary Cause: Grease

5625 Norwood Ave

Jacksonville, FL 32208

Duval County

Wednesday, February 17, 2021 @ 3:05 PM

Estimated release amount: 125 gallons

Action Taken: Affected area was washed down, sewer/wash water were recovered. Hydrated lime was applied to the affected area.
Preliminary Cause: Equipment Failure

7203 Stonehurst Rd N
Jacksonville, FL 32277

Duval County

Monday, February 22, 2021 @ 8:19 PM

Estimated release amount: 150 gallons

Action Taken: Full recovery, impacted area washed down and vacuumed.

Preliminary Cause: Grease

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

2392 W Beaver St 2/10/2021 12:50 PM - 10 gallons

206 Holly Forest Dr 2/10/2021 1:23 PM - 0 gallons

7179 Balboa Rd 2/19/2021 2:07 PM - 5 gallons

3561 Randall St 2/19/2021 9:30 PM - 5 gallons

SE Corner San Pablo Rd & JTB 2/24/2021 3:10 PM - 5 gallons

Other Events Reported To The State Watch Office

None

March 2021

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

4008 Loretto Road

Jacksonville, FL 32223

Duval County

Monday, March 1, 2021 @ 3:43 PM

Estimated gallons spilled: 100

Action Taken: Washed down affected area. Recovered wash water/storm water/sewer out of the storm water drain. Sampling to begin 3/2/2021.

Preliminary Cause: Equipment Failure

10775 Rutgers Rd

Jacksonville, FL 32218

Duval County

Monday, March 1, 2021 @ 1:05 AM

Estimated gallons spilled: 60

Action Taken: Due to rain, no sewage recoverable. Sampling begin 3/1/2021.
Preliminary Cause: Blockage

Clapboard Creek LN and Cedar Point Rd
Jacksonville, FL 32226
Duval County

Tuesday, March 2, 2021 @ 6:27 PM

Estimated gallons spilled: 1500

Action Taken: Lift station in the area was pumped down stopping the overflow from the forcemain. The forcemain was repaired, the affected area was washed down and washdown water was recovered.

Preliminary Cause: Third Party Damage

8516 India Ave
Jacksonville, FL 32211
Duval County

Tuesday, March 9, 2021 @ 11:30 AM

Estimated gallons spilled: 50

Action Taken: Blockage was removed, road was washed down.

Preliminary Cause: Blockage

3754 University Club Blvd
Jacksonville, FL 32277
Duval County

Monday, March 15, 2021 @ 11:30 AM

Estimated gallons spilled: 3300

Action Taken: JEA repaired pipe and recovered all sewer from construction hole.

Preliminary Cause: Contractor Error

103rd and Jammes Rd
Jacksonville, FL 32244
Duval County

Wednesday, March 17, 2021 @ 11:19 PM

Estimated gallons spilled: 12500

Action Taken: JEA started recovering sludge from the overflow spot until sludge line could be valved to stop overflow. Road was washed down and all wash water was recovered.

Preliminary Cause: Contractor Error

400 E Bay St
Jacksonville, FL 32202
Duval County

Tuesday, March 16, 2021 @ 12:00 AM

Estimated gallons spilled: 250

Action Taken: Ball of rope was removed from outgoing pipe to allow sewer to flow freely. Road was washed down and wash water recovered.

Preliminary Cause: Blockage

7639 Hilsdale Rd

Jacksonville, FL 32216

Duval County

Sunday, March 20, 2021 @ 11:05 PM

Estimated gallons spilled: 100

Action Taken: Jetted main line and was able to remove blockage. Road washed down. SERVE PRO called to remediate damage in customers home.

Preliminary Cause: Blockage

100 Mahogany Bay Dr

Jacksonville, FL

Duval County

Wednesday, March 31, 2021 @ 5:00 AM

Estimated gallons spilled: 7000

Action Taken: Manhole vacuumed down and maintained till main could be killed and repaired. Once main was repaired the remaining discharged sewer had soaked into ground and hydrated lime was applied to effected area.

Preliminary Cause: Equipment Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

3211 De Carlo LN

Jacksonville, FL 32277

Duval County

Wednesday, March 3, 2021 @ 4:59 PM

Estimated gallons spilled: 50

Action Taken: Curblineline was blocked off containing spill. Affected area was washed down, wash water/sewer were recovered. No impacted storm drains.

Preliminary Cause: Blockage

9795 Villiers DR S

Jacksonville, FL 32221

Duval County

Friday, March 5, 2021 @ 7:29 AM

Estimated release amount: 50 gallons

Action Taken: Washed area down and pulled back and recovered water from impacted storm drain that lead to retention pond. Sampling of impacted pond to begin 3/6.

Preliminary Cause: Blockage

1257 Stonehedge Tr LN

Jacksonville, FL 32092

Duval County

Friday, March 5, 2021 @ 7:29 AM

Estimated release amount: 150 gallons

Action Taken: Pumps were turned back on and overflow was stopped at 09:21 AM. Washed area down and recovered wash water and sewer from storm drain basin.

Preliminary Cause: Contractor Error

6039 Bartholf Ave

Jacksonville, FL 32210

Duval County

Friday, March 5, 2021 @ 10:03 AM

Estimated release amount: 600 gallons

Action Taken: Sewer soaked into ground, applied hydrated lime.

Preliminary Cause: Equipment Failure

1212 Challen Ave

Jacksonville, FL 32205

Duval County

Friday, March 5, 2021 @ 1:31 PM

Estimated release amount: 50 gallons

Action Taken: Washed down affected area and recovered sewer/wash water from storm drain basin.

Preliminary Cause: Blockage

2055 Reyko Rd

Jacksonville, FL 32207

Duval County

Friday, March 12, 2021 @ 9:59 AM

Estimated release amount: 200 gallons

Action Taken: Blockage was removed. Street was washed down. All sewer recovered from catch basin.

Preliminary Cause: Blockage

3985 Hunt Club Rd N

Jacksonville, FL 32224

Duval County

Friday, March 26, 2021 @ 4:43 PM

Estimated release amount: 250 gallons

Action Taken: Wash down and vacuum up sewer/wash down water from impacted area. Full recovery of sewer from storm drain

Preliminary Cause: Blockage

1840 Blanding Blvd

Jacksonville, FL 32210

Duval County

Tuesday, March 30, 2021 @ 12:52 PM

Estimated release amount: 510 gallons

Action Taken: Area washed down and vacuumed up. Also, one large vac truck load taken off of affected pond.

Preliminary Cause: Cave-in

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

None

Other Events Reported To The State Watch Office

1245 Reclamation Dr 3/30/2021 @ 8:30 AM - 50 gallons Sodium Hypochlorite

April 2021

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

653 Monument Road
Jacksonville, FL 32225

Duval County

Tuesday, April 6, 2021 @ 5:00 PM

Estimated gallons spilled: 1000

Action Taken: Due to dense vegetation and lack of roadway, sewer was not recovered. Sampling to begin 4/7/21.

Preliminary Cause: Grease

5546 Robert Scott Dr N

Jacksonville, FL 32207

Duval County

Tuesday, April 13, 2021 @ 6:50 PM

Estimated gallons spilled: 200

Action Taken: Washed down and vacuumed roadway.

Preliminary Cause: Grease

Davis Pond Blvd and Dewberry Dr S

Fruit Cove, FL 32259

St. Johns County

Monday, April 19, 2021 @ 12:00 AM

Estimated gallons spilled: 30,000

Action Taken: Small vac took loads off spill until big vac and crew arrived onsite. Pipe repaired, hydrated lime placed on affected grass, road washed down and all wash water recovered.

Preliminary Cause: Contractor Error

6680 103rd St

Jacksonville, FL 32210

Duval County

Wednesday, April 21, 2021 @ 12:00 AM

Estimated gallons spilled: 1,000

Action Taken: Crews maintained spill with vacuum truck until pipe was repaired. Roadway washed down and all wash water recovered.

Preliminary Cause: Pipe Failure

10523 Deerwood Park Blvd

Jacksonville, FL 32256

Duval County

Friday, April 23, 2021 @ 12:00 AM

Estimated gallons spilled: 40,000

Action Taken: Storm drains were blocked off and sewer was recovered from parking lot until valve/pipe was repaired. Area impacted by sewer washed down and all sewer recovered.

Preliminary Cause: Equipment Failure

SW Corner of Racetrack Road and Philips HWY

Jacksonville, FL 32259

St. Johns County

Tuesday, April 27, 2021 @ 09:51 AM

Estimated gallons spilled: 14,400

Action Taken: Repaired broken valve, sewer soaked into ground. Applied hydrated lime to affected area that is accessible by public. No waterways impacted.

Preliminary Cause: Contractor Error

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

5326 Regiment Dr

Jacksonville, FL 32277

Duval County

Monday, April 12, 2021 @ 9:14 AM

Estimated release amount: 200 gallons

Action Taken: Road washed down and wash water recovered. Load taken out of storm drain to recover sewer. While recovering, water flowing back toward opening.

Preliminary Cause: Grease

200 Crooked CT

Jacksonville, FL 32259

Duval County

Thursday, April 15, 2021 @ 9:32 AM

Estimated release amount: 200 gallons

Action Taken: Repaired broken forcemain and recovered sewer, rain water, and wash water from storm drain. Applied hydrated lime to affected area.

Preliminary Cause: Contractor Error

11190 Beach Blvd

Jacksonville, FL 32246

Duval County

Thursday, April 15, 2021 @ 9:20 AM

Estimated release amount: 100 gallons

Action Taken: Repaired broken forcemain and recovered sewer, rain water, and wash water from ditchline.

Preliminary Cause: Contractor Error

117 W 42nd St

Jacksonville, FL 32208

Duval County

Tuesday, April 20, 2021 @ 2:55 PM

Estimated release amount: 100 gallons

Action Taken: The blockage was removed, road washed down and all sewer/washwater recovered from storm drain.

Preliminary Cause: Blockage

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

11091 Bluehill Dr 4/15/2021 @ 10:17 PM - 10 gallons

95431 Woodbridge Pkwy 4/30/2021 @ 1:38 PM – 20 gallons

Other Events Reported To The State Watch Office

None