

January 2020

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

915 Nocatee Pkwy
Jacksonville, FL 32081
Duval County
Monday, January 20, 2020 @ 3:00 PM
Estimated gallons spilled: 792000
Action Taken: JEA personnel turned off pump to stop overflow. Overflow traveled to a reclaimed pond in Nocatee.
Preliminary Cause: Operator Error

6504 Todd Rd
Jacksonville, FL
Duval County
Wednesday, January 22, 2020 @ 11:56 AM
Estimated gallons spilled: 500
Action Taken: Road washed down.
Preliminary Cause: Blockage

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)
All releases between 50-999 gallons are reported to local agencies.

1254 De Paul Dr - 1/8/2020 9:07 a.m. 50 gallons
4728 Roanoke Blvd - 1/10/2020 3:00 a.m. 100 gallons
Craven Rd & Edgewater Crossing - 1/13/2020 a.m. 400 gallons
6504 Richard St - 1/21/2020 1:12 p.m. 100 gallons

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

None

Other Events Reported To The State Watch Office

None