

January 2020

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

915 Nocatee Pkwy
Jacksonville, FL 32081
Duval County
Monday, January 20, 2020 @ 3:00 PM
Estimated gallons spilled: 792000
Action Taken: JEA personnel turned off pump to stop overflow. Overflow traveled to a reclaimed pond in Nocatee.
Preliminary Cause: Operator Error

6504 Todd Rd
Jacksonville, FL
Duval County
Wednesday, January 22, 2020 @ 11:56 AM
Estimated gallons spilled: 500
Action Taken: Road washed down.
Preliminary Cause: Blockage

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)
All releases between 50-999 gallons are reported to local agencies.

1254 De Paul Dr - 1/8/2020 9:07 a.m. 50 gallons
4728 Roanoke Blvd - 1/10/2020 3:00 a.m. 100 gallons
Craven Rd & Edgewater Crossing - 1/13/2020 a.m. 400 gallons
6504 Richard St - 1/21/2020 1:12 p.m. 100 gallons

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

None

Other Events Reported To The State Watch Office

None

February 2020

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

7805 Delaroache Dr
Jacksonville, FL 32210
Duval County
Saturday, February 1, 2020 @ 12:00 AM
Estimated gallons spilled: 4,000
Action Taken: Washed area and recovered sewer. Lime applied to affected area.
Preliminary Cause: Equipment Failure

11201 New Berlin Rd
Jacksonville, FL 32226
Duval County
Wednesday, February 5, 2020 @ 3:00 PM
Estimated gallons spilled: 76,000
Action Taken: Washed down, vacuumed and applied hydrated lime to impacted area.
Preliminary Cause: Contractor Error

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

University Blvd & Edenfield Rd - 2/1/2020 at 1:08 p.m. 200 gallons
6360 New Kings Rd - 2/3/2020 at 8:00 a.m. 300 gallons
E 11th St and Talleyrand Ave - 2/5/2020 at 1:45 p.m.
5375 Ortega Farms Blvd - February 24, 2020 @ 3:45 PM 250 gallons
Longleaf Pine Pkwy near 7399 Longleaf Pine Pkwy - February 25, 2020 @ 9:00 PM 500 gallon

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

None

Other Events Reported To The State Watch Office

None

March 2020

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

6803 Wheat Rd
Jacksonville, FL 32244
Duval County

Wednesday, March 4, 2020 @ 12:00 PM

Estimated gallons spilled: 500

Action Taken: Valve was turned off to stop release. ARV will be replaced. Lime placed on affected area.

Preliminary Cause: Equipment Failure

NW Corner of Flanders Rd and San Jose Blvd

Jacksonville, FL

Duval County

Friday, March 13, 2020 @ 3:21 PM

Estimated gallons spilled: 200

Action Taken: Force main repaired, storm sewer flushed, sewer and flushing water removed at manhole just upstream of discharge to creek.

Preliminary Cause: Pipe Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

4160 Woodcock Dr 3/4/2020 3:31 p.m. - 50 gallons

4560 Lenox Ave 3/6/2020 1:13 p.m. - 750 gallons

5225 University Blvd W 3/12/2020 9:48 a.m. - 100 gallons

200 Ponte Vedra Blvd 3/17/2020 4:14 p.m. - 300 gallons

4560 Lenox Ave 3/18/2020 9:59 a.m. - 750 gallons

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

None

Other Events Reported To The State Watch Office

None

April 2020

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)

All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

4217 Goldie St

Jacksonville, FL

Duval County

Wednesday, April 15, 2020 @ 6:00 PM

Estimated gallons spilled: 50
Action Taken: Road washed down
Preliminary Cause: Blockage

8685 Baymeadows Rd E
Jacksonville, FL
Duval County
Thursday, April 16, 2020 @ 2:00 PM
Estimated gallons spilled: 500
Action Taken: Recovered water from pond overflow
Preliminary Cause: Equipment Failure

4060 Barnes rd
Jacksonville, FL 32207
Duval County
Friday, April 24, 2020 @ 7:39 PM
Estimated gallons spilled: 800
Action Taken: Wash down and vacuum up sewer from impacted area, apply liquid disinfectant
Preliminary Cause: Grease

4499 Hanover Park Dr
Jacksonville, FL 32224
Duval County
Tuesday, April 28, 2020 @ 9:29 AM
Estimated gallons spilled: 200
Action Taken: Sampling of pond connected to storm drain to determine water impact. Road washed down with disinfectant.
Preliminary Cause: Blockage

Beach Blvd and Ryar Rd
Jacksonville, FL 32216
Duval County
Tuesday, April 28, 2020 @ 2:10 PM
Estimated gallons spilled: 0
Action Taken: Recovery efforts ongoing to prevent further sewer entering into storm drain until pipe can be repaired.
Preliminary Cause: Contractor Error

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

241 Tresca Rd 4/21/2020 10:20 a.m. - 50 gallons

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor

events do not require external reporting however, they will also be listed to provide transparency of all releases.

5546 Gilchrist Rd 4/2/2020 6:38 p.m. - 10 gallons
5110 Dostie Dr S 4/12/2020 2:34 p.m. - 2 gallons
2800 Cimmarone Blvd 4/13/2020 9:44 a.m. - 0 gallons

Other Events Reported To The State Watch Office

7055 Bartram Preserve Parkway
Jacksonville, FL
Duval County
Tuesday, April 28, 2020 @ 12:00 AM
Estimated gallons spilled: 2,000
Action Taken: Valves were turned to stop the release of water until pipe could be repaired.
Preliminary Cause: Pipe Failure

May 2020

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

11406 San Jose Blvd
Jacksonville, FL
Duval County
Tuesday, May 4, 2020 @ 9:45 PM
Estimated gallons spilled: 250
Action Taken: Blockage removed, area washed down, and one large vac truck load pulled off of storm catch basin prior to storm pond.
Preliminary Cause: Blockage

2678 St. Johns Bluff Rd S
Jacksonville, FL 32246
Duval County
Sunday, May 17, 2020 @ 10:08 AM
Estimated gallons spilled: 6,750
Action Taken: ARV was turned off until can be repaired. Sewer recovered from median. Vac truck set up on creek to recover sewer and flush water. Sampling will be conducted on 5/18/2020.
Preliminary Cause: Equipment Failure

Mandarin Rd and Scott Mill Rd
Jacksonville, FL 32223
Duval County
Sunday, May 17, 2020 @ 9:00 PM
Estimated gallons spilled: 14,400

Action Taken: Vac trucks were unsuccessful in removing blockage. A bypass pump was set up on manhole to pump sewer directly into lift station until line can be cleared. Sewer was recovered from storm drains, areas affected limed and sampling to begin on 5/19/2020.

Preliminary Cause: Blockage

2232 Camden Ave

Jacksonville, FL 32207

Duval County

Friday, May 22, 2020 @ 4:00 PM

Estimated gallons spilled: 30

Action Taken: Wash down impacted area. Vacuum up wash down water.

Preliminary Cause: Grease

Gandy Street & Smyrna Street

Jacksonville, FL 32208

Duval County

Saturday, May 23, 2020 @ 11:00 PM

Estimated gallons spilled: 3000

Action Taken: Wash down and vacuum sewer from impacted area

Preliminary Cause: Equipment Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

10991 San Jose Blvd 5/3/20 5:35 p.m. - 50 gallons

8676 Springtree Rd 5/4/2020 7:46 p.m. - 500 gallons

1126 Odessa St 5/24/2020 10:00 a.m. - 50 gallons

5355 Dolphin Point Blvd 5/26/2020 9:10 a.m. - 400 gallons

3033 Monument Rd 5/27/2020 4:38 p.m. - 50 gallons

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

3616 Stuart St 5/9/2020 12:20 p.m. - 5 gallons

Forsyth St and Lee St 5/11/2020 11:30 a.m. - 5 gallons

7178 Balboa Rd 5/17/2020 09:47 a.m. - 25 gallons

Other Events Reported To The State Watch Office

None

June 2020

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

7200 A C Skinner Pkwy

Jacksonville, FL

Duval County

Sunday, June 7, 2020 @ 11:00 AM

Estimated gallons spilled: 1000

Action Taken: Sewage was vacuumed up from property, washed down, and wash down water was also vacuumed up and removed from property. An additional 5000 gals were removed from wet well for as a precaution. Contracted vacuum trucks were used for this clean up.

Preliminary Cause: TS/Hurricane

1018 Cassat Ave

Jacksonville, FL

Duval County

Sunday June 7, 2020 @ 9:00 AM

Estimated gallons spilled: 3000

Action Taken: N/A

Preliminary Cause: TS/Hurricane

103rd St & Firestone Rd

Jacksonville, FL

Duval County

Sunday June 7, 2020 @ 9:00 AM

Estimated gallons spilled: 2,500

Action Taken: N/A

Preliminary Cause: TS/Hurricane

5809 Jason Dr

Jacksonville, FL

Duval County

Sunday June 7, 2020 @ 9:00 AM

Estimated gallons spilled: 500

Action Taken: N/A

Preliminary Cause: TS/Hurricane

6752 London Bridge Ln

Jacksonville, FL

Duval County

Sunday June 7, 2020 @ 7:00 PM

Estimated gallons spilled: 200

Action Taken: N/A

Preliminary Cause: TS/Hurricane

5104 118th St
Jacksonville, FL
Duval County
Monday June 8, 2020 @ 8:44 PM
Estimated gallons spilled: 263,000
Action Taken: JEA crew recovered sewage water from the ditches and wetland area next to Ortega River. Area was washed down and lime applied to affected area. Signs placed and sampling will begin on 6/9/2020.
Preliminary Cause: Equipment Failure

4715 Worrall Way
Jacksonville, FL 32224
Duval County
Thursday, June 11, 2020 @ 6:17 PM
Estimated gallons spilled: 60000
Action Taken: Crew used a full circle to stop the leak. Vacuum trucks recovered sewage from road and areas of wetland. Lime was placed on road.
Preliminary Cause: Equipment Failure

8282 Western Way
Jacksonville, FL 32256
Duval County
Thursday, June 11, 2020 @ 10:00 PM
Estimated gallons spilled: 10000
Action Taken: JEA crew turned valves to isolate flow and dug down to pipe to repair pipe.
Preliminary Cause: Contractor Error

1964 W 13th St
Jacksonville, FL 32209
Duval County
Thursday, June 11, 2020 @ 9:10 PM
Estimated gallons spilled: 20
Action Taken: Road washed down and all wash water recovered.
Preliminary Cause: Blockage

14581 Spring Light Cir
Jacksonville, FL 32226
Duval County
Friday, June 12, 2020 @ 4:21 PM
Estimated gallons spilled: TBD
Action Taken:
Preliminary Cause: Contractor Error

8515 Baymeadows Way
Jacksonville, FL
Duval County
Thursday June 18, 2020 @ 11:45 AM

Estimated gallons spilled: 2,000
Action Taken: Recovered, washed down, and limed.
Preliminary Cause: Blockage

401 Century 21 Ave
Jacksonville, FL 32216
Duval County
Tuesday June 23, 2020 @ 9:34 AM
Estimated gallons released: 1,000
Action Taken: Sewer washed down and collected from street. Sewer standing in storm drain recovered.
Preliminary Cause: Blockage

12548 San Jose Blvd
Jacksonville, FL 32223
Duval County
Thursday, June 25, 2020 @ 10:43 PM
Estimated gallons spilled: 6000
Action Taken: Repairs made, impacted area washed down and vacuumed.
Preliminary Cause: Contractor Error

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)
All releases between 50-999 gallons are reported to local agencies.

3928 Baymeadows Rd 6/11/2020 4:24 p.m. - 50 gallons
45 Ames Cove 6/30/2020 3:00 p.m. – 200 gallons

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

675 Skymark Dr 6/1/2020 2:17 p.m. - 20 gallons
7923 Free Ave 6/2/2020 8:00 p.m. - 10 gallons
4298 University Blvd N 6/4/2020 12:00 a.m. - 5 gallons
139 Lighthouse Rd W 6/8/2020 11:45 a.m. - 5 gallons
3498 Valverde Ct 6/15/2020 7:45 p.m. – 25 gallons
3609 Myra St 6/19/2020 4:00 p.m. – 20 gallons
1815 W 11th St 6/22/2020 9:12 a.m. – 5 gallons
1790 Kernan Blvd S 6/26/2020 at 2:00 p.m. – 35 gallons

Other Events Reported To The State Watch Office

None

July 2020

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

4140 Hodges Blvd.
Jacksonville, FL
Duval County
Sunday, July 3, 2020 @ 9:00 AM
Estimated gallons spilled: 24,000
Action Taken: Recovered spill and applied lime to affected area
Preliminary Cause: Pipe Failure

5696 English Oaks Dr S.
Jacksonville, FL
Duval County
Sunday, July 5, 2020 @ 12:18 PM
Estimated gallons spilled: 36,500
Action Taken: Recovered spill and applied lime to affected area
Preliminary Cause: Pipe Failure

880 Eagle Point Dr
Jacksonville, FL 32092
St. Johns County
Saturday July 11, 2020 @ 11:10 AM
Estimated gallons spilled: 6,000
Action Taken: Bypass pump was set up, water was recovered from storm drains.
Preliminary Cause: Cave-in

Leo Maguire Pkwy
Jacksonville, FL 32092
St Johns County
Tuesday, July 14, 2020 @ 12:00 AM
Estimated gallons spilled: 5000
Action Taken: Vacuum up sewer and applied hydrated lime to impacted area.
Preliminary Cause: Equipment Failure

13200 Chets Creek Blvd.
Jacksonville, FL 32224
Duval County
Wednesday, July 15, 2020 @ 9:20 PM
Estimated gallons spilled: 2000
Action Taken: Vacuum up sewer and applied hydrated lime to area
Preliminary Cause: Pipe Failure

7310 Ridgeway Rd N
Jacksonville, FL 32244

Duval County

Thursday, July 16, 2020 @ 11:00 PM

Estimated gallons spilled: 500

Action Taken: Vacuum up sewer from ground around residence, wash down impacted area, and apply hydrated lime to impacted area.

Preliminary Cause: Blockage

7716 Club Duclay Drive

Jacksonville, FL 32244

Duval County

Saturday, July 18, 2020 @ 6:30 PM

Estimated gallons spilled: 5000

Action Taken: Wash down and vacuum up sewer, recover sewer from storm water ditch.

Preliminary Cause: Operator Error

10708 Dulawan Dr

Jacksonville, FL 32246

Duval County

Monday, July 20, 2020 @ 5:17 PM

Estimated gallons spilled: 400

Action Taken: Washed down and vacuumed impacted area.

Preliminary Cause: Blockage

Amelia Concourse 1000FT N of Majestic Walk

Yulee, FL

Nassau County

Friday, July 31, 2020 @ 7:30 AM

Estimated gallons spilled: 1500

Action Taken: Recovered spill from land and storm drains. Hydrated lime applied.

Preliminary Cause: Equipment Failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

7702 Club Duclay Drive 7/4/2020 2:27 a.m. - 300 gallons

8352 Chason Rd E 7/13/2020 1:27 p.m. - 750 gallons

2991 Preserve Landing Dr 7/20/2020 10:44 a.m. - 200 gallons

3243 De Carlo Ln 7/23/2020 6:00 p.m. - 100 gallons

3475 Kernan Blvd S 7/23/2020 12:48 p.m. - 300 gallons

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

None

Other Events Reported To The State Watch Office

220 Davis Pond Blvd - Reclaimed Water
Jacksonville, FL 32259
Duval County
Wednesday, July 15, 2020 @ 5:30 AM
Estimated gallons spilled: 8700
Action Taken: None required
Preliminary Cause: Equipment Failure

August 2020

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

777 Ashford Street
Jacksonville, FL 32208
Duval County
Wednesday, August 5, 2020 @ 10:30 AM
Estimated gallons spilled: 100
Action Taken: Cleaned blockage out of man hole, retrieved 6000 gal of sewer/rain water from storm drain. Washed down road and applied hydrated lime to affected area.
Preliminary Cause: Grease

2618 Dellwood Ave
Jacksonville, FL 32204
Duval County
Tuesday, August 11, 2020 @ 8:00 PM
Estimated release amount: 50 gallons
Action Taken: Due to heavy rain unable to clean up
Preliminary Cause: Cave-in

2415 D Street
Jacksonville, FL 32208
Duval County
Tuesday, August 11, 2020 @ 6:45 PM
Estimated release amount: 1000 gallons
Action Taken: Due to heavy rain unable to clean up
Preliminary Cause: Other

3450 CR 210 W
St. Johns, FL 32259
Duval County
Thursday, August 13, 2020 @ 4:00 PM
Estimated gallons spilled: 5000

Action Taken: The air release valve was repalced to stop the overflow. Sewer from roadway was recovered and lime was placed on affected area. Sampling of pond will begin on 8/14/2020.
Preliminary Cause: Equipment Failure

10190 Belle Rive Blvd
Jacksonville, FL 32256

Duval County

Thursday, August 20, 2020 @ 10:09 AM

Estimated gallons spilled: 4,200

Action Taken: Washed road down, recovered 25,000 gal of sewer and rainwater.

Preliminary Cause: Blockage

14701 Philips Highway
Jacksonville, FL 32256

Duval County

Thursday, August 27, 2020 @ 12:27 PM

Estimated gallons spilled: 2,500

Action Taken: Recovered out of storm drain and ditch, washed down road.

Preliminary Cause: Contractor error

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)

All releases between 50-999 gallons are reported to local agencies.

5022 Gate Parkway 8/5/2020 8:08 a.m. - 600 gallons

3831 St. Johns Ave 8/7/2020 10:15 a.m. - 600 gallons

103rd and Firestone Rd 8/11/2020 9:48 a.m. - 500 gallons

5428 Los Santos Way 8/12/2020 8:07pm - 100 gallons

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

4909 Rhode Island Ct 8/7/2020 2:24 p.m. - 15 gallons

Knoll Dr N and Pinnacle Dr 8/7/2020 8:05 p.m. - 15 gallons

985 W 12th St 8/25/2020 5:00 p.m. - 10 gallons

Other Events Reported To The State Watch Office

None

September 2020

SSO Events reported to the Florida Division of Emergency Management State Watch Office (SWO)
All releases that impact waters of the State, exceed 1,000 gallons in volume, or may cause a potential threat to public health or the environment will be called in to SWO within 24 hours.

15598 Lexington Park Blvd

Jacksonville, FL 32218

Duval County

Thursday, September 10, 2020 @ 7:45pm

Estimated gallons spilled: 7500

Action Taken: Street was washed down and sewer/wash water was recovered out of storm drain, apply hydrated lime to impacted area.

Preliminary Cause: Equipment Failure

514 Lomax St

Jacksonville, FL 32204

Duval County

Wednesday, September 2, 2020 @ 8:37 AM

Estimated gallons released: 100

Action Taken: Street was washed down and sewer/wash water was recovered out of storm drain

Preliminary Cause: Blockage

2066 Matefield Road

Jacksonville, FL 32225

Duval County

Tuesday, September 8, 2020 @ 12:00 PM

Estimated gallons spilled: 10000

Action Taken: Washed down street and fixed man hole.

Preliminary Cause: Cave-in

18th and Walnut

Jacksonville, FL 32206

Duval County

Tuesday, September 8, 2020 @ 11:15 AM

Estimated gallons spilled: 1000

Action Taken: Washed down street.

Preliminary Cause: Operator Error

5688 English Oaks

Jacksonville, FL 32244

Duval County

Monday, September 14, 2020 @ 12:00 AM

Estimated gallons spilled: 0

Action Taken: Recovered 66,300 from overflow site, applied hydrated lime to affected area.

Sampling to begin 9/15/20.

Preliminary Cause: Pipe Failure

3354 Kegler Dr
Jacksonville, FL 32216
Duval County
Saturday, September 19, 2020 @10:30 AM
Estimated gallons spilled: 600
Action Taken: Wahed down and vacuumed impacted area.
Preliminary Cause: Blockage

10407 Centurian Parkway
Jacksonville, FL 32256
Duval County
Monday, September 21, 2020 @ 12:00 AM
Estimated gallons spilled: 100000
Action Taken:
Preliminary Cause: Equipment Failure

8765 Baymeadows Road
Jacksonville, FL 32256
Duval County
Monday, September 21, 2020 @ 3:10 PM
Estimated gallons spilled: 1000
Action Taken: Recovered from detention pond and storm drain to bring pond out of overflow.
Road was washed down and wash water was recovered.
Preliminary Cause: Blockage

8011 Merrill Road
Jacksonville, FL 32277
Duval County
Friday, September 25, 2020 @ 3:00 PM
Estimated gallons spilled: 550
Action Taken: Washed down street.
Preliminary Cause: Blockage

234 River Hills Dr
Jacksonville, FL 32216
Duval County
Monday, September 27, 2020 @ 8:07 AM
Estimated gallons spilled: 540
Action Taken: Replaced ARV to stop overflow. No sewer was recovered from storm drain.
Preliminary Cause: Equipment failure

SSO Events Reported to Local Agencies (Florida Department of Environmental Protection - Northeast District, COJ-Environmental Quality Division)
All releases between 50-999 gallons are reported to local agencies.

6368 Thatcher Trail 9/1/2020 at 11:32 a.m. - 100 gallons
8602 Mable Dr 9/21/2020 at 10:10 p.m. - 300 gallons

Minor SSO Events

JEA reviews all SSO events to determine cause and apply corrective action. Minor events are those of less than 50 gallons that do not cause a potential threat to public health or the environment. Minor events do not require external reporting however, they will also be listed to provide transparency of all releases.

7443 Richardson Rd 9/9/2020 at 10:20 a.m. - 5 gallons

Other Events Reported To The State Watch Office

Reclaimed Event

1414 Millcoie Rd

Jacksonville, FL 32225

Duval County

Thursday, September 24, 2020 @ 4:00 PM

Estimated gallons spilled: 5000

Action Taken: None needed

Preliminary Cause: Pipe Failure

Security Breach

801 Beckner Ave

Jacksonville, FL

Duval County

Friday, September 25, 2020 @ 1:45 AM

Action Taken: Individual entered into WTP under main gate, and sat on curb. JSO and JEA security was called. Operator Jack LaLonde was called to check plant. No tampering was found within the plant.

Preliminary Cause: JSO gave individual a trespassing warning