



January 13, 2019

Project No. 15-26356.2

Mr. Matt McClure, PE

JEA

21 West Church Street

Jacksonville, FL 32202

**RE: INITIATION OF ASSESSMENT OF CORRECTIVE MEASURES
BYPRODUCT STORAGE AREA B - CCR GROUNDWATER MONITORING
ST. JOHNS RIVER POWER PARK
DUVAL COUNTY, FLORIDA**

Dear Mr. McClure:

Golder Associates Inc. is providing this notification of the initiation of assessment of corrective measures pursuant to §257.96 of the Coal Combustion Residual (CCR) Rule¹ for the Byproduct Storage Area B at the St. Johns River Power Park. The statistical evaluation of assessment monitoring results indicated that radium 226+228 at CCR-6 was a statistically significant level relative to the groundwater protection standard established for the site. Assessment of corrective measures will be initiated January 13, 2019.

Sincerely,

Golder Associates Inc.

A handwritten signature in blue ink, appearing to read 'Samuel F. Stafford'.

Samuel F. Stafford, PE

Senior Project Engineer

A handwritten signature in blue ink, appearing to read 'Gregory M. Powell'.

Gregory M. Powell, PhD, PE

Practice Leader and Principal

SFS/GMP/ams

G:\Projects\15-15-26356.2\Reports\Final\ACM Notice\SJRPP ACM Initiation Letter.docx

¹ 40 Code of Federal Regulations (CFR) §257.50 to §257.107, as revised in Phase One, Part One, Final Rule, 83 Federal Register 36435 (July 30, 2018).