



Building Community®
Procurement Department Bid Office
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

July 28, 2020

ADDENDUM NUMBER: Two (2)

TITLE: Boulevard Street Force Main and Water Main Replacement

JEA IFB NUMBER: 063-20

BID DUE DATE: July 7, 2020 August 4, 2020

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

JEA is providing the following file:

063-20 Addendum 2 Appendix B - Workbook

063-20 Addendum 2 Appendix C - Drawing Updates

GENERAL CLARIFICATIONS AND QUESTIONS FROM BIDDERS:

1. Question:

There is only one Law Enforcement Allowance noted within the Bid, given the location of this project what is JEA's intent to use officers?

Answer:

The allowance is made available by JEA and its use is up to the Contractor's discretion in accordance with the Contract Documents.

2. Question:

Pavement Repair Bid Items (Case III and Case IV) require concrete base instead of lime rock, it doesn't appear that the MOT outlined in the drawing are applicable to the nature of this work. Please explain how the Maintenance of Traffic will be set up. Will Road Closures be an option?

Answer:

The MOT/TTC plans as provided presents an example MOT/TCC scenario which has been approved by the City of Jacksonville (COJ). The Contractor will be required to develop their own detailed construction phasing and MOT/TCC plan based on the proposed means and methods of construction. The Contractor's detailed phasing and MOT/TCC plan will need to be submitted to and approved by COJ in accordance with the Contract Documents. Regarding road closures, UF Health needs at least one lane open on all roadways to allow ambulance traffic.

Acknowledge Receipt of this Addendum on the Bid Form.

3. Question:

I want to clarify the work days and times. Are they only as Installation Note no. 18 states, or will weekday work be allowed?

Answer:

Work days are weekdays, unless otherwise requested or approved by JEA. Work will be performed between the hours of 7:00 AM and 6:00 PM. The Contractor may work either five (5) 8-hour days or four (4) 10-hour days in accordance with the Contract Documents. Sheet G2 has been revised to reflect this.

4. Clarification:

Steel Plating vs Backfilling: The consideration for steel plating as opposed to backfilling was mentioned in the Pre-bid meeting. Ultimately, the decision of which to use is up to the Contractor and either option is to be paid for as part of the excavation costs and included in the price of pipe installation.

5. Revisions to drawings:

SHEET NO. 2/ DRAWING NO. G2: Revision to Installation Notes

SHEETS NO. 5-10/ DRAWING NO. C1-C6: Revised to show Case III/IV pavement repair and 1" mill and resurface asphalt pavement notes

SHEET NO. 11/ DRAWING NO. C7: Water main piping revisions

SHEET NO. 23/ DRAWING NO. D11: Revised to show Case III/IV pavement repair and 1" mill and resurface asphalt pavement notes

Acknowledge Receipt of this Addendum on the Bid Form.