



Procurement Department Bid Office  
Customer Center 1<sup>st</sup> Floor, Room 002  
21 W. Church Street  
Jacksonville, Florida 32202

September 3, 2020

ADDENDUM NUMBER: Two (2)

TITLE: Julington Creek Plantation Control Process Rehabilitation

JEA RFQ NUMBER: 99573

BID DUE DATE: September 15, 2020

TIME OF RECEIPT: 12:00 PM

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

**GENERAL CLARIFICATIONS AND QUESTIONS FROM BIDDERS:**

**1. Correction from Addendum 1, Question 2:**

Appendix B Bid Workbook. Please confirm that this spreadsheet is provided as an equipment list for information purposes only and is NOT required to be filled out with individual component costs to be considered as a complete bid submission for this project.

**Answer:**

We will use the total (Lump Sum) of the bid as the basis of the award, not the individual costs. ~~You can either fill out the Bid Workbook or enter a lump sum bid on the Bid Form, as long as a detailed quote is included to back up your bid.~~ **However, you are required to fill out the Bid Workbook with individual component costs.**

**2. Question:**

Do the PLCs and IOs need to be conformally coated?

**Answer:**

No.

**3. Question:**

Siemens has the ability to convert SLC 500 programs. If the same functionality and time to complete listed in the specification can be achieved using Siemens equipment (JEA's typical standard), can Siemens control systems be quoted as an alternative to CompactLogix?

**Answer:**

No, JEA has determined that CompactLogix is the better solution for this facility. The equipment listed in the Bid Workbook and Technical Specifications shall be used as the equipment list for this project.

**Acknowledge Receipt of this Addendum on the Bid Form.**