

# Review History

Print Date: 8/27/2020

<p><b>CDN:</b> 4161.285  <b>Project Name:</b> 5th Street- 20" Force Main Extension  <b>Project Type:</b> Utility  <b>Status:</b> Final Approved  <b>Version#:</b> 1</p>	<p><b>Project Contact:</b> Francis Nguyen  <b>Design Prof:</b> Bruce A. Neu and Claro Magpantay  <b>Developer Company:</b> JEA  <b>Developer Phone:</b> (904)665-8139  <b>Submission#:</b> 2</p>		
<b>Reviews</b>			
Discipline	Reviewer	Review Date	Status
Traffic Signals	Carlton Copeland Copeland@coj.net (904)-255-7552	8/16/2020 3:56:00 PM	Approved with note
Sheet 88: Add arrow from note "Remove and replace existing traffic signal sensors..." for southbound thru and left turn lanes. These loops may be damaged with construction and connection to Main Water Main.			
MOT Review	John Kolczynski johnfk@coj.net (904)-255-8583	8/12/2020 12:32:47 PM	Approved
Final Approver	Kevin Robinson KevinR@coj.net (904)-255-8580	8/18/2020 9:05:52 AM	Approved with note
Per Traffic Signals review: Sheet 88: Add arrow from note "Remove and replace existing traffic signal sensors..." for southbound thru and left turn lanes. These loops may be damaged with construction and connection to Main Water Main.			