



Procurement Department Bid Office
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

October 16, 2020

ADDENDUM NUMBER: ONE (1)

TITLE: 080-20 Southside Service Center (SSSC) Asphalt Paving Improvements

BID DUE DATE: October 27, 2020

TIME OF RECEIPT: 12:00 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Revise and Replace Appendix A – Technical Specifications section 2.4 with the following language:**
 - 2.4 BITUMINOUS (ASPHALT)
 - A. **The minimum thickness of the surface course shall be 2 inches of SP 12.5 asphalt pavement.**
2. **Addition to Scope from Site Visit:** All wheel stops need to be replaced.
3. **Addition to Scope from Site Visit:** All water meter boxes, electrical boxes and valve jackets need to be brought to finished grade
4. **Addition to Scope from Site Visit:** Old fence posts, approximately 30, cut 2” minimum below finished grade or remove and backfilled with base material or asphalt.
5. **Clarification:** JEA will replace signal loops at Gates.
6. **Clarification:** Asphalt drive around the warehouse is included in phase 1 as per the drawings. Include in alternate phase 1 pricing.
7. **Clarification:** This Project is for Phase 2 and 3 only with alternate pricing provided for phase 1. Phases 4 and 5 are not part of project.
8. **Question:** Please confirm Bid Dates and Times are correct.
Answer: Bids are due October 27, 2020 at 12:00 pm EST.
9. **Question:** Please confirm budget estimate for the cost of construction.
Answer: \$600,000.00

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID FORM.