



Building Community®

Procurement Department Bid Office
Customer Center – 1st Floor, Room 002
21 W. Church Street
Jacksonville, FL 32202

April 9, 2021

ADDENDUM NUMBER: Two (2)

TITLE: Eastport Road Force Main

JEA IFB NUMBER: 025-21

PROPOSAL DUE DATE: April 13, 2021

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 02:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

JEA is responding to the following questions as shown below:

1. Question:

Bid item NO. 20 & 21 specify 10" DR11 HDPE FM for the HDD segments. Can 8" DR18 Fusible PVC® pipe be used as an equal to the HDPE?

Answer:

Yes, 8" DR18 Fusible PVC, compliant with Section 750 ll.3 HDD of the JEA Water and Wastewater Standards Manual, may be considered equal to a 10" DR11 HDPE pipe for this force main project.