

***Unit 01 Fan 1A identical arrangement



PA Fan
Silencer #1

PA Fan
Silencer #2

Weatherhoods (to be reinstalled)

SA Fan
Silencer

88" from CL to CL of PA Silencers for
external bracing design

PA Fan 2A

SA Fan 2A

Unit 02 Circulating Fluidized Bed Boiler – Primary Air (PA) and Secondary Air (SA) Fan 2A Inlets

***Unit 01 Fan 1B identical arrangement

Weatherhoods (to be reinstalled)

PA Fan
Silencer #1

PA Fan
Silencer #2

SA Fan Silencer

88" from CL to CL of PA Silencers for
external bracing design

PA Fan 2B

SA Fan 2B

Unit 02 Circulating Fluidized Bed Boiler – Primary Air (PA) and Secondary Air (SA) Fan 2B Inlets