



Building Community®

Procurement Department Bid Office
Customer Center – 1st Floor, Room 002
21 W. Church Street
Jacksonville, FL 32202

May 17, 2021

ADDENDUM NUMBER: One (1)

TITLE: Southwest -Timuquana PS Upgrade Project

JEA IFB NUMBER: 1410316046

PROPOSAL DUE DATE: June 15, 2021

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 02:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

JEA is responding to the following questions as shown below:

1. Question:

What is the required operating point for bypass pumping of the station?

Answer:

6,000 GPM at 60 TDH.

2. What are the specifications for bypass pumping? These could not be found in the project specifications.

Answer:

Per Technical Specifications Section 01 14 00 1.03, contractor shall submit shop drawings and working drawings in accordance with Section 01 33 00 to show schedules and details of all temporary services, bypasses, shutdowns, tie-ins and connections to existing systems.