Headquarters - Procurement Department
225 North Pearl Street
Jacksonville, Florida 32202

October 30, 2026

ADDENDUM NUMBER: One (1)

TITLE: Purchase of Filter Bags and Pulse Jet Filter Bag Cages

JEA SOLICITATION NUMBER: 1412229878

BID DUE DATE: November 17, 2026

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 02:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Question:** What does Standards need from us to evaluate a new supplier, and where should it be sent?

   Answer: To be considered for approval by Standards, email the specification sheet for your filters and cages to the buyer at rixlw@jea.com.

2. **Question:** Realistically, is there enough time for Standards to complete that review before intent to award on this solicitation?

   Answer: Standards should be able to review and make a decision within 1 – 2 weeks after receipt of the necessary information.

3. **Question:** Section 1.13 references liquidated damage amounts, but Section 2.51 only describes the storage obligation after May 18, 2027. Are there liquidated damages beyond that, and if so, what are they?

   Answer: No, storage at the supplier's expense is the only liquidated damages.

4. **Question:** Non-Rastex PTFE sewing thread for stitching top and bottom portions can be used for the bags?

   Answer: No, the spec sheet calls out the threading to be Rastex, type 4300, PTFE.

5. **Question:** As per our records, the scrim is PPS, please confirm. Also, what weight of scrim is required?

   Answer: The scrim is PPS and the weight per spec is 3.0 oz/sq yard

6. **Question:** Respondent would greatly appreciate the opportunity to get onsite to achieve sample approval for filters and cages, but doing this will require JEA's approval, a contact at the plant, and access to the clean-side of the baghouse (once cooled down) for approx. 1 hour. Is this possible?

   Answer: No.

7. **Question:** Please confirm: JEA intends to announce winning bidder on 12/10/2026?

   Answer: Under the current timeline, rankings will be announced at the Public Evaluation Meeting and an Intent to Award communication will be issued to all Respondents. Following these steps, the contract will go before the Awards Committee on December 10, 2026, for final approval and official award.

8. **Question:** Respondent's cage (AQCWH006) will have a black organosilicon coating applied to the cage surfaces for quality control, prevention of damage during storage, and for long-term performance once installed in the baghouse. Will this be acceptable?

   Answer: No.

9. **Question:** Are the Respondents to include "2 years" of the price increases described in section 2.42, or, are the prices for the "Immediate" and "Three Year" offerings to match, and section 2.42 will apply in the future?

   Answer: The immediate purchase price of qty 2080 Cages (AQCWH006) and 2080 Filters (FILBG004) to be ordered immediately upon awarding will be firm-fixed pricing.

   The additional long-term three-year contract pricing will be firm fixed through the first year of the contract. Per Section 2.42, the awardee may annually submit a CPI price increase request 30 days prior to the anniversary date of the contract.

   Bidders should fill out pricing in the workbook for immediate pricing and for additional demand/long-term pricing. We have separated these out in case there is a lower price for the higher volume, long term contract.

10. **Question:** Respondent would like to offer the physical labor to install bags and cages in JEA's Air Pollution Control (APC, or, baghouse / fabric filter). Is JEA interested in this offer?

    Answer: No.

11. **Question:** Respondent would very much like the opportunity to present our offer to JEA in a meeting format so we can share our story, our success, our personnel's history with JEA, etc. Would this be possible?

    Answer: Public procurement rules prohibit this type of meeting prior to the proposal due date. However, Respondents are encouraged to submit this information within their formal proposals. If JEA needs clarification on the proposal submitted, we may reach out for a recorded meeting per our procurement rules.

12. **Question:** Filter bag seam: The specification requires fused vertical seams, while the drawing indicates a "3N lap seam." Could you confirm the required longitudinal seam construction and which requirement governs?

    Answer: The JEA filter bags specification utilizes a 3N lap seam construction with thermal fusing along the vertical (longitudinal) seam. This construction incorporates both the seam configuration identified on the drawing and the fused seam requirement stated in the specification. Accordingly, our understanding is that both requirements are satisfied through this combined seam construction.

13. **Question:** Country of origin: Would Chinese-manufactured products supplied through FiltEdge LLC be eligible, subject to manufacturer approval and specification compliance?

    Answer: Chinese manufacturers are not automatically disqualified.

14. **Question:** Do the federal funding provisions and domestic preferences in Sections 3.1 and 3.9 apply to this purchase, and what origin documentation would be required?

    Answer: None of the Work is funded through a federal funding source, therefore the provisions in this section do not apply to this Solicitation. However, Respondents should read through section 1.39 Scrutinized Companies to ascertain compliance.